



Inventory Response Summary information			
PWS Name: Chambersburg Water Treatment Plant			
PWSID: 7280005			
Service Line Classification Summary			
Service Line Classification	Definition	Number	Percentage
Lead	Any portion of the service line is known to be made of lead.	0	<1%
Galvanized Requiring Replacement (GRR)	A portion of the service line is galvanized and is downstream from: - a portion that was previously lead or is of unknown lead status - connectors that are lead or unknown	30	<1%
Lead Status Unknown	The service line material is not known. There is not enough evidence to support material classification.	2,391	29%
Non-Lead	An evidence-based record, method, or technique has demonstrated	5,747	70%
<b>TOTAL NUMBER OF ACTIVE SERVICE LINES ENTERED IN THE DETAILED INVENTORY</b>		<b>8,168</b>	<b>100%</b>

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1305 Alexander Ave	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	1306 ALEXANDER	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1312 Alexander Ave	D) Copper	No	E) 1931 - 1940	lead gooseneck removed	D) Copper	
Non-Lead	1315 Alexander Ave	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1324 Alexander Ave	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1334 Alexander Avenue	D) Copper	No	E) 1931 - 1940	lead gooseneck removed	D) Copper	customer service line replaced
Non-Lead	1335/1337 Alexander Avenue	D) Copper	No	E) 1931 - 1940	lead gooseneck removed	D) Copper	
Non-Lead	1338 Alexander Ave.	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Non-Lead	1341/1343 Alexander Avenue	D) Copper	No	E) 1931 - 1940	lead gooseneck removed	H) PVC	customer service line replaced
Non-Lead	1347/1349 Alexander Avenue	D) Copper	No	E) 1931 - 1940	lead gooseneck removed	D) Copper	
Non-Lead	1411 Alexander Ave.	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	1416/1418 Alexander Avenue	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	1426/1428 Alexander Avenue	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Non-Lead	1434 Alexander Ave.	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	1438 Alexander Ave.	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	1440 ALEXANDER	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	1447 ALEXANDER	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	1529 Alexander Ave.	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	1530 Alexander Ave	D) Copper	No	O) 2011 - 2020	service line replacement	H) PVC	customer service line replaced
Non-Lead	1540 ALEXANDER	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	1551 ALEXANDER	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1574 Alexander Ave	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	1575 ALEXANDER	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	1610 ALEXANDER	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1624 ALEXANDER	D) Copper	No	G) 1951 - 1960	already copper	D) Copper	
Non-Lead	1627 ALEXANDER	D) Copper	No	K) 1981 - 1990	already copper	D) Copper	
Non-Lead	1634 ALEXANDER AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1648 ALEXANDER	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1649 ALEXANDER	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	H) PVC	
Non-Lead	1707 ALEXANDER	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	1708 ALEXANDER	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	1724 ALEXANDER	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1725 ALEXANDER	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1740 ALEXANDER	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	1741 ALEXANDER	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	1801 ALEXANDER	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1806 ALEXANDER	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	1813 ALEXANDER	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	1820 ALEXANDER	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	1823 ALEXANDER	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	1824 ALEXANDER	D) Copper	No	O) 2011 - 2020	already copper	D) Copper	customer verified copper
Non-Lead	1833 ALEXANDER	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	1843 ALEXANDER	D) Copper	No	G) 1951 - 1960	already copper	D) Copper	
Non-Lead	1511 Alexander Ave.	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Lead Status Unknown	0 APPLE BLOSSOM WAY	D) Copper	No	L) 1991 - 2000		R) Unknown - Unlikely Lead	
Non-Lead	1901 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1903 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1905 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1906 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1907 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1908 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1909 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1910 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1911 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1912 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1914 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1915 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1917 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1918 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1919 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1920 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1921 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1922 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1923 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1924 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1925 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1926 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	customer verified copper
Non-Lead	1928 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	customer verified
Non-Lead	1931 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1941 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1949 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1951 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1953 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1955 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	boc verified copper
Non-Lead	1957 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1959 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1962 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1963 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1964 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1965 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1966 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1967 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1968 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1969 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1970 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1971 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1972 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1973 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1976 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1977 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1978 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1979 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1980 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1981 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1982 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1983 ASHLEY	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	1984 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1986 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1989 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1992 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1995 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1996 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2000 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2001 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2004 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2008 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2012 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2016 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2020 ASHLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	440 ATHERTON AVE	D) Copper	No	G) 1951 - 1960	already copper	D) Copper	
Non-Lead	630 BASSETT DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	640 BASSETT DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	642 BASSETT DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	644 BASSETT DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	646 BASSETT DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	648 BASSETT DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	650 BASSETT DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	670 BASSETT DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	710 BASSETT DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	730 BASSETT DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	731 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	733 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	735 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	737 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	739 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	741 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	743 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	750 BASSETT DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	751 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	753 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	755 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	757 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	759 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	761 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	770 BASSETT	D) Copper	No	M) 2001 - 2010	Initial install of service line	D) Copper	
Non-Lead	772 BASSETT	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	773 BASSETT	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	774 BASSETT	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	775 BASSETT	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	776 BASSETT	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	777 BASSETT	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	778 BASSETT	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	779 BASSETT	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	780 BASSETT	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	781 BASSETT	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	783 BASSETT	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	10 BEACON CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	11 BEACON CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	12 BEACON CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	13 BEACON CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	14 BEACON CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	15 BEACON CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	16 BEACON CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	17 BEACON CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	18 BEACON CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	19 BEACON CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	20 BEACON CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	21 BEACON CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	22 BEACON CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	23 BEACON CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	24 BEACON CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	25 BEACON CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	26 BEACON CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	27 BEACON CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	28 BEACON CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	29 BEACON CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	30 BEACON CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	393 BEDINGTON BLVD	H) PVC - polyvinyl chloride	No	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	399 BEDINGTON BLVD	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	20 BELLOWS CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	22 BELLOWS CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	24 BELLOWS CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	26 BELLOWS CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	28 BELLOWS CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	520 BENDER AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	530 BENDER AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	540 BENDER AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	548 BENDER AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	135 BENEDICT AVE	D) Copper	No	L) 1991 - 2000		H) PVC - polyvinyl chloride	
Non-Lead	190 BENEDICT AVE	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	200 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	201 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	204 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	205 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	208 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	209 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	212 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	213 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	216 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	217 BENEDICT AVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	220 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	221 BENEDICT AVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	224 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	225 BENEDICT AVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	228 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	229 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	232 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	233 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	236 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	237 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	240 BENEDICT AVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	241 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	245 BENEDICT AVE	D) Copper	No	O) 2011 - 2020	new construction	H) PVC - polyvinyl chloride	
Non-Lead	210 BIRCH ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	211 BIRCH ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	221 BIRCH ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	231 BIRCH ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	241 BIRCH ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	251 BIRCH ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	258 BIRCH ST	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	261 BIRCH ST	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	271 BIRCH ST	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	524 BISHOP AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	528 BISHOP AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	529 BISHOP AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	541 BISHOP AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	551 BISHOP AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	561 BISHOP AVE	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Non-Lead	610 BISHOP AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	618 BISHOP AVE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	626 BISHOP AVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	634 BISHOP AVE.	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	642 BISHOP AVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	650 BISHOP AVE.	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	658 BISHOP AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	664 BISHOP AVE	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Non-Lead	672 BISHOP AVE	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Non-Lead	674 BISHOP AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Lead Status Unknown	38 BLACK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	418 BLACK AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	521 BLACK AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	560 BLACK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	590 BLACK AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	599 BLACK AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	service card states copper
Lead Status Unknown	650 BLACK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	243 BLACK GAP RD	D) Copper	No	P) 2021 - 2030	repair water leak	D) Copper	
Non-Lead	245 BLACK GAP RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	1004 BLANCHARD AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	1016 BLANCHARD AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	1021 BLANCHARD AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	739 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	747 BLANCHARD AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	765 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	777 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	805 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	already copper	D) Copper	
Non-Lead	812 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	813 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	820 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	821 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	828 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	829 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	836 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	837 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	845 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	846 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	853 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	896 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	898 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	903 BLANCHARD AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	909 BLANCHARD AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	919 BLANCHARD AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	924 BLANCHARD AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	929 BLANCHARD AVE	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	H) PVC - polyvinyl chloride	
Non-Lead	939 BLANCHARD AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	508 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	512 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	516 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	517 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	519 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	520 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	521 BRACKEN DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	523 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	524 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	525 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	527 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	528 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	529 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	531 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	532 BRACKEN DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	533 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	535 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	536 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	537 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	539 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	540 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	541 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	543 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	544 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	545 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	547 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	548 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	549 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	551 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	553 BRACKEN DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1000 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	1010 BRANDON DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	1011 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customr verified copper
Non-Lead	1015 BRANDON DR	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	1020 BRANDON Dr	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	1049 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	1050 BRANDON Dr	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	1115 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1116 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1118 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1120 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	1122 E BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1124 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1126 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1138 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	1148 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	1190 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1200 BRANDON DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1201 BRANDON DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1204 BRANDON DR	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1205 BRANDON DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1208 BRANDON DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1209 BRANDON DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1212 BRANDON DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1213 BRANDON DR	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1216 BRANDON DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1220 BRANDON DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	840 BRANDON Dr	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	849 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	850 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	853 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	860 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	863 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	870 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	873 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	880 BRANDON DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	885 BRANDON DR	D) Copper	Not sure	M) 2001 - 2010		K) PEX - cross-linked polyethylene	customer verified copper
Non-Lead	890 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	894 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	896 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	898 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	900 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	901 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	903 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	905 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	907 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	909 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	910 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	911 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	913 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	920 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	925 BRANDON Dr	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	929 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	930 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	931 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	938 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	939 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	941 E BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	boc verified copper
Non-Lead	942 BRANDON DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	945 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	946 BRANDON DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	949 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customr verified copper
Non-Lead	950 BRANDON Dr	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	951 BRANDON Dr	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	952 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	954 BRANDON Dr	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	959 BRANDON Dr	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	960 BRANDON Dr	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	961 BRANDON Dr	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	962 BRANDON Dr	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Lead Status Unknown	435 BROAD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	438 BROAD St.	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	439 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	444 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	447 BROAD ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	454 BROAD ST	O) Asbestos cement	Not sure	K) 1981 - 1990		R) Unknown - Unlikely Lead	
Non-Lead	500 BROAD St.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	501 BROAD ST	O) Asbestos cement	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	505 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	511 BROAD ST	O) Asbestos cement	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	517 BROAD ST	O) Asbestos cement	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	518 BROAD ST	O) Asbestos cement	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	521 BROAD ST	O) Asbestos cement	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	530 BROAD ST	O) Asbestos cement	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	531 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	532 BROAD ST	O) Asbestos cement	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	537 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	540 BROAD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	543 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	547 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	553 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	554 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	557 BROAD St.	D) Copper	Not sure	D) 1921 - 1930		D) Copper	BOC verified copper
Lead Status Unknown	558 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	561 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	562 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Non-Lead	565 BROAD ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	567 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Non-Lead	568 BROAD ST	D) Copper	Not sure	L) 1991 - 2000		D) Copper	BOC verified copper
Lead Status Unknown	571 BROAD ST	O) Asbestos cement	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	572 BROAD ST	O) Asbestos cement	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	577 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	580 BROAD St.	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	601 BROAD St.	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	607 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	611 BROAD St.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	617 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Non-Lead	620 BROAD St.	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Lead Status Unknown	623 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	625 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	626 BROAD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	627 BROAD St.	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Lead Status Unknown	628 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	629 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	631 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	636 BROAD ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		D) Copper	customer verified copper
Lead Status Unknown	639 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	640 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	641 BROAD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	644 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	646 BROAD St.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	649 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	650 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	651 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	652 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	656 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	657 BROAD ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		D) Copper	customer verified copper
Lead Status Unknown	663 BROAD ST	S) Unknown	Not sure	C) 1911 - 1920		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	666 BROAD ST	S) Unknown	Not sure	A) Pre-1901		D) Copper	
Lead Status Unknown	667 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	673 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	675 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	677 BROAD St.	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	679 BROAD ST	D) Copper	Not sure	C) 1911 - 1920		D) Copper	BOC verified copper
Non-Lead	680 BROAD ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	682 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	683 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	685 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	690 BROAD ST	O) Asbestos cement	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	691 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	693 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	701 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	703 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	704 BROAD ST	O) Asbestos cement	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	709 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	711 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	712 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	713 BROAD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	714 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	716 BROAD ST	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	723 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	728 BROAD ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		D) Copper	BOC verified copper
Lead Status Unknown	730 BROAD ST	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	732 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	733 BROAD ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		D) Copper	customer verified copper
Non-Lead	736 BROAD ST.	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	741 BROAD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	boc verified copper
Non-Lead	750 BROAD ST.	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	751 BROAD St.	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customr verified copper
Non-Lead	753-759 BROAD ST.	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	761-767 Broad St.	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	768 BROAD ST	O) Asbestos cement	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	771 BROAD ST	O) Asbestos cement	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	773 BROAD ST	O) Asbestos cement	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	775 BROAD ST	O) Asbestos cement	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	777 BROAD ST	O) Asbestos cement	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Non-Lead	778 BROAD St.	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Lead Status Unknown	779 BROAD ST	O) Asbestos cement	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	783 BROAD ST	R) Unknown - Unlikely Lead	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	784 BROAD ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	785 BROAD ST	O) Asbestos cement	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	787 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	791 BROAD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Lead Status Unknown	800 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	802 BROAD ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	807 BROAD ST	O) Asbestos cement	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	810 BROAD St.	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	811 BROAD ST	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	813 BROAD ST	D) Copper	No	L) 1991 - 2000		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	815 BROAD ST	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	817 BROAD ST	D) Copper	No	L) 1991 - 2000		D) Copper	
Lead Status Unknown	824 BROAD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Lead Status Unknown	828 BROAD ST	O) Asbestos cement	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	834 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	850 BROAD St.	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Lead Status Unknown	855 BROAD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	867 BROAD ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	874 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	883 BROAD St.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	886 BROAD ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	888 BROAD ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	889 BROAD ST	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	890 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	892 BROAD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	10 BROOKLINE CT.	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	12 BROOKLINE CT.	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	14 BROOKLINE CT.	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	16 BROOKLINE CT.	D) Copper	No	L) 1991 - 2000		D) Copper	boc verified copper
Non-Lead	18 BROOKLINE CT.	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	20 BROOKLINE CT.	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	22 BROOKLINE CT.	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	24 BROOKLINE CT.	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	26 BROOKLINE CT.	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	101 BROOKVIEW AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	105 BROOKVIEW AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	109 BROOKVIEW AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	110 BROOKVIEW AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	119 BROOKVIEW AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	129 BROOKVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	137 BROOKVIEW AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	142 BROOKVIEW AVE	D) Copper	No	K) 1981 - 1990	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	145 BROOKVIEW AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	211 BROOKVIEW AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	1135 BROOKWOOD DRIVE	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1137 BROOKWOOD DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1139 BROOKWOOD DRIVE	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1143 BROOKWOOD DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	101 BRUMBAUGH AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	103 BRUMBAUGH AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	107 BRUMBAUGH AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	109 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	110 BRUMBAUGH AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	111 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	113 BRUMBAUGH AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	115 BRUMBAUGH AVE	D) Copper	No	F) 1941 - 1950	removed leaed gooseneck	D) Copper	
Non-Lead	117 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	120 BRUMBAUGH AVE	D) Copper	No	J) 1971 - 1980	removed lead gooseneck	D) Copper	
Non-Lead	125 BRUMBAUGH AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	126 BRUMBAUGH AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	131 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	132 BRUMBAUGH AVE	D) Copper	No	G) 1951 - 1960	removed lead	D) Copper	
Non-Lead	140 BRUMBAUGH AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	141 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	144 BRUMBAUGH AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	150 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	151 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	201 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	215 BRUMBAUGH AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	225 BRUMBAUGH AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	228 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	247 BRUMBAUGH AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	547 BRUMBAUGH AVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	255 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	261 BRUMBAUGH AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	269 BRUMBAUGH AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	46 BRUMBAUGH AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	50 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	500/504 BRUMBAUGH AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	510/514 BRUMBAUGH AVE.	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	538 BRUMBAUGH AVE	D) Copper	Not sure	O) 2011 - 2020	utilities location	D) Copper	customer verified copper
Non-Lead	540 BRUMBAUGH AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	56 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	620 BRUMBAUGH AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	63 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	67 BRUMBAUGH AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	71 BRUMBAUGH AVE	D) Copper	Not sure	K) 1981 - 1990	REPAIR TO SERVICE CORP	D) Copper	
Non-Lead	79 BRUMBAUGH AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	80 BRUMBAUGH AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	83 BRUMBAUGH AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	102 BUCHANAN ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	104 BUCHANAN ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	106 BUCHANAN ST	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	108 BUCHANAN ST	D) Copper	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	110 BUCHANAN ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	114 BUCHANAN ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980	REPAIRED WATER SERVICE	H) PVC - polyvinyl chloride	
Non-Lead	115 BUCHANAN ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	Boc verified plastic
Non-Lead	116 BUCHANAN ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	117 BUCHANAN ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	118 BUCHANAN ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	119 BUCHANAN ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	120 BUCHANAN ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	121 BUCHANAN ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	122 BUCHANAN ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	123 BUCHANAN ST	D) Copper	No	L) 1991 - 2000		H) PVC - polyvinyl chloride	
Non-Lead	125 BUCHANAN ST	D) Copper	No	L) 1991 - 2000		H) PVC - polyvinyl chloride	
Non-Lead	127 BUCHANAN ST	D) Copper	No	L) 1991 - 2000		H) PVC - polyvinyl chloride	
Non-Lead	129 BUCHANAN ST	D) Copper	No	L) 1991 - 2000		H) PVC - polyvinyl chloride	
Non-Lead	130 BUCHANAN ST	H) PVC - polyvinyl chloride	No	J) 1971 - 1980		H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	131 BUCHANAN ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	132 BUCHANAN ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	133 BUCHANAN ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	134 BUCHANAN ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	135 BUCHANAN ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	136 BUCHANAN ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	137 BUCHANAN ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	138 BUCHANAN ST	H) PVC - polyvinyl chloride	No	J) 1971 - 1980		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	150 BUCHANAN ST	H) PVC - polyvinyl chloride	No	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	152 BUCHANAN ST	D) Copper	Not sure	L) 1991 - 2000		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	154 BUCHANAN ST	D) Copper	Not sure	L) 1991 - 2000		H) PVC - polyvinyl chloride	BOC verified plastic

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	156 BUCHANAN ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	236 W BURKHART AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	240 W BURKHART AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	244 W BURKHART AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	248 W BURKHART AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	270 W BURKHART AVE.	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	353 W BURKHART AVE	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	367 W BURKHART AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	371 W BURKHART AVE.	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	200 E BURKHART	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	274 W BURKHART AVE.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	344 W BURKHART AVE.	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		H) PVC - polyvinyl chloride	customer verified plastic
Lead Status Unknown	346 W BURKHART AVE.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	350 W BURKHART AVE.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	352 W BURKHART AVE.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	369 W BURKHART AVE.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	376 W BURKHART AVE.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	7 W BURKHART AVE.	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC verified copper
Non-Lead	201 BUTTERNUT LN	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	208 BUTTERNUT LN	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	211 BUTTERNUT LN	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	216 BUTTERNUT LN	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	223 BUTTERNUT LN	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	224 BUTTERNUT LN	D) Copper	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Non-Lead	1001 BYERS AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1002 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1003 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1004 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1005 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1006 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1007 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1008 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1009 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1010 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1011 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	1012 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1015 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	1017 BYERS AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	911 BYERS AVE.	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	912/926 BYERS AVE	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	914 BYERS AVE.	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	916 BYERS AVE.	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	918 BYERS AVE.	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	920 BYERS AVE.	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	921 BYERS AVE.	D) Copper	No	K) 1981 - 1990		D) Copper	BOC verified copper
Non-Lead	922 BYERS AVE.	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	924 BYERS AVE.	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	928-942 Byers Ave	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	931 BYERS AVE.	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	941 BYERS AVE.	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	944-958 Byers Ave.	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	959 BYERS AVE.	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	960-970 Byers Ave	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	971 BYERS AVE.	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	975 BYERS AVE.	D) Copper	Not sure	K) 1981 - 1990		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	979 BYERS AVE.	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	10 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	11 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	12 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	13 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	14 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	15 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	16 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	17 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	18 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	19 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	20 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	21 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	22 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	23 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	24 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	25 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	26 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	27 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	28 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	29 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	30 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	31 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	32 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	33 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	34 CAMBRIDGE LANE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	603 CANDLESTICK CT	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	609 CANDLESTICK CT	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	615 CANDLESTICK CT	D) Copper	No	L) 1991 - 2000		H) PVC - polyvinyl chloride	
Non-Lead	624 CANDLESTICK CT	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	627 CANDLESTICK CT	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	630 CANDLESTICK CT	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	636 CANDLESTICK CT	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	600 CANDLESTICK COURT	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	606 CANDLESTICK COURT	D) Copper	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	612 CANDLESTICK COURT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	618 CANDLESTICK COURT	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	621 CANDLESTICK COURT	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	633 CANDLESTICK COURT	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	641 CANDLESTICK COURT	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	316 CARLTON AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	317 CARLTON AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	334 CARLTON AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	335 CARLTON AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	409 CARLTON AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	321 CARLTON AVE	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	324 CARLTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	327 CARLTON AVE	D) Copper	Not sure	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	330 CARLTON AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Lead Status Unknown	540 CAROLINA CT	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	132 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	168 E CATHERINE ST	D) Copper	Not sure	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Lead Status Unknown	104 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	106 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	108 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	156 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	158 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	200 W CATHERINE ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	205 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	210 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	225 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	231 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	241 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	246 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	302 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	311 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	312 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	321 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	324 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	332 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	342 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	352 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	401 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	402 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	409 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	417 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	420 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	430 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	61 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	134 W CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	145 CEDAR ST	O) Asbestos cement	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	151 CEDAR ST	O) Asbestos cement	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	163 CEDAR ST.	O) Asbestos cement	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	411 CEDAR ST	O) Asbestos cement	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	417 CEDAR ST	O) Asbestos cement	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	419 CEDAR ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	boc verified copper
Lead Status Unknown	427 CEDAR ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	430 CEDAR ST.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Lead Status Unknown	431 CEDAR ST	O) Asbestos cement	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	433 CEDAR ST	O) Asbestos cement	Not sure	L) 1991 - 2000		R) Unknown - Unlikely Lead	
Non-Lead	449 CEDAR ST.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	330 CENTER ST.	D) Copper	No	F) 1941 - 1950	CHECKED FOR LEAD	D) Copper	boc verified copper
Non-Lead	331 CENTER ST.	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	338 CENTER ST.	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	350 CENTER ST.	D) Copper	No	F) 1941 - 1950	CHECKED FOR LEAD	D) Copper	
Non-Lead	351/355 CENTER ST.	D) Copper	No	K) 1981 - 1990	CHECKED FOR LEAD	D) Copper	boc verified copper
Non-Lead	353 CENTER ST.	D) Copper	No	P) 2021 - 2030	CHECKED FOR LEAD	D) Copper	BOC verified copper
Non-Lead	357-363 CENTER ST.	D) Copper	No	P) 2021 - 2030	CHECKED FOR LEAD	D) Copper	boc verified copper
Non-Lead	359/365 CENTER ST.	D) Copper	No	K) 1981 - 1990	CHECKED FOR LEAD	D) Copper	boc verified copper
Non-Lead	367-373 CENTER ST.	D) Copper	No	K) 1981 - 1990	CHECKED FOR LEAD	D) Copper	
Non-Lead	370 CENTER ST.	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	375 CENTER ST.	D) Copper	No	G) 1951 - 1960	CHECKED FOR LEAD	D) Copper	
Non-Lead	385 CENTER ST.	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Lead Status Unknown	440 CENTER ST.	D) Copper	No	P) 2021 - 2030		R) Unknown - Unlikely Lead	
Lead Status Unknown	442 CENTER ST.	D) Copper	No	P) 2021 - 2030		R) Unknown - Unlikely Lead	
Lead Status Unknown	446 CENTER ST.	D) Copper	No	P) 2021 - 2030		R) Unknown - Unlikely Lead	
Lead Status Unknown	450 CENTER ST.	R) Unknown - Unlikely Lead	No	C) 1911 - 1920	LEAD REMOVED ALREADY	R) Unknown - Unlikely Lead	
Non-Lead	454/456 CENTER ST.	D) Copper	No	O) 2011 - 2020	REPAIRED WATER SERVICE	D) Copper	
Non-Lead	462 CENTER ST.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	465 CENTER ST.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	511 CENTER ST.	D) Copper	No	P) 2021 - 2030		D) Copper	
Non-Lead	515 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	523 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	531 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	535 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	544 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	545 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	549 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	550 CENTER ST.	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Non-Lead	556 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	559 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	561 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	563 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC VERIFIED COPPER
Non-Lead	567 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	568 CENTER ST.	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Non-Lead	572 CENTER ST.	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	584 CENTER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	585 CENTER ST.	D) Copper	No	J) 1971 - 1980	lead already removed	D) Copper	
Non-Lead	601 CENTER ST.	D) Copper	No	P) 2021 - 2030	checked for lead	D) Copper	
Lead Status Unknown	280 CENTRAL AVE.	D) Copper	No	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Non-Lead	414 CENTRAL AVE.	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	505 /507CENTRAL AVE.	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	562/564 CENTRAL AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	100 CHAMBERS HILL DR	E) Cast iron - lined	No	O) 2011 - 2020		E) Cast iron - lined	
Non-Lead	110 CHAMBERS HILL DR	E) Cast iron - lined	No	O) 2011 - 2020		E) Cast iron - lined	
Non-Lead	111 CHAMBERS HILL DR	E) Cast iron - lined	No	O) 2011 - 2020		E) Cast iron - lined	
Non-Lead	120 CHAMBERS HILL DR	E) Cast iron - lined	No	O) 2011 - 2020		E) Cast iron - lined	
Non-Lead	123 CHAMBERS HILL DR	E) Cast iron - lined	No	O) 2011 - 2020		E) Cast iron - lined	
Non-Lead	124 CHAMBERS HILL DR	E) Cast iron - lined	No	O) 2011 - 2020		E) Cast iron - lined	
Non-Lead	125 CHAMBERS HILL DR	E) Cast iron - lined	No	O) 2011 - 2020		E) Cast iron - lined	
Non-Lead	127 CHAMBERS HILL DR	E) Cast iron - lined	No	O) 2011 - 2020		E) Cast iron - lined	
Non-Lead	129 CHAMBERS HILL DR	E) Cast iron - lined	No	O) 2011 - 2020		E) Cast iron - lined	
Non-Lead	23 CHAMBERS ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	45 CHAMBERS ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	55 CHAMBERS ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	302 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	304 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	306 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	308 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	314 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	316 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	318 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	324 CHANNING DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	326 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	328 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	330 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	331 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	332 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	CUSTOMER VERIFIED COPPER
Non-Lead	333 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPPER
Non-Lead	334 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	335 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	336 CHANNING DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	338 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	341 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	343 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	344 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	345 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	346 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	347 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	348 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	349 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	350 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	351 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	352 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	353 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	CUSTOMER VERIFIED COPPER
Non-Lead	354 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	355 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	356 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	358 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	361 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	363 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	364 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	365 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	366 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	367 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	368 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	369 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	370 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	371 CHANNING	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	372 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	378 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	380 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	382 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	384 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	386 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	388 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	390 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	392 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	398 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	400 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	402 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	404 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	406 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	408 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	410 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	411 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	412 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	413 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	415 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	417 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	418 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	419 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	420 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	421 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	422 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	424 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	427 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	429 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	430 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	431 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	432 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	433 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	434 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	435 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	436 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	437 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	438 CHANNING DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	100 CHEREE DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	101 CHEREE DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	102 CHEREE DR	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	103 CHEREE DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	104 CHEREE DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	105 CHEREE DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	106 CHEREE DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	107 CHEREE DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	108 CHEREE DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	109 CHEREE DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	110 CHEREE DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	111 CHEREE DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	112 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	113 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	114 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	115 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	116 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	117 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	118 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	119 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	120 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	121 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	122 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	123 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	124 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	126 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	128 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	130 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	132 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	134 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	136 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	138 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	140 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	142 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	144 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	146 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	148 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	150 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	152 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	154 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	156 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	158 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	160 CHEREE DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	NEW CONSTRUCTION
Non-Lead	35 CHERRY AVE	D) Copper	No	K) 1981 - 1990		H) PVC - polyvinyl chloride	customer verified copper
Non-Lead	47 CHERRY AVE	D) Copper	No	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	89 CHERRY AVE	D) Copper	No	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Lead Status Unknown	0 CLEVELAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	450 CLEVELAND AVE	O) Asbestos cement	Not sure	J) 1971 - 1980		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	485/501 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	489 CLEVELAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	518 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	550 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	690 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	692 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	694 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	696 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	698 CLEVELAND AVE	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	boc verified plastic
Non-Lead	702/704 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	708/710 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	712 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030		D) Copper	
Non-Lead	714 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	722 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	724 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	740 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	748 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	752 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	786 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	788 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	792 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	796 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	798 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	800 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	
Non-Lead	802 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	
Non-Lead	804 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	
Non-Lead	846 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	848 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	850 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	852 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	858 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	859 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	904 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	914 CLEVELAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1600 CLINTON AVE	D) Copper	No	G) 1951 - 1960		D) Copper	
Non-Lead	1609 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1610 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1619 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1625 CLINTON AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1631 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1640 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1641 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1650 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1707 CLINTON AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	1719 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1730 CLINTON AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	1733 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1743 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1750 CLINTON AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1801 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1824 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	1825 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1841 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1851 CLINTON AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	1858 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1861 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1870 CLINTON AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	1881 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1900 CLINTON AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1901 CLINTON AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1907 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1913 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1919 CLINTON AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1920 CLINTON AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1922 CLINTON AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1924 CLINTON AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1925 CLINTON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1926 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1928 CLINTON AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1930 CLINTON AVE	D) Copper	Not sure	L) 1991 - 2000		H) PVC - polyvinyl chloride	
Non-Lead	1931 CLINTON AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1934 CLINTON AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1936 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1937 CLINTON AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1938 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1940 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1942 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1943 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1946 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1948 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1949 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1950 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1952 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1954 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1955 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1956 CLINTON AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1958 CLINTON AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1960 CLINTON AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1961 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1962 CLINTON AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1964 CLINTON AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1966 CLINTON AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1967 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1968 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1972 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	verified copper
Non-Lead	1973 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1976 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1979 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1980 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1984 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1985 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1988 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1991 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1994 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1997 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	2000 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	2003 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	2005 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	2006 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	2007 CLINTON AVE	D) Copper	No	L) 1991 - 2000		D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	3043 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3046 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3048 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3050 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3052 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3054 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3058 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3060 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3062 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3064 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3066 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3068 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3070 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3072 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3076 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3077 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3078 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3079 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3080 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3081 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3082 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3083 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3084 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3085 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3086 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3087 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3088 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3089 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3090 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	3091 CLINTON AVE	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	18 CLOVER CIRCLE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	22 CLOVER CIRCLE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	24 CLOVER CIRCLE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	26 CLOVER CIRCLE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	30 N COLDBROOK AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	320 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	321 S COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	333 S COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	334 S COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	343 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	344 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	354 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	367 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	380 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	383 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	390 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	401 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	402 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	404 S COLDBROOK AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	406 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	417 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	433 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	446 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	447 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	BOC verified copper
Non-Lead	460 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	523 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	524 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	539 S COLDBROOK AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	540 S COLDBROOK AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	611 S COLDBROOK AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	641 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		D) Copper	BOC verified copper
Non-Lead	650 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	665 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	677 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	678 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	687 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	711 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Lead Status Unknown	741 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Lead Status Unknown	756 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	771 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	790 S COLDBROOK AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	101 N COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	104 N COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	110 N COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	162 N COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	166 N COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	170 N COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Non-Lead	208 N COLDBROOK AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Lead Status Unknown	231 N COLDBROOK AVE	D) Copper	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	263 N COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Non-Lead	38 N COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	39 N COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	40 N COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	1012 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Lead Status Unknown	1015 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1020 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	1021 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		Q) Unknown - Likely Lead	
Lead Status Unknown	1030 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		Q) Unknown - Likely Lead	
Lead Status Unknown	1031 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		Q) Unknown - Likely Lead	
Non-Lead	1039 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1040 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	1051 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	customer verified copper
Non-Lead	1060 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1061 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1070 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1071 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
GRR	1103 S COLDBROOK AVE	D) Copper	No	O) 2011 - 2020		C) Galvanized	
GRR	1104 S COLDBROOK AVE	D) Copper	No	O) 2011 - 2020		C) Galvanized	
Lead Status Unknown	1153 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	1230 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1233 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	1236 S COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	1244 S COLDBROOK AVE	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Lead Status Unknown	1331 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	1350 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	139 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	141 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	144 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	151 S COLDBROOK AVE	D) Copper	No	F) 1941 - 1950		D) Copper	customer verified copper
Lead Status Unknown	155 S COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	customer verified copper



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	175 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	176 S COLDBROOK AVE	D) Copper	No	E) 1931 - 1940		D) Copper	
Non-Lead	179 S COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	181 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	183 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	185 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	197 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	207 S COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	209 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	214 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	219 S COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	227 S COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	233 S COLDBROOK AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	customer verified copper
Non-Lead	234 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	306 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	326 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	351 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	368 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	621 S COLDBROOK AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	634 S COLDBROOK AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	638 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		Q) Unknown - Likely Lead	
Non-Lead	668 S COLDBROOK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	830 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	boc verified copper
Non-Lead	831 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	833 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	834 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	838 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	839 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		Q) Unknown - Likely Lead	
Lead Status Unknown	844 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	845 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	851 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	852 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	858 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	859 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	864 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	865 S COLDBROOK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	904 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		Q) Unknown - Likely Lead	
Non-Lead	905 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	914 S COLDBROOK AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	915 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	922 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	923 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	930 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		Q) Unknown - Likely Lead	
Lead Status Unknown	931 S COLDBROOK AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		Q) Unknown - Likely Lead	
Non-Lead	938 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	939 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	946 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	949 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	952 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	957 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	960 S COLDBROOK AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	118 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	132 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	151 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	214 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	239 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	240/242 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	241 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	252 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	253 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	257 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	260 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	263 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	
Non-Lead	269/271 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	274 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	276 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	287 COLLEGE AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	30 COLLEGE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	105 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	123 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	33 W COMMERCE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	41 W COMMERCE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	42 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	45 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	48 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	49 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	52 W COMMERCE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	102 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	103 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	108 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	113 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	114/118 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	117 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	129 W COMMERCE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	220 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	227 W COMMERCE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Lead Status Unknown	305 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	336 W COMMERCE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	340 W COMMERCE ST	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	customer verified copper
GRR	352 W COMMERCE ST	C) Galvanized	Not sure	F) 1941 - 1950		C) Galvanized	
Lead Status Unknown	380 W COMMERCE ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Non-Lead	412 W COMMERCE ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Lead Status Unknown	420 W COMMERCE ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	421 W COMMERCE ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	56 W COMMERCE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	44 CONNER AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	47 CONNER AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	50 CONNER AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	55 CONNER AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	58 CONNER AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	306 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	309 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	310 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	313 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	314 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	317 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	318 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	321 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	322 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	325 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	326 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	329 COSELL DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	330 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	333 COSELL DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	334 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	337 COSELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	338 COSELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	341 COSELL DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	342 COSELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	345 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	349 COSELL DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	350 COSELL DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	353 COSELL DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	357 COSELL DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	358 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	361 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	365 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	366 COSELL DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Lead Status Unknown	305 CUMBERLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	311 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	service checked no lead	D) Copper	
Non-Lead	315 CUMBERLAND AVE	D) Copper	No	G) 1951 - 1960	lead gooseneck removed	D) Copper	
Non-Lead	319 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Non-Lead	325 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Non-Lead	335 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Non-Lead	346 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020	lead gooseneck removed	D) Copper	customer verified copper
Non-Lead	351 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Non-Lead	353 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020	lead gooseneck removed	D) Copper	customer verified copper
Non-Lead	354 CUMBERLAND AVE	D) Copper	No	G) 1951 - 1960	lead gooseneck removed	D) Copper	
Non-Lead	357 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Non-Lead	366 CUMBERLAND AVE	D) Copper	No	G) 1951 - 1960	service checked no lead	D) Copper	boc verified copper
Non-Lead	376 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Non-Lead	414 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Non-Lead	416 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Non-Lead	425 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Non-Lead	426 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	service checked no lead	D) Copper	boc verified copper
Non-Lead	431 CUMBERLAND AVE	D) Copper	No	M) 2001 - 2010	REPLACED WATER SERVICE	D) Copper	
Non-Lead	441 CUMBERLAND AVE	D) Copper	Not sure	F) 1941 - 1950	REPLACED WATER SERVICE	D) Copper	
Non-Lead	444 CUMBERLAND AVE	D) Copper	No	K) 1981 - 1990	REPLACED WATER SERVICE	D) Copper	
Non-Lead	447 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	REPLACED WATER SERVICE	D) Copper	
Non-Lead	448 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	REPLACED WATER SERVICE	D) Copper	customer verified copper
GRR	455 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	REPLACED WATER SERVICE	C) Galvanized	
GRR	458 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	REPLACED WATER SERVICE	C) Galvanized	boc verified galvanized
Non-Lead	461 CUMBERLAND AVE	D) Copper	Not sure	J) 1971 - 1980	service checked no lead	D) Copper	
Non-Lead	462 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	REPLACED WATER SERVICE	D) Copper	customer verified copper
Non-Lead	505 CUMBERLAND AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	514 CUMBERLAND AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	515 CUMBERLAND AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
GRR	520 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020		C) Galvanized	
Non-Lead	523 CUMBERLAND AVE	D) Copper	Not sure	O) 2011 - 2020		D) Copper	boc verified copper
Non-Lead	524 CUMBERLAND AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	531 CUMBERLAND AVE	D) Copper	No	J) 1971 - 1980	SERVICE CHECKED NO LEAD	D) Copper	
Non-Lead	532 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	SERVICE CHECKED NO LEAD	D) Copper	customer verified copper
Lead Status Unknown	538 CUMBERLAND AVE	D) Copper	No	K) 1981 - 1990	SERVICE CHECKED NO LEAD	R) Unknown - Unlikely Lead	
Non-Lead	539 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020	SERVICE CHECKED NO LEAD	D) Copper	customer verified copper
Non-Lead	547 CUMBERLAND AVE	D) Copper	No	M) 2001 - 2010	REPALCED WATER SERVICE	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	550 CUMBERLAND AVE	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	555 CUMBERLAND AVE	D) Copper	No	L) 1991 - 2000	REPAIRED WATER SERVICE	D) Copper	
Lead Status Unknown	558 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	563 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020	REPALCED WATER SERVICE	D) Copper	
Non-Lead	564 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	573 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	602 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	K) PEX	BOC verified pex
Non-Lead	609 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	REPAIRED WATER SERVICE	H) PVC - polyvinyl chloride	
Non-Lead	610 CUMBERLAND AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	619 CUMBERLAND AVE	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
GRR	623 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020	REPLACED WATER SERVICE	C) Galvanized	
Non-Lead	626 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Non-Lead	630 Cumberland Ave.	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	632 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970	checked for lead,none	D) Copper	customer verified copper
Non-Lead	635 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020	REPLACED WATER SERVICE	D) Copper	customer verified copper
Non-Lead	637 CUMBERLAND AVE	D) Copper	No	M) 2001 - 2010	no lead	D) Copper	customer verified copper
Lead Status Unknown	647 CUMBERLAND AVE	R) Unknown - Unlikely Lead	No	M) 2001 - 2010	CHECKED FOR LEAD	R) Unknown - Unlikely Lead	
Non-Lead	650 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020	checked no lead	D) Copper	customer verified copper
Non-Lead	654 CUMBERLAND AVE	D) Copper	No	J) 1971 - 1980	CHECKED FOR LEAD	D) Copper	
Non-Lead	657 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020	removed lead	D) Copper	
Non-Lead	658 CUMBERLAND AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	659 CUMBERLAND AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	664 CUMBERLAND AVE	D) Copper	No	O) 2011 - 2020	no lead lead gooseneck	D) Copper	
Non-Lead	683 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970	CHECKED FOR LEAD	D) Copper	
Non-Lead	685 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970	CHECKED FOR LEAD	D) Copper	
Non-Lead	687 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970	CHECKED FOR LEAD	D) Copper	
Non-Lead	688 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	689 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970	CHECKED FOR LEAD	D) Copper	
Non-Lead	691 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970	CHECKED FOR LEAD	D) Copper	BOC VERIFIED COPPER
Non-Lead	693 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970	CHECKED FOR LEAD	D) Copper	
Non-Lead	695 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	696 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	698 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	699 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	700 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	702 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	704 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	705 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	706 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	708 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	709 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	710 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	711 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	712 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	713 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	715 CUMBERLAND AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	717 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	719 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	721 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	723 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	725 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	727 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	729 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	731 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	735 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	737 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	739 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	741 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	743 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	745 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	747 CUMBERLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	750 Cumberland Ave	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	780 Cumberland Ave	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	901 CYPRESS ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	902 CYPRESS ST	D) Copper	No	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Lead Status Unknown	905 CYPRESS ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	906 CYPRESS ST	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	913 CYPRESS ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	914 CYPRESS ST	H) PVC - polyvinyl chloride	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	920 CYPRESS ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	925 CYPRESS ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	926 CYPRESS ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	931 CYPRESS ST	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	932 CYPRESS ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	938 CYPRESS ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	943 CYPRESS ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	944 CYPRESS ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	950 CYPRESS ST	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	956 CYPRESS ST	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	59 DARTMOUTH GREEN CT	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	50 DARTMOUTH GREEN CT	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	51 DARTMOUTH GREEN CT	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	58 DARTMOUTH GREEN CT	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	66 DARTMOUTH GREEN CT	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	67 DARTMOUTH GREEN CT	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	75 DARTMOUTH GREEN CT	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	83 DARTMOUTH GREEN CT	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	334 DEBRINA CT	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	338 DEBRINA CT	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	342 DEBRINA CT	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	346 DEBRINA CT	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	27 DELANO DR	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	1 DELANO DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	101 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	102 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	103 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	104 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	105 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	106 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	107 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	108 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	109 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	11 DELANO DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	110 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	111 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	112 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	113 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	114 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	115 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	116 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	118 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	120 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	122 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	124 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	126 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	128 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	13 DELANO DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	130 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	132 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	134 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	136 DELANO DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	138 DELANO DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	140 DELANO DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	142 DELANO DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	144 DELANO DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	149 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	15 DELANO DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	151 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	153 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	155 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	157 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	159 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	161 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	163 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	165 DELANO DR	H) PVC - polyvinyl chloride	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	167 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	169 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	17 DELANO DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	171 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	173 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	175 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	177 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	179 DELANO DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	18 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	180 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	182 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	184 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	186 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	188 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	19 DELANO DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	190 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	192 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	20 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	21 DELANO DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	22 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	23 DELANO DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	24 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	25 DELANO DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	26 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	28 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	29 DELANO DR	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	3 DELANO DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	30 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	31 DELANO DR	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	32 DELANO DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	33 DELANO DR	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	5 DELANO DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	7 DELANO DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC VERIFIED COPPER
Non-Lead	9 DELANO DR	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Lead Status Unknown	150 DERBYSHIRE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	925 DEWBERRY CT	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	930 DEWBERRY CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	935 DEWBERRY CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	939 DEWBERRY CT	H) PVC - polyvinyl chloride	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	940 DEWBERRY CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	943 DEWBERRY CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	customer verified
Non-Lead	946 DEWBERRY CT	D) Copper	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	boc verified plastic
Non-Lead	950 DEWBERRY CT	H) PVC - polyvinyl chloride	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	925 DUNCAN AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	941 DUNCAN AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	951 DUNCAN AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	961 DUNCAN AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	971 DUNCAN AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	980 DUNCAN AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	981 DUNCAN AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	995 Duncan Ave	D) Copper	No	F) 1941 - 1950		D) Copper	
Non-Lead	544 EAST POINT	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	546 East Point Ave	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	1050 E BRANDON	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Non-Lead	165 E Catherine st	D) Copper	No	O) 2011 - 2020	already copper	D) Copper	boc verified copper
Lead Status Unknown	277 E CATHERINE ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	303 E Catherine St	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	308 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	328 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	330 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	332 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	334 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	337 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	338 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	339 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	343 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	344 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	345 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	346 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	347 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Lead Status Unknown	350 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	351 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	358 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	already copper	D) Copper	customer verified copper
Non-Lead	360 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	361 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	363 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	364 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	365 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	367 E CATHERINE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	368 E CATHERINE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Lead Status Unknown	387 E CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	397 E CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	398 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	401 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	429 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	430 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	435 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	442 E Catherine st	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	447 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	448 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	451 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	455 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	459 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	460 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	463 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	464 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed leaed gooseneck	D) Copper	
Lead Status Unknown	468 E CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	469 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	474 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	475 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	478 E Catherine st	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	481 E CATHERINE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	500 E CATHERINE ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	505 E CATHERINE ST	D) Copper	No	J) 1971 - 1980	removed lead gooseneck	D) Copper	
Non-Lead	508 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	509 E CATHERINE ST	D) Copper	Not sure	J) 1971 - 1980	alrready copper	D) Copper	
Non-Lead	511 E CATHERINE ST	D) Copper	Not sure	J) 1971 - 1980	already copper	D) Copper	customer verified copper
Non-Lead	512 E CATHERINE ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	530 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	555 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	559 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	565 E CATHERINE ST	O) Asbestos cement	Not sure	A) Pre-1901		D) Copper	boc verified copper
Non-Lead	568 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	569 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	573 E CATHERINE ST	D) Copper	No	J) 1971 - 1980	removed lead gooseneck	D) Copper	
Non-Lead	614 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	626 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	764 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	119 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	128 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	already copper	D) Copper	
Non-Lead	131 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	135-139 E CATHERINE ST	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	147 E CATHERINE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	148 E CATHERINE ST	D) Copper	No	C) 1911 - 1920	removed lead gooseneck	D) Copper	
Non-Lead	151 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	153 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	154 E CATHERINE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	157 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	158 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	166 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	167 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	170 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	boc verified copper
GRR	171 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	replaced service main to cv	C) Galvanized	
Non-Lead	173 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	185 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	207 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	222 E Catherine St	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	227 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	232 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	233 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	239 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	240 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	245 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	already copper	D) Copper	
Non-Lead	246 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	249/251 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	255 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	256 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	261 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	262 E CATHERINE ST	D) Copper	No	C) 1911 - 1920	removed lead gooseneck	D) Copper	
Non-Lead	265 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	270 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	271 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	272 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	274 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	275 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	276 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	279 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	280 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	302 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	309 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	312 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	315 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	316 E CATHERINE ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	356 E CATHERINE ST	D) Copper	Not sure	M) 2001 - 2010	REPAIRED LEAK AT MAIN	D) Copper	
Non-Lead	362 E CATHERINE ST	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	366 E CATHERINE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	373 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	402 E CATHERINE ST	D) Copper	No	G) 1951 - 1960		D) Copper	
Non-Lead	408/410 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	414 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	415 E CATHERINE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	420/424 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	440 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	442/443 E CATHERINE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	503 E CATHERINE ST	D) Copper	Not sure	C) 1911 - 1920		D) Copper	customer verified copper
Non-Lead	507 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	BOC VERIFIED COPPER
Non-Lead	515/521 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	518 E CATHERINE ST	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	525 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	526 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	527 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	528 E CATHERINE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	535 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	541 E CATHERINE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	545 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	554 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	558 E CATHERINE ST	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	verified copper
Non-Lead	572 E CATHERINE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	580 E CATHERINE ST	D) Copper	No	D) 1921 - 1930	lead already removed	D) Copper	
Non-Lead	583 E CATHERINE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	606 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	610 E Catherine St	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC VERIFIED COPPER
Non-Lead	625 E CATHERINE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	630 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	720 E CATHERINE ST	D) Copper	No	P) 2021 - 2030	emoved lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	728 E CATHERINE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	BOC VERIFIED COPPER
Non-Lead	736 E CATHERINE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	744 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	750 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	760 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	770 E Catherine St	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	776 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	782 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	803 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	808 E CATHERINE ST	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	817 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	818 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	819 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	824 E CATHERINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1038 EDGAR AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	1040 EDGAR AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1046 EDGAR AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Non-Lead	1048 EDGAR AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	1050 EDGAR AVE	D) Copper	Not sure	C) 1911 - 1920		D) Copper	
Non-Lead	1052 EDGAR AVE	D) Copper	Not sure	C) 1911 - 1920		D) Copper	
Non-Lead	1144 EDGAR AVE	D) Copper	Not sure	C) 1911 - 1920		D) Copper	
Non-Lead	1146 EDGAR AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Non-Lead	1208 EDGAR AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	1220 EDGAR AVE	D) Copper	Not sure	C) 1911 - 1920		D) Copper	
Non-Lead	1230 EDGAR AVE	D) Copper	Not sure	C) 1911 - 1920		D) Copper	
Non-Lead	1306 EDGAR AVE	D) Copper	No	C) 1911 - 1920	removed lead from gooseneck	D) Copper	customer verified copper
Non-Lead	1312 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1318 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1328 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1331 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1411 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	
Non-Lead	1414 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1422 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1441 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1515 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1520 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1528 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1534 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1545 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1559 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	1611 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1614 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1615 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1619 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1640 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1680 EDGAR AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	1710 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	
Non-Lead	801 EDGAR AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	870 EDGAR AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	902 EDGAR AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	10 EDGELEA DRIVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	104 EDGELEA DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	108 EDGELEA DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	112 EDGELEA DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	116 EDGELEA DRIVE	D) Copper	Not sure	L) 1991 - 2000		H) PVC - polyvinyl chloride	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	14 EDGELEA DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	15 EDGELEA DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	19 EDGELEA DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	28 EDGELEA DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	31 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	32 EDGELEA DRIVE	D) Copper	No	O) 2011 - 2020	REPAIRED WATER SERVICE	D) Copper	
Non-Lead	36 EDGELEA DRIVE	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	40 EDGELEA DRIVE	D) Copper	No	P) 2021 - 2030	REPAIRED WATER SERVICE	H) PVC - polyvinyl chloride	
Non-Lead	41 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	44 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	47 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	48 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	52 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	53 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC verified copper
Non-Lead	56 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	59 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	60 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	64 EDGELEA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	65 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	68 EDGELEA DRIVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	71 EDGELEA DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	72 EDGELEA DRIVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	76 EDGELEA DRIVE	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	80 EDGELEA DRIVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	84 EDGELEA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	88 EDGELEA DRIVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	89 EDGELEA DRIVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	9 EDGELEA DRIVE	D) Copper	No	G) 1951 - 1960	REMOVED LEAD	D) Copper	
Non-Lead	92 EDGELEA DRIVE	D) Copper	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	customer verified pvc
Non-Lead	96 EDGELEA DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	115 EDWARDS AVE	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	130 EDWARDS AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	150 EDWARDS AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	204 EDWARDS AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	144 SOUTH EIGHTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	H) PVC - polyvinyl chloride	
Lead Status Unknown	155 SOUTH EIGHTH	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	164 SOUTH EIGHTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	174 SOUTH EIGHTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	184 SOUTH EIGHTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	194 SOUTH EIGHTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	240 SOUTH EIGHTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	250 SOUTH EIGHTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	438 SOUTH EIGHTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	439 SOUTH EIGHTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	444 SOUTH EIGHTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	445 SOUTH EIGHTH ST	D) Copper	No	P) 2021 - 2030	LEAD REMOVED ALREADY	R) Unknown - Unlikely Lead	
Non-Lead	100 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	101 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	110 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	111 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	boc verified copper
Non-Lead	120 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	121 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	130 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	131 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	140 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	141 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	150 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	151 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	160 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	161 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	170 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	171 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	180 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	181 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	190 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	191 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	boc verified copper
Non-Lead	230 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	233 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	234 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	237 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	241 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	242 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	245 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	246 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	249 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	250 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	253 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	254 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	257 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	258 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	262 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	266 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	270 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	274 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	278 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	282 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	301 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	305 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	309 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	313 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	317 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	321 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	325 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	329 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	333 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	401 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	405 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	409 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	413 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	417 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	420 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	421 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	424 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	425 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	428 EISENHOWER DRIVE	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	429 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	432 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	433 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	436 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	437 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	440 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	441 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	444 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	445 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	448 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	449 EISENHOWER DRIVE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	45 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	50 EISENHOWER DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	320 ELDER ST.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	334 ELDER ST.	D) Copper	No	G) 1951 - 1960	CHECKED FOR LEAD	D) Copper	
Non-Lead	335 ELDER ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	
Non-Lead	345 ELDER ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	
Non-Lead	346 ELDER ST.	D) Copper	Not sure	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	349 ELDER ST.	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSNECK	D) Copper	customer verified copper
Non-Lead	351 ELDER ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	BOC verified copper
Non-Lead	354 ELDER ST.	D) Copper	No	H) 1961 - 1970	CHECKED FOR LEAD	D) Copper	
Non-Lead	357 ELDER ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	
Non-Lead	362 ELDER ST.	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSNECK	D) Copper	customer verified copper
Non-Lead	363 ELDER ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	
Non-Lead	372/376 ELDER ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	
Non-Lead	375 ELDER ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	
Non-Lead	377 ELDER ST.	D) Copper	No	J) 1971 - 1980	REMOVED LEAD GOOSNECK	D) Copper	
Non-Lead	379 ELDER ST.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	382/384 ELDER ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	
Non-Lead	391/395 ELDER ST.	D) Copper	No	K) 1981 - 1990	CHECKED FOR LEAD	D) Copper	boc verified copper
Non-Lead	419 ELDER ST.	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	421 ELDER ST.	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	500 ELDER ST.	D) Copper	No	O) 2011 - 2020	already copper	D) Copper	
Non-Lead	504 ELDER ST.	D) Copper	No	J) 1971 - 1980	removed lead gooseneck	D) Copper	
Non-Lead	510 ELDER ST.	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	511 ELDER ST.	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	518 ELDER ST.	D) Copper	No	A) Pre-1901	removed lead gooseneck	D) Copper	
Non-Lead	527 ELDER ST.	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	530 ELDER ST.	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	540/543 ELDER ST.	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSNECK	D) Copper	
Non-Lead	541 ELDER ST.	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	542 ELDER ST.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	546 ELDER	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	547 ELDER ST.	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	552 ELDER ST.	D) Copper	Not sure	F) 1941 - 1950	removed lead goosneck	D) Copper	
Non-Lead	556 ELDER ST.	D) Copper	Not sure	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	560 ELDER ST.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	431 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	449 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	456 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	470 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	471 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	472 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	473 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	478 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	492/494 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	500 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	504 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	514 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	518 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC VERIFIED COPPER

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	522 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	
Non-Lead	540 ELM AVE.	D) Copper	Not sure	C) 1911 - 1920		D) Copper	
Non-Lead	551 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	569 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	572 ELM AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	617 ELM AVE.	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	355 ELROCK DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	365ELROCK DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	380 ELROCK DR	D) Copper	No	K) 1981 - 1990		D) Copper	BOC verified copper
Non-Lead	385 ELROCK DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	392 ELROCK DR	D) Copper	No	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	401 ELROCK DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	404 ELROCK DR	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	410 ELROCK DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	415 ELROCK DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	420 ELROCK DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	423 ELROCK DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	432 ELROCK DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	435 ELROCK DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	414 EPIC DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	418 EPIC DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	422 EPIC DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	426 EPIC DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	430 EPIC DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	613/617 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	637/639 FAIRGROUND AVE	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Non-Lead	700 FAIRGROUND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	702 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	710 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	716 FAIRGROUND AVE	D) Copper	Not sure	O) 2011 - 2020	removed lead gooseneck	D) Copper	BOC VERIFIED COPPER
Non-Lead	717 FAIRGROUND AVE	D) Copper	Not sure	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	721 FAIRGROUND AVE	D) Copper	Not sure	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	726/728FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	734 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	738/742 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	739 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	744 FAIRGROUND AVE	D) Copper	Not sure	O) 2011 - 2020	removed lead gooseneck	D) Copper	BOC verified copper
Non-Lead	745/747 FAIRGROUND AVE	D) Copper	Not sure	O) 2011 - 2020	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	748/752 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	751 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	757 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	765/769 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	770 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	771/775 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	787 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	788 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck		
Non-Lead	708 FAIRGROUND AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	111 S FEDERAL ST	D) Copper	Not sure	M) 2001 - 2010	renew water service	D) Copper	
Non-Lead	125 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	16 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	20 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	23 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	26 S FEDERAL ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	26/28 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	29 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	30/34 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Lead Status Unknown	33 S FEDERAL ST	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	40 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	47 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	48 N FEDERAL ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	50 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	52/54 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	53 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	56 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	59 S FEDERAL ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	60 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	61 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	64 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	65 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Lead Status Unknown	67/69 N FEDERAL ST	D) Copper	No	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Non-Lead	68 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	69 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	72 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	74/76 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	75 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	78 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	79 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	82 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Lead Status Unknown	83 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	84 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Lead Status Unknown	40 N FEDERAL ST	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	47 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Lead Status Unknown	63 N FEDERAL ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	83 N FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Lead Status Unknown	102 S FEDERAL ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	129 S FEDERAL ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	140 S FEDERAL ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	18 S FEDERAL ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	boc verified copper
Lead Status Unknown	29 S FEDERAL ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	64 S FEDERAL ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	65 S FEDERAL ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	1004 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	1013 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	1014 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	1021 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1029 S FIFTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1036 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	1039 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	1040 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	1044 S FIFTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSNECK	D) Copper	customer verified copper
Lead Status Unknown	1047 S FIFTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSNECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	105 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	1054 S FIFTH ST	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	
Non-Lead	1058 S FIFTH ST	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	
Non-Lead	1063 S FIFTH ST	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	BOC VERIFIED COPPER
Non-Lead	1070 S FIFTH ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	1071 S FIFTH ST	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSNECK	D) Copper	boc verified copper
Non-Lead	1075 S FIFTH ST	D) Copper	No	L) 1991 - 2000		D) Copper	
Lead Status Unknown	1102 S FIFTH ST	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	1103 S FIFTH ST	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	113 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC verified copper
Lead Status Unknown	1148 S FIFTH ST	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Non-Lead	115 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	118/120 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	1230-1244 S FIFTH ST	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	R) Unknown - Unlikely Lead	
Lead Status Unknown	124 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	125 FIFTH AVE	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Non-Lead	1311 S FIFTH ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Lead Status Unknown	1317 S FIFTH ST	D) Copper	Not sure	J) 1971 - 1980		R) Unknown - Unlikely Lead	
Non-Lead	1321 S FIFTH ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1331 S FIFTH ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1332 S FIFTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	1338 S FIFTH ST	S) Unknown	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	1341-1347 S FIFTH ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Lead Status Unknown	1348 S FIFTH ST	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	135 FIFTH AVE	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	148 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	149 FIFTH AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Lead Status Unknown	19 FIFTH AVE	O) Asbestos cement	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	204 FIFTH AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	211 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	216 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	221 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	222 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	227 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	232 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Lead Status Unknown	237 FIFTH AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	242 FIFTH AVE	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	245 FIFTH AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	25 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	252 FIFTH AVE	D) Copper	No	C) 1911 - 1920	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	253 FIFTH AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	boc verified copper
Lead Status Unknown	307 FIFTH AVE	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	31 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	310 FIFTH AVE	S) Unknown	Not sure	A) Pre-1901		H) PVC - polyvinyl chloride	
Non-Lead	317 S FIFTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	319 S FIFTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	320 FIFTH AVE	H) PVC - polyvinyl chloride	Not sure	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Lead Status Unknown	325 FIFTH AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	330 FIFTH AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	331 FIFTH AVE	D) Copper	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	37 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	44 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	440FIFTH AVE	E) Cast iron - lined	No	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	46 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	47 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	48 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	540 FIFTH AVE	O) Asbestos cement	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	55 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	56 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	602 Fifth Ave	O) Asbestos cement	No	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	610 FIFTH AVE	D) Copper	No	F) 1941 - 1950		R) Unknown - Unlikely Lead	
GRR	62 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	C) Galvanized	boc verified galv
Lead Status Unknown	65 FIFTH AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	750 FIFTH AVE	P) Other non-lead material	Not sure	L) 1991 - 2000	ductile	R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	761 Fifth Ave	O) Asbestos cement	No	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	765 FIFTH AVE	R) Unknown - Unlikely Lead	Not sure	L) 1991 - 2000		R) Unknown - Unlikely Lead	
Lead Status Unknown	767 Fifth Ave	O) Asbestos cement	No	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	785 FIFTH AVE	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	797 Fifth Ave	O) Asbestos cement	No	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	805 S FIFTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	815 S FIFTH ST	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	820 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	825 Fifth Ave	O) Asbestos cement	No	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	828 S FIFTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	829 S FIFTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	830 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	835 Fifth Ave	O) Asbestos cement	No	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	840 FIFTH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	843 S FIFTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	850 FIFTH AVE	O) Asbestos cement	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	906 S FIFTH ST	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	916 S FIFTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	919 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	926 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	929 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	934 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	937 S FIFTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	940 S FIFTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	943 S FIFTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	946 S FIFTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	949 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	951 S FIFTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	956 S FIFTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	970 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	978 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	982 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	983 S FIFTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	319 FIFTH AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	1232-1242 S FIFTH ST	D) Copper	No	O) 2011 - 2020	already copper	R) Unknown - Unlikely Lead	
Non-Lead	375 FLORAL AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	380 FLORAL AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	390 FLORAL AVE	D) Copper	No	P) 2021 - 2030		D) Copper	
Non-Lead	394 FLORAL AVE	D) Copper	Not sure	P) 2021 - 2030		D) Copper	
Non-Lead	398 FLORAL AVE	D) Copper	No	P) 2021 - 2030		D) Copper	
Non-Lead	724 FLORAL AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	725 FLORAL AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	740 FLORAL AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	743 FLORAL AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	764 FLORAL AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	1 FOLTZ AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	3 FOLTZ AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1001 S FOURTH ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Non-Lead	1004 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1018 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1024 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1028 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1029 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1035 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1036 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1039 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1044 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1047 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1102 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1107 S FOURTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	1111 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1117 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1120 S FOURTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	1131 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1137 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	115 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	117 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	1229 S FOURTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	123 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	1239 S FOURTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	124 S FOURTH ST	D) Copper	Not sure	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	1255 S FOURTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	129 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	131 N FOURTH ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	1312 S FOURTH ST	D) Copper	Not sure	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Non-Lead	132 S FOURTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	1332 S FOURTH ST	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	136 S FOURTH ST	D) Copper	No	K) 1981 - 1990	lead already removed	D) Copper	
Non-Lead	139 S FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	boc verified copper
Non-Lead	140 S FOURTH ST	D) Copper	No	O) 2011 - 2020	lead already removed	D) Copper	
Lead Status Unknown	143 N FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	145 S FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Lead Status Unknown	151 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	153 N FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	155 N FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	158 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	
Lead Status Unknown	159 N FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	161 N FOURTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	162 S FOURTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	H) PVC - polyvinyl chloride	
Non-Lead	165 N FOURTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	169 N FOURTH ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	170 S FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Lead Status Unknown	173 N FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	174 S FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	177 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	179 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	181 N FOURTH ST	D) Copper	No	C) 1911 - 1920	removed lead gooseneck	D) Copper	
Lead Status Unknown	183 N FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	19 S FOURTH ST	R) Unknown - Unlikely Lead	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	20 N FOURTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	21/25 N FOURTH ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	218/220 S FOURTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	231 S FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Lead Status Unknown	233/235 S FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Non-Lead	243 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	249 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	255 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	261 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	267 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	315/319 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	33/37 N FOURTH ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	453 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	454 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	455 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	471 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	499 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	500 S FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Lead Status Unknown	503 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	512 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	
Lead Status Unknown	517/519 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	520 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	523 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	524 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	526 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	527 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	530 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	552 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	557 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	561 S FOURTH ST	H) PVC - polyvinyl chloride	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	customer verified pvc
Non-Lead	563 S FOURTH ST	H) PVC - polyvinyl chloride	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	565/567 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	568/570 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	569 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	580/584 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	589 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	597 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	598 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	60 N FOURTH ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	62 N FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	629 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	633/635 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	637/639 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	70 N FOURTH ST	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	701 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	725 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	74 N FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	747 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	78 N FOURTH ST	D) Copper	Not sure	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	800 S FOURTH ST	D) Copper	Not sure	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	805 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	807 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	818 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	820 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	821 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	827 S FOURTH ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	837 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	840 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	847 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	901 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	906 S FOURTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	918 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	923 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	924 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	941 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	949 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	950 S FOURTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	956 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	959 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	964 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	969 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	972 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	145 N FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	customer verified copper
Lead Status Unknown	1240 S FOURTH ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	153 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	157 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	159 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	161 S FOURTH ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	181 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	260 S FOURTH ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	312 S FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	318 S FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	320 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	323 S FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	324 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	327 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	330 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	333 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	334 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	430 S FOURTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	431 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	436 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	444 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	446 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	448 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	449 S FOURTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Non-Lead	450 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	452 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	492 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	498 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	501 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	592 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	643 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	645 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	649 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	826 S FOURTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	111 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	137/139 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	14 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	217 N FRANKLIN ST	D) Copper	No	M) 2001 - 2010		D) Copper	
Lead Status Unknown	225-1 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Non-Lead	245 N FRANKLIN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	317 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Lead Status Unknown	33 S FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	36 S FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	39 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	401 N FRANKLIN ST	F) Cast iron - unlined	Not sure	M) 2001 - 2010		E) Cast iron - lined	
Non-Lead	444 N FRANKLIN ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	448 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	450 N FRANKLIN ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	466 N FRANKLIN ST	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	481 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Non-Lead	500 N FRANKLIN ST	D) Copper	Not sure	O) 2011 - 2020		K) PEX - cross-linked polyethylene	
Lead Status Unknown	51 S FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
GRR	517 N FRANKLIN ST	C) Galvanized	Not sure	C) 1911 - 1920		C) Galvanized	
Lead Status Unknown	524 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Lead Status Unknown	528 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Non-Lead	533535 N FRANKLIN ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	538 N FRANKLIN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	545 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	548 N FRANKLIN ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	55 N FRANKLIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	550 N FRANKLIN ST	D) Copper	No	P) 2021 - 2030		D) Copper	BOC VERIFIED COPPER
Non-Lead	553 N FRANKLIN ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	557 N FRANKLIN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	BOC verified copper
Lead Status Unknown	570 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	573 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	619 N FRANKLIN ST	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	640 N FRANKLIN ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	649 N FRANKLIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	651 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Non-Lead	71 N FRANKLIN ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	80 S FRANKLIN ST	D) Copper	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	81 S FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	834 N FRANKLIN ST	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	938/964 N FRANKLIN ST	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	138-150 FRANKLIN FARM LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	154 FRANKLIN FARMS LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	181 FRANKLIN FARMS LANE	E) Cast iron - lined	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	201 FRANKLIN FARMS LANE	E) Cast iron - lined	No	H) 1961 - 1970		E) Cast iron - lined	
Non-Lead	425 FRANKLIN FARMS LANE	E) Cast iron - lined	No	H) 1961 - 1970		E) Cast iron - lined	
Non-Lead	625 FRANKLIN FARMS LANE	E) Cast iron - lined	No	L) 1991 - 2000		D) Copper	
Lead Status Unknown	107 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	109 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	110 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	122 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	125 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	126 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	127 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	129 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	130 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	145 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC verified copper
Lead Status Unknown	149 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	153 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	155 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	201 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	219 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	233 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	241 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	25 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	305 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC verified copper
Lead Status Unknown	309 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	31 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	311 N FRANKLIN ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	313 N FRANKLIN ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Lead Status Unknown	321 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	327 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	35 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	398 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	416 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	422 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	426 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	432 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	436 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	452 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	454 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	462 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	472 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	474 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	476 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	513 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	514 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	521 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	525 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	531 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	532 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	542 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	546 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	556 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	57 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	59 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	602 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	612 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	67 N FRANKLIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	69 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	73 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	747 N FRANKLIN ST	D) Copper	No	H) 1961 - 1970		H) PVC - polyvinyl chloride	boc verified plastic
Non-Lead	768 N FRANKLIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Lead Status Unknown	77 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	785 N FRANKLIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	83 N FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	861 N FRANKLIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Non-Lead	862 N FRANKLIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Non-Lead	910 N FRANKLIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Lead Status Unknown	131 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	25 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	26 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	27 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	29 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	35 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	37 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	38 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	39 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	49 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	53 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	55 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	61 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	65 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	79 S FRANKLIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	131 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	136 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	141 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	146/150 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	147 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC verified copper
Lead Status Unknown	15 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	155 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC verified copper
Lead Status Unknown	16/18 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	17/21 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	205 GARBER ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Non-Lead	218 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	22 GARBER ST	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	233 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	234 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	238 GARBER ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	242 GARBER ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	26 GARBER ST	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	29/31 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	30/34 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	40/44 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	41 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	48 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	53/55 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	54 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	60 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	61 /63 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	64/66 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC verified copper
Lead Status Unknown	67/69 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	68 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	85 GARBER ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC verified copper
Lead Status Unknown	109 GARFIELD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	117-119 GARFIELD ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	122-124 GARFIELD ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	123 GARFIELD ST	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	125 GARFIELD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	130 GARFIELD ST	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	151 GARFIELD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	155 GARFIELD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	160 GARFIELD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	161 GARFIELD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	165/167 GARFIELD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	168 GARFIELD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC verified copper
Lead Status Unknown	171 GARFIELD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	176 GARFIELD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	182 GARFIELD ST	D) Copper	Not sure	O) 2011 - 2020	REPLACED MAIN TO C.V	D) Copper	
Lead Status Unknown	219/221 GARFIELD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	225 GARFIELD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	231 GARFIELD ST	D) Copper	No	K) 1981 - 1990	LEAD ALREADY REMOVED	D) Copper	
Lead Status Unknown	235 GARFIELD ST	R) Unknown - Unlikely Lead	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	239 GARFIELD ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	244/246 GARFIELD ST	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	247 GARFIELD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	250/252 GARFIELD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	251 GARFIELD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	254/258 GARFIELD ST	D) Copper	No	H) 1961 - 1970	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	255/257 GARFIELD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	261/263 GARFIELD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	329 GARFIELD ST	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	336 GARFIELD ST	D) Copper	No	J) 1971 - 1980	LEAD ALREADY REMOVED	H) PVC - polyvinyl chloride	
Non-Lead	337 GARFIELD ST	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	341 GARFIELD ST	D) Copper	No	H) 1961 - 1970	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	343 GARFIELD ST	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	355 GARFIELD ST	D) Copper	No	H) 1961 - 1970	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	359 GARFIELD ST	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	361 GARFIELD ST	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	711 GARFIELD ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	721 GARFIELD ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	744 GARFIELD ST	D) Copper	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	765 E GARFIELD ST	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	400 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	424 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	428 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	432 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	434 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	438 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	440 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	442 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	450 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	451 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	452 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	454 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	456 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	461 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	462 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	464 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	470 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	471 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	475 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	480 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	481 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	488 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	489 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	491 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	493 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	494 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	495 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	497 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	500 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified pvc
Non-Lead	520 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	540 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	561 GATEWAY AVE.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	819 GEYER DRIVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	823 GEYER CIRCLE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	827 GEYER CIRCLE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	831 GEYER CIRCLE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	835 GEYER CIRCLE	D) Copper	No	L) 1991 - 2000		D) Copper	BOC verified copper
Non-Lead	839 GEYER CIRCLE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	843 GEYER CIRCLE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	850 GEYER DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	872 GEYER DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	873 GEYER DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	875 GEYER DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	876 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	877 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	879 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	880 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	881 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	883 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	884 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	885 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	BOC verified copper
Non-Lead	887 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	888 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	889 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	891 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	892 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	893 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	895 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	896 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	897 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	899 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	900 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	901 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	903 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	904 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	905 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	907 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	908 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	909 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	911 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	912 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	915 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	916 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	919 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	920 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	923 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	924 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	927 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	928 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	931 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	932 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	935 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	936 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	939 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	940 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	943 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	944 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	947 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	948 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	951 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	952 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	955 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	956 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	959 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	960 GEYER DRIVE	D) Copper	No	I) 1991 - 2000		D) Copper	
Non-Lead	963 GEYER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	964 GEYER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	967 GEYER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	971 GEYER DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	975 GEYER DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Lead Status Unknown	120 E GILBERT AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	101 GLEN ST.	D) Copper	No	H) 1961 - 1970	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	123 GLEN ST.	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	125 GLEN ST.	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	126 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	127 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	128 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	135 GLEN ST.	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	146 GLEN ST.	D) Copper	No	P) 2021 - 2030	ALREADY REMOVED LEAD	D) Copper	
Non-Lead	154 GLEN ST.	D) Copper	No	D) 1921 - 1930	ALREADY REMOVED LEAD	D) Copper	
Non-Lead	204 GLEN ST.	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	207 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	210 GLEN ST.	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	211 GLEN ST.	D) Copper	No	O) 2011 - 2020	ALREADY REMOVED LEAD	D) Copper	customer verified copper
Non-Lead	214 GLEN ST.	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	224 GLEN ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	23 GLEN ST.	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	231 GLEN ST.	D) Copper	No	G) 1951 - 1960	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Non-Lead	241 GLEN ST.	D) Copper	No	H) 1961 - 1970	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	248 GLEN ST.	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	251 GLEN ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	29 GLEN ST.	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	300 GLEN ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	303 GLEN ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	308 GLEN ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	315 GLEN ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	316 GLEN ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	32 GLEN ST.	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	322 GLEN ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	325 GLEN ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	328 GLEN ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	329 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	33 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	333 GLEN ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	34 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	345 GLEN ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	350 GLEN ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	357 GLEN ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	360 GLEN ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	366 GLEN ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	369 GLEN ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	374 GLEN ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	377 GLEN ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	38 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	380 GLEN ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	386/388 GLEN ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	394 GLEN ST.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	44 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	48 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	52 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	53 GLEN ST.	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	55/57 GLEN ST.	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	56/62 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	BOC verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	61 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	66 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	81/83 GLEN ST.	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	91 GLEN ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	BOC verified copper
Non-Lead	97 GLEN ST.	D) Copper	No	H) 1961 - 1970	REMOVED LEAD GOOSENECK	D) Copper	BOC verified copper
Non-Lead	105 GRANDVIEW AVE.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	110 GRANDVIEW AVE.	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	112 GRANDVIEW AVE.	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	114 GRANDVIEW AVE.	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	116 GRANDVIEW AVE.	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	121 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	127 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	131 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	132 GRANDVIEW AVE.	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	141 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	153 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	205 GRANDVIEW AVE.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	217 GRANDVIEW AVE.	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	222 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	232 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	233 GRANDVIEW AVE.	H) PVC - polyvinyl chloride	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	243 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	244 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	252 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	261 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	304 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	305 GRANDVIEW AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	315 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	323 GRANDVIEW AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	328 GRANDVIEW AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	333 GRANDVIEW AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	338 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	343 GRANDVIEW AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	350 GRANDVIEW AVE.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	357 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	360 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	367 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	370 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	376 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	377 GRANDVIEW AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	384 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	407 GRANDVIEW AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	420 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	421 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	427 GRANDVIEW AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	432 GRANDVIEW AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	436 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	440 GRANDVIEW AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	444 GRANDVIEW AVE.	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	452 GRANDVIEW AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	466 GRANDVIEW AVE.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	460 GRANDVIEW AVE.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	75 GRANDVIEW AVE.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	83 GRANDVIEW AVE.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	86 GRANDVIEW AVE.	D) Copper	Not sure	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	87 GRANDVIEW AVE.	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	91 GRANDVIEW AVE.	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	48 GRANDVIEW CROSSING	D) Copper	No	O) 2011 - 2020		D) Copper	
Lead Status Unknown	MISSTAKE 59 GRANDVIEW CROSSING	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	51 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	53 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	55 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	56 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	57 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	59 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	61 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	63 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	64 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	72 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	74 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	76 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	78 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	79 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	80 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	82 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	84 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified
Non-Lead	86 GRANDVIEW CROSSING	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	207 GRANT ST	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Lead Status Unknown	209 GRANT ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	211 GRANT ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	227 GRANT ST	H) PVC - polyvinyl chloride	Not sure	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Non-Lead	240 GRANT ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	
Non-Lead	247 GRANT ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	
Non-Lead	251 GRANT ST.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	253 GRANT ST.	H) PVC - polyvinyl chloride	No	P) 2021 - 2030	REMOVED LEAD	H) PVC - polyvinyl chloride	
Non-Lead	255 GRANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	customer verified copper
Lead Status Unknown	260 GRANT ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	342 GRANT ST.	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	372 GRANT ST.	D) Copper	No	M) 2001 - 2010	REMOVED LEAD	R) Unknown - Unlikely Lead	
Lead Status Unknown	406 GRANT ST	D) Copper	No	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Non-Lead	409 GRANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	
Non-Lead	450 GRANT ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	
Lead Status Unknown	474 GRANT ST.	R) Unknown - Unlikely Lead	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	100 GREEN MEADOW LN	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1028 GREYSTONE CIRCLE	H) PVC - polyvinyl chloride	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1029 GREYSTONE CIRCLE	H) PVC - polyvinyl chloride	No	K) 1981 - 1990		D) Copper	
Non-Lead	1030 GREYSTONE CIRCLE	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	1033 GREYSTONE CIRCLE	D) Copper	No	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	1034 GREYSTONE CIRCLE	H) PVC - polyvinyl chloride	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1038 GREYSTONE CIRCLE	H) PVC - polyvinyl chloride	No	K) 1981 - 1990		D) Copper	
Non-Lead	1042 GREYSTONE CIRCLE	H) PVC - polyvinyl chloride	No	K) 1981 - 1990		D) Copper	
Lead Status Unknown	417 GUILFORD AVE	D) Copper	No	F) 1941 - 1950	ALREADY COPPER	R) Unknown - Unlikely Lead	
Non-Lead	420/430 GUILFORD AVE	D) Copper	Not sure	J) 1971 - 1980	already copper	D) Copper	
Non-Lead	421 GUILFORD AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Lead Status Unknown	422 GUILFORD AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	424 GUILFORD AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	426 GUILFORD AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	428 GUILFORD AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	440 GUILFORD AVE	D) Copper	Not sure	M) 2001 - 2010	renewed water lines	R) Unknown - Unlikely Lead	
Lead Status Unknown	442 GUILFORD AVE	D) Copper	Not sure	M) 2001 - 2010	renewed water lines	R) Unknown - Unlikely Lead	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	443 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	444 GUILFORD AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	445 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	446 GUILFORD AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	448 GUILFORD AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	450 GUILFORD AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	460 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	already copper	D) Copper	
Non-Lead	461 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	467 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	500 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	512 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	518 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Lead Status Unknown	523 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	528 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	537 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	542 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	547 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	already copper	R) Unknown - Unlikely Lead	
Non-Lead	552 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	558 GUILFORD AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	564 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	567/569 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Lead Status Unknown	579 GUILFORD AVE	D) Copper	Not sure	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Non-Lead	602 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	605 GUILFORD AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	614 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	636 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	650 GUILFORD AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	652 GUILFORD AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Lead Status Unknown	653 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	661 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	668 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	D) Copper	customer verified copper
Non-Lead	671 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	698 GUILFORD AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	201 N HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	202 N HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	209 N HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	210 N HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	217 N HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	218 N HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	225 N HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	301 S HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	302 S HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	309 S HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	314 S HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	315 S HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	320 S HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	326 S HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	331 S HACKBERRY DR	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	332 S HACKBERRY DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	104 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	105 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	114 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	115 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	124 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	125 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	134 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	135 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	144 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	145 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	154 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	155 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	boc verified copper
Non-Lead	165 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	175 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	185 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	195 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	205 HAMILTON RD	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	215 HAMILTON RD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	225 HAMILTON RD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	439 HAMILTON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Non-Lead	440 HAMILTON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Non-Lead	441 HAMILTON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Non-Lead	444 HAMILTON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Lead Status Unknown	445 HAMILTON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Non-Lead	446 HAMILTON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Non-Lead	449 HAMILTON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Non-Lead	454 HAMILTON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Non-Lead	455 HAMILTON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Non-Lead	459 HAMILTON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Non-Lead	501 HAMILTON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Lead Status Unknown	51 HAMILTON RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	55 HAMILTON RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	74 HAMILTON RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	75 HAMILTON RD	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	84 HAMILTON RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	85 HAMILTON RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	94 HAMILTON RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	95 HAMILTON RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	118 S HARRISON AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	124 N HARRISON AVE	D) Copper	No	P) 2021 - 2030		D) Copper	
Non-Lead	275 S HARRISON AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	320 S HARRISON AVE	D) Copper	No	J) 1971 - 1980	already copper	D) Copper	
Non-Lead	325 S HARRISON AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Lead Status Unknown	603 HARRISON DR	D) Copper	No	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Non-Lead	611 HARRISON DR	D) Copper	No	L) 1991 - 2000	already copper	D) Copper	
Non-Lead	619 HARRISON DR	D) Copper	No	L) 1991 - 2000	already copper	D) Copper	
Non-Lead	627 HARRISON DR	H) PVC - polyvinyl chloride	No	J) 1971 - 1980	already copper	H) PVC - polyvinyl chloride	
Non-Lead	635 HARRISON DR	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	650 HARRISON	D) Copper	No	O) 2011 - 2020	already copper	D) Copper	
Lead Status Unknown	651 HARRISON DR	D) Copper	No	O) 2011 - 2020	already copper	R) Unknown - Unlikely Lead	
Lead Status Unknown	670 HARRISON DR	D) Copper	No	O) 2011 - 2020	already copper	R) Unknown - Unlikely Lead	
Non-Lead	671 HARRISON DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Lead Status Unknown	23 HAZEL	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	25 HAZEL	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	26 HAZEL	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	30 HAZEL	D) Copper	No	P) 2021 - 2030	removed lead goosencek	R) Unknown - Unlikely Lead	
Lead Status Unknown	38 HAZEL	S) Unknown	Not sure	A) Pre-1901		D) Copper	boc verified copper
Non-Lead	42 HAZEL	D) Copper	No	P) 2021 - 2030	removed lead goosencek	D) Copper	customer verified copper
Non-Lead	50 HAZEL	D) Copper	No	P) 2021 - 2030	removed lead goosencek	D) Copper	customer verified copper
Non-Lead	58 HAZEL	D) Copper	No	P) 2021 - 2030	removed lead goosencek	D) Copper	customer verified copper
Lead Status Unknown	66 HAZEL	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	67 HAZEL	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	72 HAZEL	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	404 HEINTZELMAN	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	410 HEINTZELMAN	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	448 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	449 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	452 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	453 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	457 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	458 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	460 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	463 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	467 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	471 /475 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	477 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	483 HEINTZELMAN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Lead Status Unknown	604 HEINTZELMAN	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		E) Cast iron - lined	boc verified ductile
Non-Lead	1 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	10 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	11 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	12 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	13 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		H) PVC - polyvinyl chloride	
Non-Lead	15 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	17 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	19 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	2 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	20 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	22 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	24 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	26 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	3 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	4 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	5 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	6 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	7 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	8 HEMLOCK CIRCLE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	216 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	217 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
GRR	222 HIGH ST	D) Copper	No	P) 2021 - 2030	already copper	C) Galvanized	
Lead Status Unknown	224/226 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	225 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	227 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	231/233 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	234/236 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	239 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	241 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	243 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	244 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	247 HIGH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	248/250 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	257 HIGH ST	D) Copper	No	P) 2021 - 2030	already copper	D) Copper	
Non-Lead	258 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	259 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	269 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	304 HIGH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	308 HIGH ST	D) Copper	No	P) 2021 - 2030	already copper	D) Copper	BOC verified copper
Lead Status Unknown	311/315 HIGH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	312 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	316 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	325 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	331 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	334/336 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	337/339 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	342/344 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	359 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	510 HIGH ST	D) Copper	No	P) 2021 - 2030	already copper	R) Unknown - Unlikely Lead	
Non-Lead	529 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	538 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	539 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	554 HIGH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	555 HIGH ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	645 HIGH ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	708 HIGH ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	715 HIGH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	720 HIGH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	721 HIGH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	126 S HIGHFIELD LN	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	134 N HIGHFIELD LN	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	139 N HIGHFIELD	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	140 N HIGHFIELD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	145 N HIGHFIELD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	146 N HIGHFIELD	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	151 N HIGHFIELD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	152 N HIGHFIELD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	158 N HIGHFIELD	D) Copper	No	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	164 N HIGHFIELD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	165 N HIGHFIELD	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	169 N HIGHFIELD LN	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	113 S. HIGHFIELD LN	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	121 S. HIGHFIELD LN	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	129 S. HIGHFIELD LN	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	423 HIGHLAND AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	424 HIGHLAND AVE	D) Copper	No	F) 1941 - 1950	ALREADY COPPER	D) Copper	BOC verified copper
Non-Lead	432 HIGHLAND AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	433 HIGHLAND AVE	D) Copper	No	K) 1981 - 1990	REPLACED MAIN TO C.V	D) Copper	
Non-Lead	442 HIGHLAND AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	447 HIGHLAND AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	454 HIGHLAND AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	455 HIGHLAND AVE	D) Copper	No	H) 1961 - 1970	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	470 HIGHLAND AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	530 HIGHLAND AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	531 HIGHLAND AVE	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	546 HIGHLAND AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	549 HIGHLAND AVE	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	561 HIGHLAND AVE	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	571 HIGHLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	601 HIGHLAND AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	boc verified copper
Non-Lead	604 HIGHLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	boc verified copper
Non-Lead	623 HIGHLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	624 HIGHLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	642 HIGHLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	700 HIGHLAND AVE	D) Copper	Not sure	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	724 HIGHLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	726 HIGHLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	727 HIGHLAND AVE	D) Copper	Not sure	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	728 HIGHLAND AVE	D) Copper	Not sure	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	729 HIGHLAND AVE	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	730 HIGHLAND AVE	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	731 HIGHLAND AVE	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	732 HIGHLAND AVE	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	734 HIGHLAND AVE	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	735 HIGHLAND AVE	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	736 HIGHLAND AVE	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	BOC verified copper
Non-Lead	737 HIGHLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1080 HOLLYWELL AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1081 HOLLYWELL AVE	E) Cast iron - lined	Not sure	H) 1961 - 1970		E) Cast iron - lined	
Non-Lead	1089 HOLLYWELL AVE	E) Cast iron - lined	Not sure	H) 1961 - 1970		E) Cast iron - lined	
Non-Lead	1096 HOLLYWELL AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1097 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1105 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1113 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1120 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1121 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1128 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1129 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1136 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1137 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1144 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1145 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1152 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1153 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Lead Status Unknown	1160 HOLLYWELL AVE	R) Unknown - Unlikely Lead	Not sure	L) 1991 - 2000		R) Unknown - Unlikely Lead	
Non-Lead	1161 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1168 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1169 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1176 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1177 HOLLYWELL AVE	E) Cast iron - lined	Not sure	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	1180 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		E) Cast iron - lined	
Lead Status Unknown	1184 HOLLYWELL AVE	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	1188 HOLLYWELL AVE	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Lead Status Unknown	1192 HOLLYWELL AVE	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	1196 HOLLYWELL AVE	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1260 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1276 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1292 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1308 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1324 HOLLYWELL AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Lead Status Unknown	1340 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1412 HOLLYWELL AVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1416 HOLLYWELL AVE	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1420 HOLLYWELL AVE	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1424 HOLLYWELL AVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1428 HOLLYWELL AVE	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1432 HOLLYWELL AVE	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1436 HOLLYWELL AVE	D) Copper	No	K) 1981 - 1990		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1440 HOLLYWELL AVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1444 HOLLYWELL AVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1448 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1452 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1456 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1464 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1468 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1472 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1476 HOLLYWELL AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1480 HOLLYWELL AVE	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Non-Lead	1484 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1488 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	400 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	410 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	419 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	420 HOLLYWELL AVE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	430 HOLLYWELL AVE	D) Copper	No	O) 2011 - 2020	lead gooseneck removed	D) Copper	
Non-Lead	434 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	lead gooseneck removed	D) Copper	customer verified copper
Non-Lead	439 HOLLYWELL AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Lead Status Unknown	441 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	445 HOLLYWELL AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Lead Status Unknown	464 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	475 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	519 HOLLYWELL AVE	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	R) Unknown - Unlikely Lead	
Non-Lead	520 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	533 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	535 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	539 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	540 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	543 HOLLYWELL AVE	R) Unknown - Unlikely Lead	No	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Non-Lead	572 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	ALREADY COPPER	D) Copper	
Non-Lead	585 HOLLYWELL AVE	D) Copper	No	M) 2001 - 2010	lead gooseneck removed	D) Copper	
Non-Lead	586 HOLLYWELL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	587 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	lead gooseneck removed	D) Copper	
Non-Lead	589 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	lead gooseneck removed	D) Copper	
Non-Lead	591 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	lead removed	D) Copper	
Non-Lead	593 HOLLYWELL AVE	D) Copper	No	M) 2001 - 2010	lead gooseneck removed	D) Copper	
Non-Lead	595 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	lead gooseneck removed	D) Copper	
Non-Lead	597 HOLLYWELL AVE	D) Copper	No	M) 2001 - 2010	lead gooseneck removed	D) Copper	
Non-Lead	599 HOLLYWELL AVE	D) Copper	No	M) 2001 - 2010	lead gooseneck removed	D) Copper	
Non-Lead	602 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	614 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	631 HOLLYWELL AVE	D) Copper	No	H) 1961 - 1970	already copper	D) Copper	
Non-Lead	637 HOLLYWELL AVE	D) Copper	No	H) 1961 - 1970	already copper	D) Copper	
Non-Lead	640 HOLLYWELL AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Lead Status Unknown	641 HOLLYWELL AVE	D) Copper	No	H) 1961 - 1970	already copper	R) Unknown - Unlikely Lead	
Lead Status Unknown	642 HOLLYWELL AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	647 HOLLYWELL AVE	D) Copper	No	H) 1961 - 1970	already copper	D) Copper	
Non-Lead	651 HOLLYWELL AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	657 HOLLYWELL AVE	D) Copper	No	O) 2011 - 2020	already copper	D) Copper	
Lead Status Unknown	670 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	671 HOLLYWELL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	675-679 HOLLYWELL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	725 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	800 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	940 HOLLYWELL AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	950 HOLLYWELL AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	100 HOOD ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	323 HOOD	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	325/327 HOOD	D) Copper	No	P) 2021 - 2030	LEAD GOOSENECK REMOVED	D) Copper	
Non-Lead	33 HOOD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	333/335 HOOD	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	337/339 HOOD	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	347/349 HOOD	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	401 HOOD	C) Galvanized	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Non-Lead	407 HOOD	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Non-Lead	411 /413 HOOD	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Lead Status Unknown	425 HOOD ST.	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	427 HOOD	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Non-Lead	429 HOOD ST.	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Lead Status Unknown	439 HOOD ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	R) Unknown - Unlikely Lead	
Non-Lead	447 HOOD ST.	D) Copper	No	L) 1991 - 2000	LEAD ALREADY REMOVED	D) Copper	
Lead Status Unknown	461 HOOD ST.	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	507 HOOD ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	R) Unknown - Unlikely Lead	
Non-Lead	513 HOOD ST.	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	H) PVC - polyvinyl chloride	
Lead Status Unknown	517 HOOD ST	D) Copper	No	P) 2021 - 2030	LEAD REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	519 HOOD ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	R) Unknown - Unlikely Lead	
Non-Lead	525 HOOD ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	
Non-Lead	537 HOOD ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD	D) Copper	
Non-Lead	565 HOOD ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	customer verified copper
Non-Lead	567 HOOD ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	customer verified copper
Non-Lead	575 HOOD ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	
Lead Status Unknown	577 HOOD ST	D) Copper	No	P) 2021 - 2030	lead gooseneck removed	R) Unknown - Unlikely Lead	
Non-Lead	117 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	119 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	121 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	123 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	125 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	127 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	129 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	131 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	133 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	135 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	136 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	138 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	140 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	142 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	144 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	146 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	148 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	150 HORIZON WAY	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	241 HORST AVE.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD	D) Copper	
Lead Status Unknown	320 HORST AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	321 HORST AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	326 HORST AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	333 HORST AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	336 HORST AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	341 HORST AVE.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	344 HORST AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	347 HORST AVE.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)			Customer Owned Portion of the Service Line (Curbstop to Building)		
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	74 HORST AVE.	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	77 HORST AVE.	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1051 HOUSER RD.	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	1053 HOUSER RD.	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	912 HOUSER RD.	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	924 HOUSER RD.	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	950 HOUSER RD.	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	110 HUDSON AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	115 HUDSON AVE	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	209 HUDSON AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	241 HUDSON AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	351 HUDSON AVE	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	361 HUDSON AVE	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	384 HUDSON AVE	D) Copper	No	G) 1951 - 1960	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	385 HUDSON AVE	D) Copper	No	G) 1951 - 1960		D) Copper	
Lead Status Unknown	70 HUDSON AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	110 INDUSTRIAL DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	118 INDUSTRIAL DRIVE	D) Copper	Not sure	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Non-Lead	120 INDUSTRIAL DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	130 INDUSTRIAL DRIVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	147 INDUSTRIAL DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	185 INDUSTRIAL DRIVE	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	190 INDUSTRIAL DRIVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	34 INDUSTRIAL DRIVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	40 INDUSTRIAL DRIVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	49 INDUSTRIAL	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	69 INDUSTRIAL	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	80 INDUSTRIAL DRIVE	D) Copper	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	89 INDUSTRIAL DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	201 E IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	209 E IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	217 E IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	225 E IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	0 W IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	301 W IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	302 W IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	305 W IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	308 W IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	309 W IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	313 W IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	317 W IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	323 W IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Non-Lead	327 W IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	331 W IRVA DR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	201 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	205 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	209 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	213 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	217 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	221 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	225 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified brass
Non-Lead	229 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	233 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	237 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	238 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	241 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	242 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	245 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	246 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	249 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	250 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	253 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	254 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	257 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	258 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	261 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	262 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	265 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	266 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	269 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	273 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	277 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	281 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	285 JUSTINE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	100 KELBY DR	D) Copper	No	P) 2021 - 2030		D) Copper	
Non-Lead	101 KELBY DR	D) Copper	No	P) 2021 - 2030		D) Copper	
Non-Lead	102 KELBY DR	D) Copper	No	P) 2021 - 2030		D) Copper	
Non-Lead	103 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	104 KELBY DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	105 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	106 KELBY DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	107 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	108 KELBY DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	109 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	110 KELBY DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	111 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	112 KELBY DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	113 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	114 KELBY DR	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	115 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	116 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	117 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	118 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	119 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	120 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	121 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	122 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	123 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	124 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	125 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	126 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	127 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	128 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	129 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	130 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	131 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	132 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	133 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	134 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	135 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	136 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	137 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	138 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	139 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	140 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	141 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	142 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	143 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	144 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	145 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	146 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	147 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	148 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	149 KELBY	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	1 KELHIGH	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	18 KELHIGH	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	2 KELHIGH	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	20 KELHIGH	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	22 KELHIGH	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	24 KELHIGH	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	26 KELHIGH	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	28 KELHIGH	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	3 KELHIGH	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	30 KELHIGH	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	32 KELHIGH	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	34 KELHIGH	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	36 KELHIGH	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	38 KELHIGH	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	4 KELHIGH	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	40 KELHIGH	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	42 KELHIGH	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	44 KELHIGH	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	46 KELHIGH	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	48 KELHIGH	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	5 KELHIGH DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	6 KELHIGH	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	8 KELHIGH	D) Copper	No	M) 2001 - 2010		D) Copper	
Lead Status Unknown	1108 KENNEBEC	R) Unknown - Unlikely Lead	Not sure	K) 1981 - 1990		R) Unknown - Unlikely Lead	
Non-Lead	1110 KENNEBEC DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1112 KENNEBEC	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1113 KENNEBEC	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	1116 KENNEBEC	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1124 KENNEBEC	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1126 KENNEBEC	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1128 KENNEBEC	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1130 KENNEBEC	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1132 KENNEBEC	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1134 KENNEBEC	E) Cast iron - lined	Not sure	L) 1991 - 2000		E) Cast iron - lined	customer verified copper
Non-Lead	1137 KENNEBEC	D) Copper	No	K) 1981 - 1990		D) Copper	
Lead Status Unknown	1144 KENNEBEC DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1156 KENNEBEC	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	11 KENNEDY	D) Copper	No	O) 2011 - 2020	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	116 KENNEDY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	122 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	131 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	135 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	136 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	141 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	142 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	146 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	147/149 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Non-Lead	15 KENNEDY	D) Copper	No	O) 2011 - 2020	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	150/152 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	151/153 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	158 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	E) Cast iron - lined	
Non-Lead	159/163 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	162 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	165 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	166/168 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	171 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	172 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	176 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	18 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	181 KENNEDY ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	186 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	20 KENNEDY	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	111 KENWOOD	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	115 KENWOOD RD	D) Copper	Not sure	H) 1961 - 1970	UNUSED LINE CUT OFF 8/11/2015	D) Copper	
Non-Lead	12 KENWOOD	D) Copper	No	O) 2011 - 2020	REMOVED GALVANIZED LINE	D) Copper	
Non-Lead	120 KENWOOD	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
GRR	15 KENWOOD	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	C) Galvanized	boc verified galvanized
Non-Lead	220 KENWOOD	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	260 KENWOOD	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	261 KENWOOD RD	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	280 KENWOOD	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	32 KENWOOD	D) Copper	No	C) 1911 - 1920	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	50 KENWOOD RD	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	63 KENWOOD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	44 KEYSTONE AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	51 KEYSTONE AVE	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	52 KEYSTONE AVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	54 KEYSTONE AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	55 KEYSTONE AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	56 KEYSTONE AVE	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	57 KEYSTONE AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	58 KEYSTONE AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	59 KEYSTONE AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	61 KEYSTONE AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	66 KEYSTONE AVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Lead Status Unknown	231/233 E KING ST	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	435/439 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	151 E. KING ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	170 E. KING ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	175 E. KING ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	209 E. KING ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	213 E. KING ST.	D) Copper	No	O) 2011 - 2020	REMOVE LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	221 /223 E. KING ST.	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSNECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	225 E. KING ST.	D) Copper	No	O) 2011 - 2020	REMOVE LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	226 E. KING ST.	D) Copper	No	O) 2011 - 2020	REMOVE LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	228/230 E. KING ST.	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSNECK	R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	229 E. KING ST.	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	232 E. KING	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	234 E. KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	235 E. KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	238 E. KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	239 E. KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	240 E. KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	245 E. KING ST	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	R) Unknown - Unlikely Lead	
Lead Status Unknown	251 E. KING ST.	D) Copper	Not sure	O) 2011 - 2020	ALREADY COPPER	R) Unknown - Unlikely Lead	
Lead Status Unknown	252 E. KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	257 E. KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	263 E. KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	267 E. KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	271 E KING ST	D) Copper	Not sure	M) 2001 - 2010	RENEWED WATER SERVICE	R) Unknown - Unlikely Lead	
Non-Lead	279 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	283 E KING ST	D) Copper	No	M) 2001 - 2010	RELOCATE WATER SERVICE	D) Copper	
GRR	301 E KING ST	D) Copper	Not sure	O) 2011 - 2020	REPLACE WATER SERVICE MAIN TO CV	C) Galvanized	
Lead Status Unknown	307/309 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	310 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	312/314 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	313 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	315 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	319 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	324 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	325/327 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	328/330 E KING ST	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	R) Unknown - Unlikely Lead	
Lead Status Unknown	329 E KING ST	D) Copper	No	P) 2021 - 2030	lead gooseneck removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	331 E. KING ST.	D) Copper	No	P) 2021 - 2030	lead gooseneck removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	334 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	339/341 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	340 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	342/346 E. KING ST.	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	343/345 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	347/349 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	348 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	352/356 E. KING ST.	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	353 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	354/366 E KING ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	357 E KING	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	358 E KING	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	359 E KING ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	customer verified copper
Lead Status Unknown	365 E. KING ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	368/370 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	371 E KING	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	375/377 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	379-385 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD	R) Unknown - Unlikely Lead	
Non-Lead	387 E KING ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Lead Status Unknown	389 E. KING ST.	D) Copper	Not sure	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	418 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	422 E. KING ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	424 E KING ST	R) Unknown - Unlikely Lead	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	426 E KING ST	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Lead Status Unknown	428 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	429 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	431 E. KING ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	433 E KING ST	D) Copper	No	H) 1961 - 1970	ALREADY COPPER	D) Copper	
Lead Status Unknown	443/445 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	449/451 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	450 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	452 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	454 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	455 E KING ST	D) Copper	No	O) 2011 - 2020	LEAD ALREADY REMOVED	D) Copper	
Lead Status Unknown	458 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	459 E KING ST	D) Copper	No	O) 2011 - 2020	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	465/467 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	466/470 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	489/491 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	513 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	518 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	H) PVC - polyvinyl chloride	customer verified pvc
Lead Status Unknown	519 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	526 E KING ST	D) Copper	No	O) 2011 - 2020	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	530 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	531 E KING ST	D) Copper	No	K) 1981 - 1990	CHECKED FOR LEAD	D) Copper	
Lead Status Unknown	532 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	536 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	537/539 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	540 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	543 E. KING ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	544 E KING ST	D) Copper	No	H) 1961 - 1970	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	545 E. KING ST.	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	546 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	549 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	552 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	555 E. KING ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	556/558 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	559 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	562 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	563 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	565 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	568 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	569 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	572 E. KING ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	573 E. KING ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	576 E KING ST	D) Copper	No	H) 1961 - 1970	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	580 E KING ST	D) Copper	No	H) 1961 - 1970	CHECKED FOR LEAD COUPLING	D) Copper	customer verified copper
Non-Lead	581 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified
Lead Status Unknown	584/586 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	585 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	588 E KING ST	D) Copper	No	D) 1921 - 1930	REPLACED CURB VALVE TO MAIN	C) Galvanized	
Non-Lead	589 E KING ST	D) Copper	No	H) 1961 - 1970	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	590 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	601/603 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	602 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	606 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	610 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	614 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	618 E KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	915 E KING ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	935 E KING ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	971 E KING ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	979 E KING ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	980 E KING ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	10 W KING ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	101 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	107 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	111 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	112 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	119 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	12 W KING ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	121 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	123 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	125 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	131 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	133 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	135 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	137 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	141 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	145 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	149/153 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	157 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	158 W KING ST	D) Copper	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	167 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	169 W KING ST	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	171 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	175 W KING ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	177 W KING ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	19 W KING ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	214 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	216/218 W KING ST	D) Copper	No	H) 1961 - 1970	CHECKED FOR LEAD	R) Unknown - Unlikely Lead	
Non-Lead	219 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	222 W KING ST	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	223 W KING ST	D) Copper	No	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	224 W KING ST	D) Copper	No	O) 2011 - 2020	CHECKED FOR LEAD	R) Unknown - Unlikely Lead	
Lead Status Unknown	227 W KING ST	D) Copper	No	O) 2011 - 2020	CHECKED FOR LEAD	R) Unknown - Unlikely Lead	
Lead Status Unknown	228 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	231 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	234 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	237 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	238 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	241 W KING ST	D) Copper	No	C) 1911 - 1920	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	242 W KING ST	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
GRR	245 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	C) Galvanized	
Lead Status Unknown	246 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	248 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	249 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	251 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	254 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	255 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	259 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	260 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	261 W KING ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	262 W KING ST	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	263 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	271 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	277 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	283 W KING ST	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	289 W KING ST	D) Copper	No	O) 2011 - 2020	CHECKED FOR LEAD	R) Unknown - Unlikely Lead	
Lead Status Unknown	291 W KING ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	30 W KING ST	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Lead Status Unknown	305 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	307 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	312/315 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	318 W KING ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	319/323 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	322 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	327/329 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	328 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	333/335 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	337/339 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	340 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	347/349 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	348/350 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	353 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	354/356 W KING ST	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	357/361 W KING ST	D) Copper	No	C) 1911 - 1920	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	362 W KING ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	39 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	40 W KING ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	401 /403 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	410 W KING ST	D) Copper	No	O) 2011 - 2020	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	415 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	416 W KING ST	D) Copper	No	O) 2011 - 2020	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	417 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	419 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	420 W KING ST	D) Copper	No	D) 1921 - 1930	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	421 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	423 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	426/432 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	436/438 W KING ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	437 W KING ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	52 W KING ST	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	528 W KING ST	D) Copper	No	D) 1921 - 1930	SERVICE CHECKED NO LEAD	D) Copper	customer verified copper
Lead Status Unknown	529 W KING ST	D) Copper	No	D) 1921 - 1930	SERVICE CHECKED NO LEAD	R) Unknown - Unlikely Lead	
Lead Status Unknown	531 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	562 W KING ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	612 W KING ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	614 W KING ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	616 W KING ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	70 W KING ST	D) Copper	No	K) 1981 - 1990	SERVICE CHECKED NO LEAD	D) Copper	customer verified copper
Non-Lead	407 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	417 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	429 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	430 KRAISS AVE	D) Copper	No	O) 2011 - 2020	already copper	D) Copper	
Non-Lead	435 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	440 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	448 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	455 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	456 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	464 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	480 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	524 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	527 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	532 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	535 KRAISS AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	538 KRAISS AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	545 KRAISS AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	548 KRAISS AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	555 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	557 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	558 KRAISS AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	572 KRAISS AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	606 KRAISS AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	95 KRINER RD	E) Cast iron - lined	No	M) 2001 - 2010		E) Cast iron - lined	
Non-Lead	109 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	110 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	115 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	116 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	121 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	122 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	127 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	128 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	133 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	134 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	139 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	140 LANTERN LANE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	145 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	146 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	151 LANTERN LANE	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	152 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	157 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	158 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	163 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	164 LANTERN LANE	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	169 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	170 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	176 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	182 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	188 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	193 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	194 LANTERN LANE	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	197 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	198 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	206 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	212 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	218 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	221 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	222 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	225 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	226 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	229 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	230 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	233 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	234 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	237 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	238 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	241 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	242 LANTERN LANE	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	245 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	246 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	249 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	250 LANTERN LANE	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	253 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	254 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	257 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	258 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	262 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	266 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	270 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	302 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	304 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	306 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	312 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	314 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	316 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	322 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	324 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	326 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	328 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	330 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	331 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	332 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	333 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	334 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	335 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	336 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	337 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	339 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	341 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	342 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	343 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	344 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	345 LANTERN LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	346 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	348 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	350 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	351 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	352 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	353 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	354 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	355 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	356 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	357 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	359 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	361 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	362 LANTERN LN	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	363 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	364 LANTERN LN	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	365 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	366 LANTERN LN	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	368 LANTERN LN	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	441 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	442 LANTERN LN	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	443 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	444 LANTERN LN	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	445 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	446 LANTERN LN	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	447 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	448 LANTERN LN	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	449 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	450 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	451 LANTERN LN	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	452 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	454 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	456 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	457 LANTERN LN	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	459 LANTERN LN	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	461 LANTERN LN	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	462 LANTERN LANE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	463 LANTERN LN	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	464 LANTERN LANE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	465 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	466 LANTERN LANE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	467 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	469 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	471 LANTERN LANE	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Lead Status Unknown	205 LARCH AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	212 LARCH AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	215 LARCH AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	220 LARCH AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	230 LARCH AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	240 LARCH AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	250 LARCH AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	251 LARCH AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	260 LARCH AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	270 LARCH AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	10 LAUREL AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	11 LAUREL AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	30 LAUREL AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	50 LAUREL AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	51 LAUREL AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	60 LAUREL AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	61 LAUREL AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	71 LAUREL AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	81 LAUREL AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	90 LAUREL AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	91 LAUREL AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1015 LEIDIG DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1020 LEIDIG DR	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1021 LEIDIG DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1000 LEIDIG DR	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	1001 LEIDIG DR	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1009 LEIDIG DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1029 LEIDIG DR	D) Copper	Not sure	M) 2001 - 2010		E) Cast iron - lined	
Non-Lead	1030 LEIDIG DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1035 LEIDIG DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1040 LEIDIG DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1041 LEIDIG DR	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1049 LEIDIG DR	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	1055 LEIDIG DR	D) Copper	Not sure	M) 2001 - 2010	RENEW WATER SERVICE	H) PVC - polyvinyl chloride	customer verified pvc
Non-Lead	1061 LEIDIG DR	H) PVC - polyvinyl chloride	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	1069 LEIDIG DR	D) Copper	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	1075 LEIDIG DR	D) Copper	Not sure	M) 2001 - 2010	RENEW WATER SERVICE	D) Copper	
Non-Lead	910 LEIDIG DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	911 LEIDIG DR	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	920 LEIDIG DR	D) Copper	No	P) 2021 - 2030	CHECKED NO LEAD	D) Copper	
Non-Lead	921 LEIDIG DR	D) Copper	No	O) 2011 - 2020	SERVICE ALREADY COPPER	D) Copper	customer verified copper
Non-Lead	930 LEIDIG DR	D) Copper	No	P) 2021 - 2030	CHECKED NO LEAD	D) Copper	
Non-Lead	931 LEIDIG DR	D) Copper	No	P) 2021 - 2030	CHECKED NO LEAD	D) Copper	
Non-Lead	941 LEIDIG DR	D) Copper	No	H) 1961 - 1970	CHECKED NO LEAD	D) Copper	customer verified copper
Non-Lead	950 LEIDIG DR	D) Copper	No	P) 2021 - 2030	CHECKED NO LEAD	D) Copper	
Non-Lead	951 LEIDIG DR	D) Copper	No	P) 2021 - 2030	CHECKED NO LEAD	D) Copper	customer verified copper
Non-Lead	960 LEIDIG DR	D) Copper	No	H) 1961 - 1970	CHECKED NO LEAD	D) Copper	
Non-Lead	961 LEIDIG DR	D) Copper	No	H) 1961 - 1970	CHECKED NO LEAD	D) Copper	customer verified copper
Non-Lead	965 LEIDIG DR	D) Copper	No	H) 1961 - 1970	CHECKED NO LEAD	D) Copper	
Non-Lead	970 LEIDIG DR	D) Copper	No	H) 1961 - 1970	CHECKED NO LEAD	D) Copper	
Non-Lead	971 LEIDIG DR	D) Copper	No	J) 1971 - 1980	CHECKED NO LEAD	D) Copper	
Non-Lead	980 LEIDIG DR	D) Copper	No	J) 1971 - 1980	CHECKED NO LEAD	D) Copper	
Non-Lead	981 LEIDIG DR	D) Copper	No	J) 1971 - 1980	CHECKED NO LEAD	D) Copper	
Non-Lead	990 LEIDIG DR	D) Copper	No	H) 1961 - 1970	CHECKED NO LEAD	D) Copper	
Non-Lead	991 LEIDIG DR	D) Copper	No	H) 1961 - 1970	CHECKED NO LEAD	D) Copper	
GRR	124 E LIBERTY ST	D) Copper	Not sure	O) 2011 - 2020	REPALCED MAINTO CV	C) Galvanized	
Non-Lead	126/128 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	BOC VERIFIED COPPER
GRR	130 E LIBERTY ST	D) Copper	Not sure	O) 2011 - 2020	WATER SERVICE REPLACED	C) Galvanized	
Non-Lead	133 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	LEAD GOOSENECK REMOVED	D) Copper	customer verified copper
GRR	134 E LIBERTY ST	D) Copper	No	O) 2011 - 2020		C) Galvanized	
Lead Status Unknown	144 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	148 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	154 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	159 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	160 E LIBERTY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	174 E LIBERTY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	180 E LIBERTY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	228 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	244 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	245 E LIBERTY ST	D) Copper	Not sure	K) 1981 - 1990	ALREADY COPPER/NO LEAD	D) Copper	
Lead Status Unknown	256 E LIBERTY ST	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	257 E LIBERTY ST	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	259 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	260 E LIBERTY ST	D) Copper	Not sure	O) 2011 - 2020	ALREADY COPPER	R) Unknown - Unlikely Lead	
Non-Lead	265 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	270 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	271 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	278 E LIBERTY ST	D) Copper	No	J) 1971 - 1980	ALREADY COPPER	D) Copper	
Lead Status Unknown	279 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	280 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	LEAD ALREADY REMOVED	D) Copper	
Lead Status Unknown	302/304 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	305 E LIBERTY ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Lead Status Unknown	307 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	309 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	312 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	313 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	314 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	315 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	H) PVC - polyvinyl chloride	
Lead Status Unknown	320 E LIBERTY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	321 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	325 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	343 E LIBERTY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	345 E LIBERTY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	353 E LIBERTY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	360 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Lead Status Unknown	362 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	363 E LIBERTY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	370 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	372 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	373 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	376 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	377 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	378 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	381 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	382 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	385 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	386 E LIBERTY ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	420 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	424 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	428 E LIBERTY ST	D) Copper	Not sure	O) 2011 - 2020	ALREADY COPPER	R) Unknown - Unlikely Lead	
Lead Status Unknown	429 E LIBERTY ST	D) Copper	No	A) Pre-1901	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	434 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	437/439 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	440/442 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	445 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	448/450 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REPAIRED WATER SERVICE	D) Copper	customer verified copper
Non-Lead	451 LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	452 LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	455 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	460 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	461 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
GRR	467 E LIBERTY ST	D) Copper	Not sure	O) 2011 - 2020	replace service main to cv	C) Galvanized	verified galvanized
Lead Status Unknown	470 E LIBERTY ST	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	473 E LIBERTY ST	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	478 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	481 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	483 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	500/502 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	501 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	506 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	507 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	510 E LIBERTY ST	D) Copper	No	H) 1961 - 1970	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	511 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	515 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	519 E LIBERTY ST	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	522 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	525 E LIBERTY ST	D) Copper	No	C) 1911 - 1920	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	530 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	534 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	535 E LIBERTY ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	538 E LIBERTY ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	541 E LIBERTY ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	542 E LIBERTY ST	D) Copper	No	H) 1961 - 1970	ALREADY COPPER	D) Copper	
Non-Lead	546 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	549 E LIBERTY ST	D) Copper	No	C) 1911 - 1920	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	554 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	557 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	H) PVC - polyvinyl chloride	customer verified copper
Non-Lead	558 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	559/561 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	569 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	570 E LIBERTY ST	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	573 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	622 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	625 E LIBERTY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	76 W LIBERTY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	93 W LIBERTY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	273 LIGHT AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	206 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	218 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	415 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	419 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	423 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	427 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	430 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	435 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	440 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	70 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	76 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	78 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	95 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	99 LIMEKILN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Lead Status Unknown	100 LINCOLN RD	D) Copper	Not sure	J) 1971 - 1980		R) Unknown - Unlikely Lead	
Non-Lead	101 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	110 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	111 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	120 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	121 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	130 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	131 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	140 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	141 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	boc verified copper
Non-Lead	150 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	151 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	160 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	161 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	170 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	171 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	180 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	181 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	190 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	191 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	90 LINCOLN RD	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	1047 LINCOLN WAY EAST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	1048 LINCOLN WAY EAST	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Lead Status Unknown	1049 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1053 LINCOLN WAY EAST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	1054 LINCOLN WAY EAST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	1055 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	1060 LINCOLN WAY EAST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1065 LINCOLN WAY EAST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	1066 LINCOLN WAY EAST	D) Copper	Not sure	P) 2021 - 2030	NEW WATER LINE	H) PVC - polyvinyl chloride	
Non-Lead	1069 LINCOLN WAY EAST	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	1070 LINCOLN WAY EAST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	1097 LINCOLN WAY EAST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1098 LINCOLN WAY EAST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1110 LINCOLN WAY EAST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	1120 LINCOLN WAY EAST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	1121 LINCOLN WAY EAST	E) Cast iron - lined	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1226 LINCOLN WAY EAST	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1228 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1232 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1234 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1238 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1300 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010	NEW WATER SERVICE	D) Copper	boc verified copper
Non-Lead	1304 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1310 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1315 LINCOLN WAY EAST	E) Cast iron - lined	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1319 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1329 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1337 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1340 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1350 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1351 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1358/1360 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1361 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	boc verified copper
Non-Lead	1364 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1370 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1371 /1373 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1380 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1402 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1404 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1428 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1431 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1433 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1435 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1439 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1441 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1449 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1451 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1453 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1460 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1464 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1478 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1496 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1497 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1498 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	150 LINCOLN WAY EAST	D) Copper	Not sure	P) 2021 - 2030		D) Copper	
Non-Lead	1506 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1507 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1508 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1510 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1512 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1513 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1515 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1520 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1521 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1525 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	157 LINCOLN WAY EAST	E) Cast iron - lined	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	1649 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1725 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1743 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1751 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1755 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1759 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1760 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1764 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1768 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1771 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1772 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1776 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1777 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1779 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1781 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1782 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1783 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1784 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1785 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1795 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1805 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	220 LINCOLN WAY EAST	D) Copper	Not sure	C) 1911 - 1920		D) Copper	
Lead Status Unknown	263 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	273 LINCOLN WAY EAST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	330 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Lead Status Unknown	338 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		H) PVC - polyvinyl chloride	customer verified copper
Lead Status Unknown	373 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	376 LINCOLN WAY EAST	D) Copper	Not sure	D) 1921 - 1930	REPAIR WATER SERVICE	R) Unknown - Unlikely Lead	
Lead Status Unknown	386 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	387 LINCOLN WAY EAST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	389 LINCOLN WAY EAST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	429 LINCOLN WAY EAST	D) Copper	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	447 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	L) 1991 - 2000		R) Unknown - Unlikely Lead	
Lead Status Unknown	497 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	515 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	521/523 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	527 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	533 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	539 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	543 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	554 LINCOLN WAY EAST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	565 LINCOLN WAY EAST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	575 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	583 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	586 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	591 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	592 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	596 LINCOLN WAY EAST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	597 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Non-Lead	600 LINCOLN WAY EAST	D) Copper	No	K) 1981 - 1990	removed lead gooseneck	D) Copper	
Lead Status Unknown	603 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	611 LINCOLN WAY EAST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	622 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	635 LINCOLN WAY EAST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	702 LINCOLN WAY EAST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	704 LINCOLN WAY EAST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	724 LINCOLN WAY EAST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	764 LINCOLN WAY EAST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	770 LINCOLN WAY EAST	D) Copper	Not sure	O) 2011 - 2020	REPAIR WATER SERVICE	D) Copper	customer verified copper
Non-Lead	858 LINCOLN WAY EAST	D) Copper	Not sure	O) 2011 - 2020	MOVED WATER SERVICE LINE	D) Copper	customer verified copper
Non-Lead	901 LINCOLN WAY EAST	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Lead Status Unknown	928 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	J) 1971 - 1980		R) Unknown - Unlikely Lead	
Non-Lead	946 LINCOLN WAY EAST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	978 LINCOLN WAY EAST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	983 LINCOLN WAY EAST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	984 LINCOLN WAY EAST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	BOC verified copper
Non-Lead	985 LINCOLN WAY EAST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	990 LINCOLN WAY EAST	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	998 LINCOLN WAY EAST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	BOC verified copper
Lead Status Unknown	23 LINCOLN WAY W	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	25 LINCOLN WAY W	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	27 LINCOLN WAY W	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	40 LINCOLN WAY W	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	45/47LINCOLN WAY WEST	D) Copper	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	601 LINCOLN WAY W	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	210 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	215 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	220 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	225 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	230 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	235 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	240 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	245 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	250 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	255 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	260 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	270 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	280 LINDEN AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	701 LONG LANE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	702 LONG LANE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	707 LONG LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	715 LONG LANE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	723 LONG LANE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	803 LONG LANE	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	809 LONG LANE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	810 LONG LANE	D) Copper	No	K) 1981 - 1990		D) Copper	BOC verified copper
Non-Lead	819 LONG LANE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	829 LONG LANE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	836 LONG LANE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	841 LONG LANE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	850 LONG LANE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	853 LONG LANE	D) Copper	No	J) 1971 - 1980		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	861 LONG LANE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	864 LONG LANE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	869 LONG LANE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	310 LORTZ AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	340 LORTZ AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	R) Unknown - Unlikely Lead	
Non-Lead	346 LORTZ AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	
Non-Lead	359 LORTZ AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	
Non-Lead	360 LORTZ AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD	D) Copper	
Non-Lead	363 LORTZ AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD	D) Copper	
Non-Lead	366 LORTZ AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD	D) Copper	
Non-Lead	369 LORTZ AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD	D) Copper	
Non-Lead	370 LORTZ AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	D) Copper	boc verified copper
Non-Lead	373 LORTZ AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD	D) Copper	
Non-Lead	379 LORTZ AVE	D) Copper	No	G) 1951 - 1960	REMOVED LEAD	D) Copper	
Non-Lead	380 LORTZ AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD	D) Copper	customer verified copper
Lead Status Unknown	433/437 LORTZ AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD	R) Unknown - Unlikely Lead	
Non-Lead	448 LORTZ AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD	D) Copper	customer verified copper
Non-Lead	456 LORTZ AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD	D) Copper	
Non-Lead	483 LORTZ AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD	D) Copper	
Lead Status Unknown	712 LORTZ AVE	D) Copper	No	G) 1951 - 1960	removed lead	R) Unknown - Unlikely Lead	
Lead Status Unknown	735 LORTZ AVE	D) Copper	No	F) 1941 - 1950	remove lead	R) Unknown - Unlikely Lead	
Non-Lead	740 LORTZ AVE	D) Copper	No	G) 1951 - 1960	REMOVED LEAD	D) Copper	
Non-Lead	800 LORTZ AVE	D) Copper	No	F) 1941 - 1950	removed lead	D) Copper	
Non-Lead	808 LORTZ AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD	D) Copper	customer verified copper
Non-Lead	809 LORTZ AVE	D) Copper	No	P) 2021 - 2030	removed lead	D) Copper	customer verified copper
Non-Lead	816 LORTZ AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD	D) Copper	
Non-Lead	819 LORTZ AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD	D) Copper	
Lead Status Unknown	195 W LOUDON ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
GRR	331 W LOUDON ST.	D) Copper	Not sure	H) 1961 - 1970		Galvanized	customer verified galvanized
Lead Status Unknown	342 W LOUDON ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	358 W LOUDON ST.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Lead Status Unknown	360 W LOUDON ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	362 W LOUDON ST.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	366 W LOUDON ST.	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	368 W LOUDON ST.	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	408 W LOUDON ST.	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	414 W LOUDON ST.	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	420 W LOUDON ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	422 W LOUDON ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	424 W LOUDON ST.	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	430 W LOUDON ST.	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	436 W LOUDON ST.	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Non-Lead	502 W LOUDON ST.	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	510 W LOUDON ST.	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Lead Status Unknown	545 W LOUDON ST.	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Lead Status Unknown	550 W LOUDON ST.	R) Unknown - Unlikely Lead	No	L) 1991 - 2000		D) Copper	
Lead Status Unknown	584 W LOUDON ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	700 W LOUDON ST.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	499 E LUDWIG AVE	D) Copper	Not sure	K) 1981 - 1990		R) Unknown - Unlikely Lead	
Lead Status Unknown	523 E LUDWIG AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	575 E LUDWIG AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	12 W LUDWIG AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	100 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1058 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1059 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	1061 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1075 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Lead Status Unknown	1123 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1236 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1346 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1353 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1412 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1420 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1436 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified
Non-Lead	1437 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1461 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1476 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1479 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1536 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		K) PEX - cross-linked polyethylene	boc verified pex
Lead Status Unknown	175 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1758 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	boc verified pvc
Non-Lead	1769 LINCOLN WAY EAST	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Lead Status Unknown	218 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	221 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	225 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	232 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	239 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	247 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	250 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	257 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	278 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	307 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	308 LINCOLN WAY EAST	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Lead Status Unknown	315 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	332 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	339 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	346 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	368 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	374 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	382 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	384 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	385 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	391 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	393 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	395 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	401 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	435 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	439 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	456 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	458 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	465 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	466 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	467 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	473 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	474 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	479 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	490 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	501 LINCOLN WAY EAST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	520 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	556 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	564 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	568 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	572 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	574 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	577 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	587 LINCOLN WAY EAST	D) Copper	Not sure	C) 1911 - 1920		D) Copper	
Lead Status Unknown	589 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	605 LINCOLN WAY EAST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	634 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	642 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	646 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	696 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		H) PVC - polyvinyl chloride	customer verified copper
Lead Status Unknown	700 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	708 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	714 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	716 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	726 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	734 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	736 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	742 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	766 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	7757 LINCOLN WAY EAST	D) Copper	No	H) 1961 - 1970		D) Copper	
Lead Status Unknown	776 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	800 LINCOLN WAY EAST	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	832 LINCOLN WAY EAST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	837 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	854 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	902 LINCOLN WAY EAST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	949 LINCOLN WAY EAST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	950 LINCOLN WAY EAST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	974 LINCOLN WAY EAST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	987 LINCOLN WAY EAST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	999 LINCOLN WAY EAST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	0 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	101 LINCOLN WAY WEST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	108 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	110 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	116 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	118 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	120 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	124 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	126 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
GRR	127 LINCOLN WAY WEST	D) Copper	No	O) 2011 - 2020		Galvanized	customer verified galvanized
Lead Status Unknown	130 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	134 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	141 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	142 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	146 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	154 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	159 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	160 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	164 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	169 LINCOLN WAY WEST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	170 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	201 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	204 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	211 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	212 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	213 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	214 LINCOLN WAY WEST	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Lead Status Unknown	220 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	222 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	225 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	226 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	232 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	234 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	235 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	238 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	240 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	241 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	245 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	BOC verified copper
Lead Status Unknown	246 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	252 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	253 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	260 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	261 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	267 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	BOC verified copper
Lead Status Unknown	270 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	271 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	272 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	275 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	276 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	279-281 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	282 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	284 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	285 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	289/291 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	291 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	292 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	296 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	297 LINCOLN WAY WEST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	300 LINCOLN WAY WEST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	301 LINCOLN WAY WEST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	308 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	309 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	312 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC verified copper
Lead Status Unknown	316 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	317 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	319 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	323 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	324 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	334 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	335 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	343 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	345/347 LINCOLN WAY WEST	D) Copper	Not sure	C) 1911 - 1920		D) Copper	
Lead Status Unknown	346 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	348 LINCOLN WAY WEST	D) Copper	Not sure	J) 1971 - 1980		R) Unknown - Unlikely Lead	
Lead Status Unknown	352 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	357 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Lead Status Unknown	358 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	364 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	365 LINCOLN WAY WEST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK, servic on Garber	D) Copper	
Lead Status Unknown	368 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	374 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Non-Lead	401 LINCOLN WAY WEST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	404 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	416 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	417 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	420 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	425 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	434 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	440 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	446 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	461 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	customer verified plastic
Lead Status Unknown	462 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	465 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	472 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	473 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		H) PVC - polyvinyl chloride	customer verified copper
Lead Status Unknown	49 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	491 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	498 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	510 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	54 LINCOLN WAY WEST	D) Copper	Not sure	K) 1981 - 1990		R) Unknown - Unlikely Lead	
Lead Status Unknown	542 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	60 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	601 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Non-Lead	609 LINCOLN WAY WEST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	611 LINCOLN WAY WEST	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Lead Status Unknown	613 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	615 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	618 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	622 LINCOLN WAY WEST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	625 LINCOLN WAY WEST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	628 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	639 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	642 LINCOLN WAY WEST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	649 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	651 LINCOLN WAY WEST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	653 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	662 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	68 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	696 LINCOLN WAY WEST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	70 LINCOLN WAY WEST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	700 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	K) 1981 - 1990		R) Unknown - Unlikely Lead	
Lead Status Unknown	72 LINCOLN WAY WEST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Non-Lead	800 LINCOLN WAY WEST	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	801 LINCOLN WAY WEST	D) Copper	No	H) 1961 - 1970		D) Copper	
Lead Status Unknown	101 MACINTOSH WAY	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	102 N MAIN ST	E) Cast iron - lined	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	105 N MAIN ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Lead Status Unknown	109 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	11 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	115 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	127 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	13 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	133 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	14 N MAIN ST	E) Cast iron - lined	Not sure	O) 2011 - 2020		E) Cast iron - lined	
Lead Status Unknown	15 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	17 N MAIN ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Lead Status Unknown	19 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	200 N MAIN ST	E) Cast iron - lined	Not sure	J) 1971 - 1980	DUCTILE IRON	E) Cast iron - lined	
Non-Lead	21 N MAIN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	221 N MAIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	226 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	230 N MAIN ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	232 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	23/27 N MAIN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD	R) Unknown - Unlikely Lead	
Lead Status Unknown	242 N MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	244 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	33 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	49 N MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	5 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	59 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	65 N MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	67 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	7 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	71 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	73 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	75 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	77 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	81 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	83 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	85 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	9 N MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	100 S MAIN ST	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD	D) Copper	
Non-Lead	1002 S MAIN ST	D) Copper	No	K) 1981 - 1990		D) Copper	
Lead Status Unknown	1003 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1008 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	101 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	102 S MAIN ST	D) Copper	Not sure	M) 2001 - 2010	REMOVED LEAD	R) Unknown - Unlikely Lead	
Non-Lead	1020 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1031 S MAIN ST	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	1033 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Lead Status Unknown	1035 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1039 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		R) Unknown - Unlikely Lead	boc verified copper
Non-Lead	1041 S MAIN ST	D) Copper	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1047 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Lead Status Unknown	105 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	1055 S MAIN ST	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	1065 S MAIN ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	1069 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	107 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1071 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1075 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	1080 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1081 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	1085 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1090 S MAIN ST	E) Cast iron - lined	Not sure	K) 1981 - 1990		E) Cast iron - lined	
Lead Status Unknown	1101 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	1111 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1121 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1131 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1137 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	114 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1140 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1141 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	115 S MAIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1150 S MAIN ST	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	1151 S MAIN ST	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Lead Status Unknown	1160 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Non-Lead	1161 S MAIN ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	117 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	1170 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1171 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	1184 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	119 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	1199 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	120 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1200 S MAIN ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	1201 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1210 S MAIN ST	D) Copper	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	1211 S MAIN ST	D) Copper	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Lead Status Unknown	1221 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1227 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	123 S MAIN ST	S) Unknown	Not sure	A) Pre-1901		D) Copper	boc verified copper
Non-Lead	1230 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Lead Status Unknown	1231 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1240 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	1241 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	125 S MAIN ST	S) Unknown	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	1251 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1260 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	1261 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	127 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1270 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1271 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Lead Status Unknown	129 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	130 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	133 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		E) Cast iron - lined	customer verified ductile iron
Non-Lead	136 S MAIN ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	138 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1391 S MAIN ST	E) Cast iron - lined	Not sure	M) 2001 - 2010		E) Cast iron - lined	
Lead Status Unknown	1401 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1411 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1421 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	1441 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	145 S MAIN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	1461 S MAIN ST	D) Copper	Not sure	L) 1991 - 2000		H) PVC - polyvinyl chloride	
Lead Status Unknown	1481 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	149 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	15 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1550 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1571 S MAIN ST	D) Copper	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Lead Status Unknown	159 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	166 S MAIN ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	boc verified copper
Lead Status Unknown	172 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	174 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	176 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	177 S MAIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	179 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	180 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	182 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	183 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	184 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	19 S MAIN ST	D) Copper	Not sure	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	20 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	200 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	203 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	207 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	208 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	210 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	211 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	212 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	217 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	223 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	229 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	232 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	233 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	235 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	238 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	240 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	241 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	246 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	247 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	249 S MAIN ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	252 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	256 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	259 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	262 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	270 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	J) 1971 - 1980		R) Unknown - Unlikely Lead	
Lead Status Unknown	272 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	275 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	276 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	280 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	29 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	300 S MAIN	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	301 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	307 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	308 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	31 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	311 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	312 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	316 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	317 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	320 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	323 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	324 S MAIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	326 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	327 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	33 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	331 S MAIN ST	D) Copper	No	O) 2011 - 2020	removed lead	D) Copper	
Lead Status Unknown	333 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	334 S MAIN ST	D) Copper	No	O) 2011 - 2020	removed lead	D) Copper	
Lead Status Unknown	336 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	338 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	340 S MAIN ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	36 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	37 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	38 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	40 S MAIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Lead Status Unknown	401 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	402 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	406 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	407 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	409 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	412 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	414 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	418 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	42 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	422 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	423 S MAIN ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	425 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	428 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	L) 1991 - 2000		R) Unknown - Unlikely Lead	
Lead Status Unknown	43 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	435 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	436 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	439 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	442 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	445 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	453 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	455 S MAIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Lead Status Unknown	46 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	47 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	483 S MAIN ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	50 S MAIN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	501 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	502 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	509 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	51 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	510 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	511 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	516 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	522 S MAIN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	523 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	528 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	530 S MAIN ST	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Lead Status Unknown	533 S MAIN ST	D) Copper	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	536 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	538 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	54 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	540 S MAIN ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Lead Status Unknown	546 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	55 S MAIN ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	boc verified copper
Lead Status Unknown	550 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)			Customer Owned Portion of the Service Line (Curbstop to Building)		
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	555/557 S MAIN ST	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Lead Status Unknown	556 S MAIN ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	559 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	56 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	560 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	566 S MAIN ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	567 S MAIN ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	568 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	571 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	572 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	575 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	576 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	58 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	583 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	587 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	601 S MAIN ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	605/609 S MAIN ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	608 S MAIN ST	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	610 S MAIN ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	611 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	619 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	620 S MAIN ST	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	621 S MAIN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	624 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	636 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	638 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		D) Copper	boc verified copper
Lead Status Unknown	64 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	641 S MAIN ST	D) Copper	No	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	653 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	66 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	660 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	662 S MAIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	675 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	679 S MAIN ST	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Lead Status Unknown	700 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	71 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	72 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	75 S MAIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	752 S MAIN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	753 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	756 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	759 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	76 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	763 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	764 S MAIN ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	768 S MAIN ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	80 S MAIN ST	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	83 S MAIN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	875 S MAIN ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	881 S MAIN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	883 S MAIN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	920 S MAIN ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	935 S MAIN ST	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	958 S MAIN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	customer verified copper
Non-Lead	960 S MAIN ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	961 S MAIN ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	962 S MAIN ST	D) Copper	Not sure	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	975 S MAIN ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	980 S MAIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	992 S MAIN ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	994 S MAIN ST	D) Copper	No	K) 1981 - 1990	removed lead	D) Copper	
Non-Lead	996 S MAIN ST	D) Copper	No	K) 1981 - 1990		D) Copper	
Lead Status Unknown	215 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	223 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	239 MARTIN AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC verified copper
Lead Status Unknown	245 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	246 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	247 MARTIN AVE	S) Unknown	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	249 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	250 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	251 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	253 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	255 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	256 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	257 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	258 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	259 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	261 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	263 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	265 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	270 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	272 MARTIN AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	257 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	260 MARTINA DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	261 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	264 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	265 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	268 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	269 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified
Non-Lead	272 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	275 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	276 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	281 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	282 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	287 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	288 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	289 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	292 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	296 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	300 MARTINA DRIVE	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	304 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	308 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	312 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	316 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	317 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	320 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	321 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified copper
Non-Lead	324 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	325 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	328 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	329 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	332 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	333 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	336 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	337 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	340 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	341 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	344 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	345 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	348 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	349 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	352 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	353 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	356 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	357 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	360 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	361 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	362 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	364 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	365 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	366 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	368 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	369 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	370 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	372 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	373 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	374 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	376 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	378 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	380 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	381 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	382 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	384 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	385 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	386 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	387 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	388 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	390 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	391 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	392 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	394 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	396 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	398 MARTINA DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	400 MARTINA DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	402 MARTINA DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	404 MARTINA DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	408 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	410 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	412 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	414 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	418 MARTINA DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	420 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	421 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	422 MARTINA DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	424 MARTINA DRIVE	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	425 MARTINA DRIVE	D) Copper	Not sure	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	426 MARTINA DRIVE	D) Copper	No	P) 2021 - 2030	moved curb valve	H) PVC - polyvinyl chloride	
Non-Lead	428 MARTINA DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	430 MARTINA DRIVE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	186 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	189 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	190 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	194 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	205 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	206 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	214 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	218 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	219 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	221 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	222 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	225 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	226 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	229 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	230 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	234 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	238 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	242 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	246 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	250 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	254 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	258 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	261 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	262 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	265 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	266 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	270 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified pvc
Non-Lead	274 MATTHEW DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Lead Status Unknown	1000 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	1001 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	1036 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Non-Lead	1037 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	1069 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	1070 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	1079 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	1080 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	1090 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	1100 E MCKINLEY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1151 E MCKINLEY ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	131 E MCKINLEY ST	D) Copper	No	A) Pre-1901	repair to curb vlave	R) Unknown - Unlikely Lead	
Lead Status Unknown	145 E MCKINLEY ST.	D) Copper	No	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	146 E MCKINLEY ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD	R) Unknown - Unlikely Lead	
Lead Status Unknown	147 E MCKINLEY ST	D) Copper	No	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	148 E MCKINLEY ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD	R) Unknown - Unlikely Lead	
Lead Status Unknown	150/152 E MCKINLEY ST	D) Copper	No	D) 1921 - 1930	REMOVED LEAD	R) Unknown - Unlikely Lead	
Lead Status Unknown	151 E MCKINLEY ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	153 E MCKINLEY ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	156/158 E MCKINLEY ST	D) Copper	Not sure	O) 2011 - 2020	REPLACE COPPER MAIN TO CURB	D) Copper	
Lead Status Unknown	157 E MCKINLEY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	159 E MCKINLEY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	210 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	220/222 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	221 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	223 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	226 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	234 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	238 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	244 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	248 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	250 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	256 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	261 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	301 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	305 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	310 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Lead Status Unknown	313 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	317/321 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	318 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	322 E MCKINLEY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	324 E MCKINLEY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	325/329 E MCKINLEY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	328 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	332 E MCKINLEY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	337 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	338 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	343 E MCKINLEY ST	D) Copper	No	G) 1951 - 1960	ALREADY REMOVED LEAD	R) Unknown - Unlikely Lead	
Non-Lead	344 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC verified copper
Non-Lead	347 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Lead Status Unknown	348 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	350 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	353 E MCKINLEY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	357 E MCKINLEY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	360 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	H) PVC - polyvinyl chloride	
Lead Status Unknown	363 E MCKINLEY STREET	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	364 E MCKINLEY ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	367 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	373 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	378 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	384 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	385 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	386 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	389 E MCKINLEY ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	boc verified copper
Lead Status Unknown	570 E MCKINLEY DRIVE	E) Cast iron - lined	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	610 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	611 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	636 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	700 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	710 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	727 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	829 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	E) Cast iron - lined	customer verified ductile iron
Lead Status Unknown	830 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK,	R) Unknown - Unlikely Lead	
Lead Status Unknown	845 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	900 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	901 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	906 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	911 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	912 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	917 E MCKINLEY ST	D) Copper	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	918 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	924 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	925 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	938 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	939 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	952 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	953 E MCKINLEY ST	D) Copper	Not sure	J) 1971 - 1980		R) Unknown - Unlikely Lead	
Lead Status Unknown	964 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	978 E MCKINLEY ST	D) Copper	Not sure	J) 1971 - 1980		R) Unknown - Unlikely Lead	
Non-Lead	979 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	992 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	993 E MCKINLEY ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	0 MEADOWBROOK LN	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	10 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	12 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	14 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	16 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	customer verified copper
Non-Lead	18 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	20 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	customer verified copper
Non-Lead	24 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	customer verified copper
Non-Lead	26 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	28 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	30 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	32 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	34 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	36 MEADOW DRIVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Lead Status Unknown	40 MENNO VILLAGE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	50 MENNO VILLAGE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	60 MENNO VILLAGE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	514 MENTZER AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	515 MENTZER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	522 MENTZER AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	523 MENTZER AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	530 MENTZER AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	531 MENTZER AVE	D) Copper	No	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	538 MENTZER AVE	D) Copper	No	H) 1961 - 1970		D) Copper	boc verified copper
Non-Lead	539 MENTZER AVE	D) Copper	No	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	544 MENTZER AVE	D) Copper	No	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	547 MENTZER AVE	D) Copper	No	H) 1961 - 1970		D) Copper	
Non-Lead	552 MENTZER AVE	D) Copper	No	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	555 MENTZER AVE	D) Copper	No	H) 1961 - 1970		D) Copper	inspection
Non-Lead	200 MERIWEATHER DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	201 MERIWEATHER DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	202 MERIWEATHER DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	203 MERIWEATHER DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	204 MERIWEATHER DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	205 MERIWEATHER DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	206 MERIWEATHER DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	207 MERIWEATHER DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	208 MERIWEATHER DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	209 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	210 MERIWEATHER DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	211 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	212 MERIWEATHER DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	213 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	214 MERIWEATHER DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	215 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	216 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	217 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	218 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	219 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	220 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	221 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	222 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	223 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	224 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	225 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	226 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	227 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	228 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	229 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	230 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	231 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	232 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	233 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	234 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	235 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	236 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	237 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	238 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	239 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	240 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	241 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	242 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	243 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	244 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	245 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	246 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	248 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	250 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	252 MERIWEATHER DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	766 MIDDLE ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	815 MIDDLE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	819 MIDDLE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	832 MIDDLE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	E) Cast iron - lined	customer verified copper
Non-Lead	833 MIDDLE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	835 MIDDLE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	838 MIDDLE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Lead Status Unknown	839 MIDDLE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	843 MIDDLE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	844 MIDDLE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	847 MIDDLE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	848 MIDDLE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	851 MIDDLE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	859 MIDDLE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	860 MIDDLE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	870 MIDDLE ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	875 MIDDLE ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	881 MIDDLE ST	D) Copper	No	P) 2021 - 2030	ewmoved lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	124 MILL RD.	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	128 MILL RD.	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	144 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	156 MILL RD.	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	170 MILL RD.	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	171 MILL RD.	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	173 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	175 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	177 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	179 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	181 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	183 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	185 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	187 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	189 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	190 MILL RD.	E) Cast iron - lined	No	J) 1971 - 1980		E) Cast iron - lined	
Non-Lead	191 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	193 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	195 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	201 MILL RD.	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	203 MILL RD.	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	205 MILL RD.	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	207 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	209 MILL RD.	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	211 MILL RD.	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	213 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	215 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	217 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	219 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	220 MILL RD.	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	221 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	223 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	228 MILL RD.	D) Copper	No	P) 2021 - 2030		D) Copper	
Non-Lead	236 MILL RD.	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	244 MILL RD.	D) Copper	No	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	260 MILL RD.	D) Copper	Not sure	P) 2021 - 2030	REPAIR WATER SERVICE	D) Copper	
Non-Lead	265 MILL RD.	D) Copper	No	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	268 MILL RD.	D) Copper	No	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	276 MILL RD.	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	277 MILL RD.	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	284 MILL RD.	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	customer verified copper
Non-Lead	290 MILL RD.	D) Copper	No	P) 2021 - 2030		H) PVC - polyvinyl chloride	
Non-Lead	298 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	300 MILL RD.	D) Copper	No	M) 2001 - 2010		D) Copper	BOC verified copper
Non-Lead	315 MILL RD.	D) Copper	No	L) 1991 - 2000		H) PVC - polyvinyl chloride	
Non-Lead	328 MILL RD.	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	404 MILL RD.	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	412 MILL RD.	H) PVC - polyvinyl chloride	No	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	420 MILL RD.	H) PVC - polyvinyl chloride	No	O) 2011 - 2020		D) Copper	
Non-Lead	428 MILL RD.	H) PVC - polyvinyl chloride	No	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	218/222 MILLER ST	D) Copper	Not sure	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	224/228 MILLER ST	D) Copper	Not sure	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	246 MILLER ST	D) Copper	Not sure	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	254 MILLER ST	D) Copper	Not sure	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	255 MILLER ST	D) Copper	Not sure	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	260 MILLER ST	D) Copper	Not sure	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	264 MILLER ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	266 MILLER ST	D) Copper	Not sure	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
GRR	268 MILLER ST	D) Copper	Not sure	D) 1921 - 1930	LEAD ALREADY REMOVED	C) Galvanized	
Non-Lead	270/272 MILLER ST	D) Copper	Not sure	J) 1971 - 1980	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	276 MILLER ST	D) Copper	Not sure	K) 1981 - 1990	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	280 MILLER ST	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	282 MILLER ST	D) Copper	Not sure	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	320 MILLER ST	D) Copper	Not sure	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	332 MILLER ST	D) Copper	Not sure	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	342 MILLER ST	D) Copper	Not sure	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	boc verified copper
Lead Status Unknown	400 MILLER ST	D) Copper	Not sure	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	570 MILLER ST	D) Copper	Not sure	H) 1961 - 1970	WATER SERVICE REPLACED	D) Copper	
Non-Lead	575 MILLER ST	D) Copper	Not sure	G) 1951 - 1960	WATER SERVICE REPLACED	D) Copper	boc verified copper
Lead Status Unknown	576 MILLER ST	D) Copper	Not sure	G) 1951 - 1960	WATER SERVICE REPLACED	R) Unknown - Unlikely Lead	
Non-Lead	581 MILLER ST	D) Copper	Not sure	G) 1951 - 1960	WATER SERVICE REPLACED	D) Copper	customer verified copper
Non-Lead	590 MILLER ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	2294 MOLLY PITCHER HWY	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	430 MONTGOMERY AVE	D) Copper	No	G) 1951 - 1960	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	463 MONTGOMERY AVE	D) Copper	No	A) Pre-1901		D) Copper	
Non-Lead	464 MONTGOMERY AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	515 MONTGOMERY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	517 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	518 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	523 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	524 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	529 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	532 MONTGOMERY AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	boc verified copper
Non-Lead	535 MONTGOMERY AVE	D) Copper	Not sure	H) 1961 - 1970	no lead gooseneck	D) Copper	
Non-Lead	541 MONTGOMERY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	545 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	546 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Non-Lead	548 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Non-Lead	551 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	552 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	558 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	559 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	561 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	570 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	575 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	579 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	580 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	582 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	590 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	591 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	593 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	no lead	D) Copper	
Non-Lead	602 MONTGOMERY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	630 MONTGOMERY AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	641 MONTGOMERY AVE	D) Copper	Not sure	O) 2011 - 2020		K) PEX - cross-linked polyethylene	
Non-Lead	661 MONTGOMERY AVE	D) Copper	No	H) 1961 - 1970	no lead	D) Copper	
Non-Lead	691 MONTGOMERY AVE	D) Copper	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	1 MONTICELLO	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	230 MT MORIAH ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	239 MT MORIAH ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	250 MT MORIAH ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	254 MT MORIAH ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	258 MT MORIAH ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	1034 MORROW PLACE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1036 MORROW PLACE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	205 MOWER RD	D) Copper	No	J) 1971 - 1980		H) PVC - polyvinyl chloride	customer verified
Non-Lead	379 MT PLEASANT RD	D) Copper	No	G) 1951 - 1960		D) Copper	boc verified copper
Non-Lead	425 NELSON ST	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	436 NELSON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	440 NELSON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	460 NELSON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	470 NELSON ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	471 NELSON ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	473 NELSON ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	477 NELSON ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	512 NELSON ST	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Lead Status Unknown	519 NELSON ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	522 NELSON ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	530 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	531 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	535 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	536 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	538/540 NELSON ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	541 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	544 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	545 NELSON ST	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	546 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	548 NELSON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	550 NELSON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	551 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	554 NELSON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	555 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	556 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	557 NELSON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	558 NELSON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	564 NELSON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	565 NELSON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	568 NELSON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	569 NELSON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	570 NELSON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Lead Status Unknown	573 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	574/576 NELSON ST	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	577 NELSON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	578 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	580 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	581 NELSON ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	585 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	905 NELSON ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	910 NELSON ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	930 NELSON ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	931 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	940 NELSON ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	953 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	956 NELSON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	960 NELSON ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	967 NELSON ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	970 NELSON ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	4688 NEWMAN RD	D) Copper	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Lead Status Unknown	1465 NITTERHOUSE DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1475 NITTERHOUSE DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1490 NITTERHOUSE DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1530 NITTERHOUSE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1599 NITTERHOUSE DR	E) Cast iron - lined	No	L) 1991 - 2000		E) Cast iron - lined	
Lead Status Unknown	1480 NITTERHOUSE DR	R) Unknown - Unlikely Lead	Not sure	L) 1991 - 2000		R) Unknown - Unlikely Lead	
Lead Status Unknown	1500 NITTERHOUSE DR	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	133 NORLAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	312 NORLAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	334 NORLAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	43 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	600 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	620 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	630 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	725 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	730 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	735 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	740 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	745 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	750 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	800 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	801 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	810 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	825 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	830 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	832 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	850 NORLAND AVE	D) Copper	Not sure	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Lead Status Unknown	860 NORLAND AVE	D) Copper	Not sure	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Lead Status Unknown	861 NORLAND AVE	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	870 NORLAND AVE	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Non-Lead	875 NORLAND AVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Lead Status Unknown	901 NORLAND AVE	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	913 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	916 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	917 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	920 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	921 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	924 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	925 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	947 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	955 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	960 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	962 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	963 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	964 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	966 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	967 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	968 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	970 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	971 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	975 NORLAND AVE	S) Unknown	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	979 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	980 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	982 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	983 NORLAND AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	986 NORLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	990 NORLAND AVE	S) Unknown	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Non-Lead	1000 NORLAND AVE	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Lead Status Unknown	110 NORLAND AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	124 NORLAND AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	150 NORLAND AVE	D) Copper	No	C) 1911 - 1920	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	207 NORLAND AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	220 NORLAND AVE	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	233 NORLAND AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	238 NORLAND AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	246 NORLAND AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	254 NORLAND AVE	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	H) PVC - polyvinyl chloride	customer verified pvc
Non-Lead	304 NORLAND AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Lead Status Unknown	31 NORLAND AVE	D) Copper	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	322 NORLAND AVE	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	433 NORLAND AVE	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Lead Status Unknown	445 NORLAND AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	449 NORLAND AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	453 NORLAND AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	454 NORLAND AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	469 NORLAND AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	471 NORLAND AVE	D) Copper	Not sure	E) 1931 - 1940	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	601 NORLAND AVE	D) Copper	Not sure	O) 2011 - 2020	WATER SERVICE REPAIR	R) Unknown - Unlikely Lead	
Lead Status Unknown	625 NORLAND AVE	R) Unknown - Unlikely Lead	Not sure	L) 1991 - 2000		R) Unknown - Unlikely Lead	
Lead Status Unknown	65 NORLAND AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	720 NORLAND AVE	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	220 NORTH ST	D) Copper	No	F) 1941 - 1950	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Lead Status Unknown	226 NORTH ST	R) Unknown - Unlikely Lead	Not sure	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	232 NORTH ST	R) Unknown - Unlikely Lead	Not sure	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	234 NORTH ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	235 NORTH ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	237 NORTH ST	D) Copper	No	M) 2001 - 2010		D) Copper	
Lead Status Unknown	239 NORTH ST	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	241 NORTH ST	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	243 NORTH ST	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	245 NORTH ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	538 OAK ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	540 OAK ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	585 OAK ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	528 OAK ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	529 OAK ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	534 OAK ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	535 OAK ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	547 OAK ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	557 OAK ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	580 OAK ST	D) Copper	No	J) 1971 - 1980	lead already removed	D) Copper	
Non-Lead	101 OHIO AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	110 OHIO AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	121 OHIO AVE	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	130-138 OHIO AVE	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	134 OHIO AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	207 OHIO AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	307 OHIO AVE	D) Copper	Not sure	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	430 OHIO AVE	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	434 OHIO AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	435 OHIO AVE	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	437 OHIO AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	438 OHIO AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	442 OHIO AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	445 OHIO AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	447 OHIO AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	451 OHIO AVE	C) Galvanized	No	O) 2011 - 2020	lead already removed	D) Copper	customer verified copper
Lead Status Unknown	452 OHIO AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	456 OHIO AVE	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	467 OHIO AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	468 OHIO AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	469 OHIO AVE	D) Copper	No	J) 1971 - 1980	CHECKED FOR LEAD	D) Copper	
Non-Lead	472 OHIO AVE	D) Copper	No	J) 1971 - 1980	CHECKED FOR LEAD	D) Copper	
Non-Lead	473 OHIO AVE	D) Copper	No	K) 1981 - 1990	CHECKED FOR LEAD	D) Copper	
Non-Lead	477 OHIO AVE	D) Copper	No	K) 1981 - 1990	CHECKED FOR LEAD	D) Copper	
Non-Lead	927-929 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	931 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	933 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	935 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	937 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	939 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	941 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	943 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	945 ORCHARD DR	D) Copper	No	K) 1981 - 1990		K) PEX - cross-linked polyethylene	customer verified pex
Non-Lead	947 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	949 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	950 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	951 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	953 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	955 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	957 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	959 ORCHARD DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	961 ORCHARD DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	963 ORCHARD DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	965 ORCHARD DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	711 ORCHARD COURT	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	712 ORCHARD COURT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	715 ORCHARD COURT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	customer verified coper
Non-Lead	716 ORCHARD COURT	D) Copper	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	customer verified copper
Non-Lead	719 ORCHARD COURT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	720 ORCHARD COURT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	723 ORCHARD COURT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	727 ORCHARD COURT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1001 ORCHARD DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1002 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1003 ORCHARD DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1004 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1005 ORCHARD DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1006 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1007 ORCHARD DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1008 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1009 ORCHARD DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1010 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1011 ORCHARD DRIVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1012 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1014 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1016 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1020 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1024 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1028 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1032 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1036 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1040 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1044 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1048 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1052 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1056 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1060 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1064 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1068 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1072 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Lead Status Unknown	1076 ORCHARD DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1250 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1350 ORCHARD DRIVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1355 ORCHARD DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	NEW WATER SERVICE
Non-Lead	1415 ORCHARD DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified copper
Non-Lead	1500 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC verified copper
Non-Lead	1501 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1540 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1580 ORCHARD DRIVE	E) Cast iron - lined	No	L) 1991 - 2000	DUCTILE IRON	D) Copper	
Non-Lead	1600 ORCHARD DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1603 ORCHARD DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1605 ORCHARD DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1609 ORCHARD DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1610 ORCHARD DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1611 ORCHARD DRIVE	E) Cast iron - lined	No	M) 2001 - 2010		E) Cast iron - lined	
Non-Lead	1613 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1617 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1618 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1620 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1624 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1628 ORCHARD DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	1632 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1636 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1640 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1641 ORCHARD DRIVE	P) Other non-lead material	Not sure	O) 2011 - 2020	DUCTILE IRON	P) Other non-lead material	DUCTILE IRON
Non-Lead	1660 ORCHARD DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	1665 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1667 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1671 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	1675 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1680 ORCHARD DRIVE	P) Other non-lead material	Not sure	L) 1991 - 2000	DUCTILE IRON	D) Copper	
Non-Lead	2631 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2641 ORCHARD DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	2651 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2661 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2671 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	2681 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2691 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2821 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2841 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2861 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2881 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2901 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3000 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3002 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3004 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3006 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	3008 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3010 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3012 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3014 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3016 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3018 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3020 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3022 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3024 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	3026 ORCHARD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	645 ORCHARD DRIVE	D) Copper	No	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	646 ORCHARD DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	655 ORCHARD DRIVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	797 ORCHARD DRIVE	D) Copper	No	K) 1981 - 1990	lead already removed	D) Copper	
Non-Lead	801 ORCHARD DRIVE	D) Copper	No	M) 2001 - 2010	lead already removed	H) PVC - polyvinyl chloride	boc verified plastic
Non-Lead	809 ORCHARD DRIVE	D) Copper	Not sure	M) 2001 - 2010	RENEWED WATER SERVICE	H) PVC - polyvinyl chloride	
Non-Lead	810 ORCHARD DRIVE	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	911-925 ORCHARD DRIVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	967 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	969 ORCHARD DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	369 OVERLEA CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	373 OVERLEA CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	377 OVERLEA COURT	D) Copper	No	L) 1991 - 2000		D) Copper	boc verified copper
Non-Lead	380 OVERLEA COURT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	388 OVERLEA COURT	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	144 OYLER DRIVE	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	102 PARK AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Lead Status Unknown	118 PARK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	122 PARK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	128/132 PARK AVE	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Lead Status Unknown	129 PARK AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	131 PARK AVE	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	135 PARK AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	138/142 PARK AVE	D) Copper	Not sure	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Non-Lead	151 PARK AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	220 PARK AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	228 PARK AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	233/235 PARK AVE	D) Copper	No	J) 1971 - 1980	ALREADY COPPER	D) Copper	
Non-Lead	234 PARK AVE	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	239/241 PARK AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	243 PARK AVE	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	244 PARK AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	251 PARK AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	261/263 PARK AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	280 PARK AVE	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	290 PARK AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	200 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer veified copper
Non-Lead	201 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	204 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	205 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	208 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	209 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	212 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	213 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	216 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	217 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	220 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	221 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	224 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	225 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	228 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	229 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	232 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	233 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	236 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	237 PARKVIEW DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	173 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	177 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	178 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	181 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	182 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	185 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	186 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	189 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	190 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	193 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	194 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	197 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	198 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	20 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	201 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	266 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	270 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	286 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	290 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	294 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	298 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	30 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	306 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	310 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	314 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	318 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	32 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	322 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	326 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	327 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	330 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	331 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	334 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	335 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	338 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	339 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	342 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified plastic
Non-Lead	343 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	347 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	351 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	355 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	40 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	50 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	60 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	70 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	80 PARKWOOD DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	418 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	427 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	428 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	433 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	436 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	439 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	442 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	445 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	451 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	452 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	457 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	460 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	461 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	467 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	468 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	476 PAUL AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	120 PENNCRAFT AVE	D) Copper	Not sure	J) 1971 - 1980		R) Unknown - Unlikely Lead	
Lead Status Unknown	25 PENNCRAFT AVE	D) Copper	Not sure	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Non-Lead	112 PENNSYLVANIA AVE	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Non-Lead	121 PENNSYLVANIA AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	131 PENNSYLVANIA AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	customer verified ductile iron
Non-Lead	134 PENNSYLVANIA AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified pvc
Lead Status Unknown	135 PENNSYLVANIA AVE	D) Copper	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	212 PENNSYLVANIA AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	309 PENNSYLVANIA AVE	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	310 PENNSYLVANIA AVE	D) Copper	Not sure	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Lead Status Unknown	424 PENNSYLVANIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	427 PENNSYLVANIA AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	434 PENNSYLVANIA AVE	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	435 PENNSYLVANIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	442 PENNSYLVANIA AVE	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	461 PENNSYLVANIA AVE	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	462 PENNSYLVANIA AVE	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	469 PENNSYLVANIA AVE	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	480 PENNSYLVANIA AVE	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	484 PENNSYLVANIA AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	485 PENNSYLVANIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1015 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1301 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1419 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1420 PHILADELPHIA AVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Lead Status Unknown	1421 PHILADELPHIA AVE	O) Asbestos cement	Not sure	K) 1981 - 1990		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	1425 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1500 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	1506 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1512 PHILADELPHIA AVE	D) Copper	Not sure	D) 1921 - 1930	REPAIRED WATER SERVICE	R) Unknown - Unlikely Lead	
Lead Status Unknown	1514 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	1516 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	1520 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	258 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	266 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	267 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	276 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	280 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	284 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	297 PHILADELPHIA AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	301 PHILADELPHIA AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	315 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	317 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	320 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	321 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	325 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	339 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	343 PHILADELPHIA AVE	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	347 PHILADELPHIA AVE	D) Copper	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	351 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	353 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	355 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	360 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	361 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	364 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	365 PHILADELPHIA AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	366 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	370 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		H) PVC - polyvinyl chloride	boc verified plastic
Lead Status Unknown	371 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	375 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	387 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	431 PHILADELPHIA AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Lead Status Unknown	500 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	503 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	507 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	510 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	515 PHILADELPHIA AVE	S) Unknown	Not sure	A) Pre-1901		H) PVC - polyvinyl chloride	
Lead Status Unknown	520 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	524 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copoper
Lead Status Unknown	525 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	532 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	535 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	540 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	545 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		H) PVC - polyvinyl chloride	
Lead Status Unknown	546 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	555 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	550 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	556 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	559 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	567 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	568 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	602 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	603 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	604 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	610 PHILADELPHIA AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	613 PHILADELPHIA AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	customer verified lead
Lead Status Unknown	615 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	616 PHILADELPHIA AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Non-Lead	621 PHILADELPHIA AVE	D) Copper	Not sure	C) 1911 - 1920		D) Copper	
Lead Status Unknown	627 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	630 PHILADELPHIA AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	633 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	639 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Non-Lead	640 PHILADELPHIA AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	643 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	649 PHILADELPHIA AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	657 PHILADELPHIA AVE	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	662 PHILADELPHIA AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	670 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	673 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	675 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	704 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	708 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	709 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	722 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	724 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	725 PHILADELPHIA AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Lead Status Unknown	735 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	736 PHILADELPHIA AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	755 PHILADELPHIA AVE	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Lead Status Unknown	756 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	760 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
GRR	808 PHILADELPHIA AVE	C) Galvanized	Not sure	D) 1921 - 1930		D) Copper	boc verified galvanized
Lead Status Unknown	809 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	827 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	828 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Lead Status Unknown	848 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Non-Lead	862 PHILADELPHIA AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	874 PHILADELPHIA AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	913 PHILADELPHIA AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	918 PHILADELPHIA AVE	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	200 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	206 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	210 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	214 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	217 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	218 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	221 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	225 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	229 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	233 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	237 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	241 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	242 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	245 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	246 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	249 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	250 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	253 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	254 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	257 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	boc verified copper
Non-Lead	258 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	261 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC verified copper
Non-Lead	262 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	265 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	266 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	269 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	270 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	273 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	274 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	277 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	278 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	281 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	282 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	286 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	325 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	328 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	329 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	332 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	333 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	336 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	337 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	340 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	341 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	344 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	345 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	348 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	349 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	352 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	353 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	356 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	360 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	361 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	364 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	365 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	405 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	409 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	413 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	414 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	417 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	418 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	421 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	422 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	425 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	426 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	429 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	430 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	434 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	435 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	445 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	455 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	465 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	475 PHOENIX DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Lead Status Unknown	10 PINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	11 PINE ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	331 PINE CT	D) Copper	No	A) Pre-1901	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	51 PLASTERER AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	61 PLASTERER AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	335 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	521 PLEASANT ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	529 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	541 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	543 PLEASANT ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	550 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	553 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	563 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	565 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	567 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	569 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	583 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	607 PLEASANT ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	613 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	617 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	621 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	625 PLEASANT ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	626 PLEASANT ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	628 PLEASANT ST	D) Copper	Not sure	P) 2021 - 2030	moved water service	H) PVC - polyvinyl chloride	
Non-Lead	630 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	H) PVC - polyvinyl chloride	
Lead Status Unknown	632 PLEASANT ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	634 PLEASANT ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	636 PLEASANT ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	646 PLEASANT ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	656/658 PLEASANT ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	701 PLEASANT ST	D) Copper	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Lead Status Unknown	145 E POINT AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	251 E POINT AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	544 E POINT AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	546 E POINT AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	522 POPLAR AVE	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	524 POPLAR AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	528/532 POPLAR AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	535 POPLAR AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	538/542 POPLAR AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	541 POPLAR AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	548 POPLAR AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	boc verified copper
Non-Lead	554 POPLAR AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	1000 POTATO ROLL LN	E) Cast iron - lined	No	O) 2011 - 2020		E) Cast iron - lined	
Non-Lead	1900 POWELL DR	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	1902 POWELL DR	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	1904 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1906 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1908 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1910 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1912 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	1914 POWELL DR	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	1916 POWELL DR	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified copper





Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	2040 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2041 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2042 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2043 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	2044 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2045 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	BOC verified copper
Non-Lead	2046 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2047 POWELL DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	customer verified pvc
Non-Lead	2048 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2049 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	2050 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2051 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	2052 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2053 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	2055 POWELL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	990 PROGRESS RD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1025 PROGRESS RD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1035 PROGRESS RD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1041 PROGRESS RD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1053 PROGRESS RD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1057 PROGRESS RD	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1061 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1065 PROGRESS RD	D) Copper	Not sure	A) Pre-1901		D) Copper	
Non-Lead	1069 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1073 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1077 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1081 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1085 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1089 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1093 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1097 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1101 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1105 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1109 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1113 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1117 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1121 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1125 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1129 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1133 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	boc verified copper
Non-Lead	1137 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1141 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1145 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1149 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1153 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1154 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1157 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1158 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1161 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1162 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1165 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1166 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1169 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1173 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1177 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1201 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1204 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1205 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1208 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1209 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1212 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1213 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1216 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1217 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1220 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1221 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1224 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1225 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	BOC verified copper
Non-Lead	1228 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1229 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1232 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1233 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1237 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1241 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1245 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1248 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1249 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1252 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1253 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1256 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1257 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1260 PROGRESS RD	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	1261 PROGRESS RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1275 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1280 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1281 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1285 PROGRESS RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	811 PROGRESS RD	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	910 PROGRESS RD	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	930 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	941 PROGRESS RD	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	951 PROGRESS RD	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Non-Lead	953 PROGRESS RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	955 PROGRESS RD	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Non-Lead	965 PROGRESS RD	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	975 PROGRESS RD	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	12 QUARRY RD	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	26 QUARRY RD	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Lead Status Unknown	121 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	122 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	123 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	125 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	128 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	129 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	130 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	136 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	143 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	148 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	150 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	156 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	174 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
GRR	180 E QUEEN ST	D) Copper	Not sure	H) 1961 - 1970		Galvanized	BOC verified galvanized
Non-Lead	226 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	228 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	230 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	237 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	248 E QUEEN ST	D) Copper	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Non-Lead	250 E QUEEN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	256 E QUEEN ST	S) Unknown	Not sure	A) Pre-1901		D) Copper	boc verified copper
Non-Lead	258 E QUEEN ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	H) PVC - polyvinyl chloride	
Non-Lead	262 E QUEEN ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	H) PVC - polyvinyl chloride	
Lead Status Unknown	268 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	272 E QUEEN ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	278 E QUEEN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	280 E QUEEN ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	285 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	300 E QUEEN ST	D) Copper	Not sure	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	302 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	305 E QUEEN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	306 E QUEEN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	309 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	310 E QUEEN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	312 E QUEEN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	315 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	317 E QUEEN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC verified copper
Non-Lead	320 E QUEEN ST	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Lead Status Unknown	321 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	322 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	325 E QUEEN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	326 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	330 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	334 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	337 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	339 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	340 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	345 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	346 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	347 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	348 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	351 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	366 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	371 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	377 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	378 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	380 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	385 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	386 E QUEEN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	387 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	390 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	391 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	392 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	394 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	395 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	398 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	408 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	415 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	420 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	426 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	430 E QUEEN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	boc verified copper
Lead Status Unknown	438 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	440 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	446 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	451 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	454 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	458 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	460 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	463 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	464 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	466 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	467 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	476 E QUEEN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
GRR	479 E QUEEN ST	C) Galvanized	Not sure	H) 1961 - 1970		C) Galvanized	
GRR	481 E QUEEN ST	C) Galvanized	Not sure	H) 1961 - 1970		C) Galvanized	
Lead Status Unknown	482 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	486 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	494 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	496 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	498 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	500 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	503 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	510 E QUEEN ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	518 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	520 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	524 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	526 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	538 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	540 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	542 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	550 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	556 E QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	18 W QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	20 W QUEEN ST	D) Copper	Not sure	P) 2021 - 2030		D) Copper	
Lead Status Unknown	32 W QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	38 W QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	5 W QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	60 W QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	66 W QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	72 W QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	75 W QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	78 W QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	82 W QUEEN ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1 RACHEL DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	13 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	17 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Lead Status Unknown	21 RACHEL DR	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	25 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	29 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	33 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	37 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	41 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	43 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	47 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	5 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	51 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	52 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	55 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	56 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	59 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	60 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	63 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	64 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	67 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	68 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	71 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	72 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	75 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	76 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	79 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	80 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	84 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	9 RACHEL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	1090 RAGGED EDGE RD	E) Cast iron - lined	Not sure	H) 1961 - 1970		D) Copper	boc verified
Non-Lead	1206 RAGGED EDGE RD	E) Cast iron - lined	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Non-Lead	390 RAGGED EDGE RD	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	400 RAGGED EDGE RD	D) Copper	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Non-Lead	528 RAGGED EDGE RD	D) Copper	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	976 RAGGED EDGE RD	E) Cast iron - lined	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Non-Lead	122 RAMSEY AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	135 RAMSEY AVE	D) Copper	No	D) 1921 - 1930	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	145 RAMSEY AVE	D) Copper	No	J) 1971 - 1980	removed lead gooseneck	D) Copper	
Non-Lead	224 RAMSEY AVE	D) Copper	No	J) 1971 - 1980	removed lead gooseneck	D) Copper	
Non-Lead	226 RAMSEY AVE	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	230 RAMSEY AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	231 RAMSEY AVE	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	234 RAMSEY AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	247 RAMSEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	248 RAMSEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	258 RAMSEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	259/263 RAMSEY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	262 RAMSEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	265/269 RAMSEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	333 RAMSEY AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	425 RAMSEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	437 RAMSEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	439 RAMSEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	H) PVC - polyvinyl chloride	
Non-Lead	440 RAMSEY AVE	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Lead Status Unknown	10 REDWOOD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	12 REDWOOD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	14 REDWOOD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	16 REDWOOD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	17 REDWOOD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	18 REDWOOD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	2 REDWOOD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	20 REDWOOD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	35 REDWOOD ST	H) PVC - polyvinyl chloride	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	boc verified plastic

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	37 REDWOOD ST	H) PVC - polyvinyl chloride	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	boc verified plastic
Non-Lead	39 REDWOOD ST	H) PVC - polyvinyl chloride	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Lead Status Unknown	4 REDWOOD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	41 REDWOOD ST	H) PVC - polyvinyl chloride	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	43 REDWOOD ST	H) PVC - polyvinyl chloride	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Lead Status Unknown	6 REDWOOD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	8 REDWOOD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	21 REDWOOD ST	H) PVC - polyvinyl chloride	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC verified plastic
Non-Lead	23 REDWOOD ST	H) PVC - polyvinyl chloride	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	25 REDWOOD ST	H) PVC - polyvinyl chloride	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	27 REDWOOD ST	H) PVC - polyvinyl chloride	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	29 REDWOOD ST	H) PVC - polyvinyl chloride	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	31 REDWOOD ST	H) PVC - polyvinyl chloride	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	33 REDWOOD ST	H) PVC - polyvinyl chloride	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	45 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	47 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	49 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	51 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	53 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	54 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	55 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	56 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	57 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	58 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	59 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	61 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	63 REDWOOD ST	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	BOC VERIFIED PLASTIC
Non-Lead	525 RESERVOIR ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	532 RESERVOIR ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	651 RESERVOIR	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	135 RIDDLE RD	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	138 RIDDLE RD	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	139 RIDDLE RD	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	140 RIDDLE RD	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	142 RIDDLE RD	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	150 RIDDLE RD	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	160 RIDDLE RD	R) Unknown - Unlikely Lead	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	161 RIDDLE RD	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	531 RIFE ST.	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	533 RIFE ST.	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	535 RIFE ST.	D) Copper	No	F) 1941 - 1950	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	536 RIFE ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	545 RIFE ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	548 RIFE ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	551 RIFE ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	554 RIFE ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	559 RIFE ST.	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	565 RIFE ST.	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	566 RIFE ST.	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	203 ROLAND AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	261 ROLAND AVE	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	273 ROLAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	300 ROLAND AVE	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	312 ROLAND AVE	D) Copper	No	G) 1951 - 1960	lead already removed	D) Copper	
Non-Lead	313 ROLAND AVE	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	333 ROLAND AVE	D) Copper	No	P) 2021 - 2030	lead gooseneck removed	D) Copper	customer verified copper
Non-Lead	345 ROLAND AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	348 ROLAND AVE	D) Copper	No	H) 1961 - 1970	lead gooseneck already removed	D) Copper	customer verified copper
Non-Lead	355 ROLAND AVE	D) Copper	No	J) 1971 - 1980	lead gooseneck already removed	D) Copper	
Non-Lead	368 ROLAND AVE	D) Copper	No	J) 1971 - 1980	lead gooseneck already removed	D) Copper	
Non-Lead	371 ROLAND AVE	D) Copper	No	G) 1951 - 1960	lead already removed	D) Copper	
Lead Status Unknown	80 ROOSEVELT ARMS COURT	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	82 ROOSEVELT ARMS COURT	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	84 ROOSEVELT ARMS COURT	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	86 ROOSEVELT ARMS COURT	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	88 ROOSEVELT ARMS COURT	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	37 ROSE ST.	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	42 ROSE ST.	D) Copper	No	K) 1981 - 1990	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	302 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	305 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	306 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	309 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	310 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	313 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	314 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	317 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	318 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	321 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	322 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	325 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	326 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	329 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	330 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	341 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	345 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	349 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	350 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	353 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	354 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	357 ROSEANN DRIVE	D) Copper	No	M) 2001 - 2010		D) Copper	
Lead Status Unknown	770 ROSEWOOD CT	R) Unknown - Unlikely Lead	Not sure	K) 1981 - 1990		R) Unknown - Unlikely Lead	
Lead Status Unknown	773 ROSEWOOD CT	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Non-Lead	783 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	789 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	790 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	799 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	800 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	810 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	811 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	831 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	842 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	customer verified copper
Non-Lead	851 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	854 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	861 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	862 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	869 ROSEWOOD CT	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	873 ROSEWOOD CT	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	301 ROY PITZ AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	310 ROY PITZ AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	312 ROY PITZ AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	821 RUSTIC HILL DR	H) PVC - polyvinyl chloride	No	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	822 RUSTIC HILL DR	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	825 RUSTIC HILL DR	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	826 RUSTIC HILL DR	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	831 RUSTIC HILL DR	H) PVC - polyvinyl chloride	No	K) 1981 - 1990		D) Copper	BOC verified copper
Non-Lead	832 RUSTIC HILL DR	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	835 RUSTIC HILL DR	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	841 RUSTIC HILL DR	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	845 RUSTIC HILL DR	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	846 RUSTIC HILL DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	847 RUSTIC HILL DR	D) Copper	No	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	849 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	850 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	851 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	853 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	854 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	858 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	861 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	862 RUSTIC HILL DR	D) Copper	No	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	863 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	866 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	867 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	870 RUSTIC HILL DR	D) Copper	No	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	871 RUSTIC HILL DR	D) Copper	No	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	872 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	873 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	874/876/878 RUSTIC HILL DR	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	875 RUSTIC HILL DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	877 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	879 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	880 RUSTIC HILL DR	D) Copper	No	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	881 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	882 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	883 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	885 RUSTIC HILL DR	D) Copper	No	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	886 RUSTIC HILL DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	11 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	12 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	14 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	15 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	16 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	17 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	18 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	19 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	20 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	21 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	22 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	23 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	24 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	25 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	26 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	27 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	29 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	31 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	33 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	35 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	37 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	39 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	41 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	43 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	45 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	47 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	49 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	51 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	53 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	55 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	56 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	57 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	58 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	59 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	60 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	61 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	62 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	63 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	64 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	65 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	66 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	67 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	68 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	69 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	70 SANIBEL LN	D) Copper	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Lead Status Unknown	1000 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1111 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1112 SCOTLAND AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	1114 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1115 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	1116 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1120 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	1124 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	BOC VERIFIED COPPER
Non-Lead	1127 SCOTLAND AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	1130 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1136 SCOTLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	1139 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1141 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1142 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1148 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1149 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1150 SCOTLAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1152 SCOTLAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1208 SCOTLAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1209 SCOTLAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	1210 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	1211 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1212 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	1214 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	1216 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1220 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1223 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1224 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1229 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1230/1232 SCOTLAND AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	1233 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1237 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1238 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1243 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1244 SCOTLAND AVE	D) Copper	No	M) 2001 - 2010	removed lead	D) Copper	
Lead Status Unknown	1246 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1247 SCOTLAND AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	1304 SCOTLAND AVE	D) Copper	No	F) 1941 - 1950	remove lead gooseneck	D) Copper	
Non-Lead	1307 SCOTLAND AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Lead Status Unknown	1308 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1312 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1314 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1318 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1320 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	1329 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1337 SCOTLAND AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	1338 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1339 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1343-1347 SCOTLAND AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	1352 SCOTLAND AVE	D) Copper	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	1400 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	1401 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1405 SCOTLAND AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	1416 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Non-Lead	1419 SCOTLAND AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Lead Status Unknown	1420 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	1431 SCOTLAND AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	1432 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Lead Status Unknown	1444 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC verified copper
Non-Lead	1446 SCOTLAND AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	boc verified copper
Lead Status Unknown	1447 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	1505 SCOTLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1506 SCOTLAND AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	1524 SCOTLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1527 SCOTLAND AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	BOC verified copper
Non-Lead	1530 SCOTLAND AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	1534 SCOTLAND AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	1535 SCOTLAND AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	1542 SCOTLAND AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	1545 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1550 SCOTLAND AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	1551 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	1558 SCOTLAND AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	1564 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1568 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	1570 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1576 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	1600 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	1604 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	1621 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	1628 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1636 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	1645 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1648 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1660 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1670 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1675 SCOTLAND AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	1714 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	1715 SCOTLAND AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	1741 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	1751 SCOTLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1761 SCOTLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	1762 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1764 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1774 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1809 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1818 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	1830 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	1831 SCOTLAND AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	1842 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	1845 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1850 SCOTLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1855 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	1858 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	1866 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	1875 SCOTLAND AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	1878 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	1881 SCOTLAND AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	1901 SCOTLAND AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Lead Status Unknown	1920 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1930 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1936 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1942 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1948 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1957 SCOTLAND AVE	E) Cast iron - lined	Not sure	G) 1951 - 1960		E) Cast iron - lined	
Lead Status Unknown	1962 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		D) Copper	
Lead Status Unknown	1970 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1976 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1982 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1988 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	2000 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	2011 SCOTLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	2055 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	910 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	916 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	921 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	922 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	923 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	925 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	926 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	927 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC verified copper
Lead Status Unknown	929 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	931 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	934 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	935 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	937 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	944 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	948 SCOTLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	954 SCOTLAND AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	BOC verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	959 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	960 SCOTLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	965 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	970 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	971 SCOTLAND AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	975 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	978 SCOTLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified copper
Lead Status Unknown	979 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	980 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Non-Lead	981/985 SCOTLAND AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	984/986 SCOTLAND AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	988 SCOTLAND AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	989 SCOTLAND AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	990 SCOTLAND AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	993 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	997 SCOTLAND AVE	R) Unknown - Unlikely Lead	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Non-Lead	998 SCOTLAND AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	11 SCOTLAND RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	130 N SECOND ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	217 N SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	218 N SECOND ST	E) Cast iron - lined	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Lead Status Unknown	231 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	272 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	279 N SECOND ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	3 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	305 N SECOND ST	E) Cast iron - lined	Not sure	G) 1951 - 1960		E) Cast iron - lined	boc verified copper
Lead Status Unknown	31 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	340 N SECOND ST	D) Copper	Not sure	M) 2001 - 2010	MOVED WATER SERVICE	D) Copper	
Lead Status Unknown	361 N SECOND ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	365 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	39 N SECOND ST	R) Unknown - Unlikely Lead	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	40 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	412 N SECOND ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	420 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	428 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	432 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	436 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	442 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	52 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	56 N SECOND ST	E) Cast iron - lined	Not sure	O) 2011 - 2020		E) Cast iron - lined	
Lead Status Unknown	72 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	74 N SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	80 N SECOND ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	100 S SECOND	E) Cast iron - lined	Not sure	O) 2011 - 2020		E) Cast iron - lined	
Lead Status Unknown	121 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	125 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	127 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	131 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	135 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	139 S SECOND ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Lead Status Unknown	145 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	146 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	152 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	153 S SECOND ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	154 S SECOND ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	157 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		H) PVC - polyvinyl chloride	customer verified plastic
Lead Status Unknown	159 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	161 S SECOND ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	162 S SECOND ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	170 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	172 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	182 S SECOND ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Lead Status Unknown	202 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	212 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	218 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	224 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	225 S SECOND ST	D) Copper	Not sure	M) 2001 - 2010	cut off 7/10/2008	D) Copper	
Lead Status Unknown	232 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	240 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	246 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	252 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	258 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	26 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	261 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	262 S SECOND ST	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	customer verified
Lead Status Unknown	264 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	265 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	266 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	270 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	272 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	273 S SECOND ST	D) Copper	No	O) 2011 - 2020	lead already removed	D) Copper	
Lead Status Unknown	276 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Non-Lead	277 S SECOND ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	280 S SECOND ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	283 S SECOND ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Lead Status Unknown	30 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	300 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	302 S SECOND ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	310 S SECOND ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	customer verified copper
Lead Status Unknown	315 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	319 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	324 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	328 S SECOND ST	S) Unknown	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	33 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	330 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	336 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	34 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	340 S SECOND ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	37 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	38 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	400 S SECOND ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	verified copper
Lead Status Unknown	401 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	412 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	418 S SECOND ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	420 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	425 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	428 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	429 S SECOND ST	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	432 S SECOND ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	433 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	435 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	436 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Non-Lead	439 S SECOND ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	447 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	448 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	453 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	454 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	457 S SECOND ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	boc verified copper
Lead Status Unknown	461 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	473 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	500 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	505 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	507 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	509 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	511 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	513 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	520 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	521 S SECOND ST	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Lead Status Unknown	524 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	526 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	529 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	531 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	532 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	536 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	538 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	539 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	546 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	547 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	55 S SECOND ST	E) Cast iron - lined	Not sure	L) 1991 - 2000		D) Copper	customer verified copper
Lead Status Unknown	550 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	552 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	554 S SECOND ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	555 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	556 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	557 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	558 S SECOND ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Lead Status Unknown	559 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	561 S SECOND ST	S) Unknown	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	563 S SECOND ST	S) Unknown	Not sure	A) Pre-1901		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	568 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	570 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	575 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	578 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	579 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	58 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	583 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	585 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	588 S SECOND ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	589 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	593 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	602 S SECOND ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	603 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	605 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		H) PVC - polyvinyl chloride	customer verified plastic
Lead Status Unknown	606 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		D) Copper	BOC VERIFIED COPPER
Lead Status Unknown	608 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	610 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	612 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	614 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Non-Lead	615 S SECOND ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	616 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	619 S SECOND ST	D) Copper	Not sure	K) 1981 - 1990		R) Unknown - Unlikely Lead	
Non-Lead	620 S SECOND ST	D) Copper	Not sure	P) 2021 - 2030	REPAIR WATER SERVICE LEAK	D) Copper	
Lead Status Unknown	624 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	625 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	632 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	636 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	646 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	647 S SECOND ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	648 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	702 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	706 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	712 S SECOND ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	716 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	720 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	725 S SECOND ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	726 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	734 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	736 S SECOND ST	D) Copper	Not sure	O) 2011 - 2020	MOVED CURB STOP	D) Copper	
Non-Lead	74 S SECOND ST	E) Cast iron - lined	Not sure	K) 1981 - 1990		E) Cast iron - lined	
Lead Status Unknown	740 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	75 S SECOND ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	763 S SECOND ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	773 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	779 S SECOND ST	D) Copper	Not sure	M) 2001 - 2010	REPLACED SERVICE	D) Copper	
Non-Lead	780 S SECOND ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	783 S SECOND ST	D) Copper	Not sure	M) 2001 - 2010	REPLACED SERVICE	D) Copper	
Lead Status Unknown	789 S SECOND ST	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	791 S SECOND ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	112 N SEVENTH ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	boc verified copper
Non-Lead	120 N SEVENTH	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	243 N SEVENTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	260 N SEVENTH ST	E) Cast iron - lined	Not sure	K) 1981 - 1990		E) Cast iron - lined	
Non-Lead	302 N SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD SERVICE	D) Copper	
Lead Status Unknown	59 N SEVENTH ST	D) Copper	Not sure	K) 1981 - 1990		R) Unknown - Unlikely Lead	
Lead Status Unknown	1331 S SEVENTH ST	D) Copper	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Non-Lead	225 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	255 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	273 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	SERVICE CHECKED NO LEAD	D) Copper	customer verified copper
Non-Lead	303 S SEVENTH ST	D) Copper	Not sure	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	321 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	375 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	385 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	395 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	412 S SEVENTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	426 S SEVENTH ST	S) Unknown	Not sure	E) 1931 - 1940		D) Copper	boc verified copper
Lead Status Unknown	427 S SEVENTH ST	D) Copper	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	438 S SEVENTH ST	R) Unknown - Unlikely Lead	Not sure	E) 1931 - 1940		D) Copper	BOC verified copper
Lead Status Unknown	439 S SEVENTH ST	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	444 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	445 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	454 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	457 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	462 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	465 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	470 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	475 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	506 S SEVENTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	507 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	530 S SEVENTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	533 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	560 S SEVENTH ST	D) Copper	No	G) 1951 - 1960	lead already removed	D) Copper	customer verified copper
Lead Status Unknown	561 S SEVENTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	580 S SEVENTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck.	D) Copper	customer verified copper
Lead Status Unknown	581 S SEVENTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	203 S GATE MALL	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	209 S GATE MALL	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	215 S GATE MALL	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	221 S GATE MALL	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	227 S GATE MALL	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	245 S GATE MALL	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	251 S GATE MALL	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	255 S GATE MALL	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1051 SHEFFLER DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1101 SHEFFLER DR	D) Copper	No	L) 1991 - 2000		D) Copper	BOC verified copper
Non-Lead	1151 SHEFFLER DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1201 SHEFFLER DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1440 SHEFFLER DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1445 SHEFFLER DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1469 SHEFFLER DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1473 SHEFFLER DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1477 SHEFFLER DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1481 SHEFFLER DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1489 SHEFFLER DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1100 SHELLER AVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	1102 SHELLER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	1106 SHELLER AVE	D) Copper	No	J) 1971 - 1980		D) Copper	
Non-Lead	1108 SHELLER AVE	E) Cast iron - lined	No	K) 1981 - 1990		D) Copper	
Non-Lead	1110 SHELLER AVE	E) Cast iron - lined	No	L) 1991 - 2000		D) Copper	
Non-Lead	1115 SHELLER AVE	E) Cast iron - lined	No	K) 1981 - 1990		D) Copper	
Non-Lead	3011 SIENNA DR	H) PVC - polyvinyl chloride	No	P) 2021 - 2030		D) Copper	
Non-Lead	3013 SIENNA DR	H) PVC - polyvinyl chloride	No	P) 2021 - 2030		D) Copper	
Non-Lead	3015 SIENNA DR	H) PVC - polyvinyl chloride	No	P) 2021 - 2030		D) Copper	
Non-Lead	3017 SIENNA DR	H) PVC - polyvinyl chloride	No	P) 2021 - 2030		D) Copper	
Non-Lead	3019 SIENNA DR	H) PVC - polyvinyl chloride	No	P) 2021 - 2030		D) Copper	
Non-Lead	3021 SIENNA DR	H) PVC - polyvinyl chloride	No	P) 2021 - 2030		D) Copper	
Lead Status Unknown	100 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	101 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	106 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	107/111 N SIXTH ST	D) Copper	No	C) 1911 - 1920	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	117 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	125 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	131 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	134 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	139 N SIXTH ST	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	R) Unknown - Unlikely Lead	
Non-Lead	212 N SIXTH ST	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	D) Copper	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	22 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	221 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	222 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	231 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	232 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	237 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	240 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	247 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	250 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	36 N SIXTH ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	37 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	38 N SIXTH ST	D) Copper	Not sure	O) 2011 - 2020	ALREADY COOPER	R) Unknown - Unlikely Lead	
Lead Status Unknown	39 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	44 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	51 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	54/58 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	59 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	63 N SIXTH ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	64 N SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	68 N SIXTH ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	131 S SIXTH ST	D) Copper	No	A) Pre-1901	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	132 S SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	H) PVC - polyvinyl chloride	
Lead Status Unknown	136 S SIXTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	139 S SIXTH ST	D) Copper	No	C) 1911 - 1920	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	140 S SIXTH ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	142 S SIXTH ST	D) Copper	No	C) 1911 - 1920	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	143 S SIXTH ST	D) Copper	No	C) 1911 - 1920	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	146 S SIXTH ST	D) Copper	No	C) 1911 - 1920	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	147 S SIXTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	158 S SIXTH ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
GRR	161 S SIXTH ST	D) Copper	No	C) 1911 - 1920	lead already removed	C) Galvanized	
Non-Lead	209 S SIXTH ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	215 S SIXTH ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	216 S SIXTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	222 S SIXTH ST	D) Copper	No	G) 1951 - 1960	lead already removed	D) Copper	
Lead Status Unknown	223 S SIXTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	225 S SIXTH ST	D) Copper	No	C) 1911 - 1920	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	229 S SIXTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	234 S SIXTH ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Lead Status Unknown	235 S SIXTH ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	244 S SIXTH ST	D) Copper	No	L) 1991 - 2000	lead already removed	D) Copper	
Lead Status Unknown	245 S SIXTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	251 S SIXTH ST	D) Copper	No	F) 1941 - 1950	lead already removed	D) Copper	
Non-Lead	258 S SIXTH ST	D) Copper	No	G) 1951 - 1960	lead already removed	D) Copper	
Non-Lead	259 S SIXTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	265 S SIXTH ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	boc verified copper
Non-Lead	268 S SIXTH ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	271 S SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	303 S SIXTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	304 S SIXTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	310 S SIXTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Lead Status Unknown	313 S SIXTH ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	315 S SIXTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	321 S SIXTH ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	322 S SIXTH ST	D) Copper	Not sure	D) 1921 - 1930		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	323 S SIXTH ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	331 S SIXTH ST	D) Copper	No	C) 1911 - 1920	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	332 S SIXTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Lead Status Unknown	337 S SIXTH ST	D) Copper	No	C) 1911 - 1920	lead already removed	R) Unknown - Unlikely Lead	
Non-Lead	346 S SIXTH ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	350 S SIXTH ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	418 S SIXTH ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	425 S SIXTH ST	D) Copper	No	F) 1941 - 1950	remove lead gooseneck	D) Copper	boc verified copper
Non-Lead	428 S SIXTH ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	440 S SIXTH ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	462 S SIXTH ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	511 S SIXTH ST	E) Cast iron - lined	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	512 S SIXTH ST	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	710 S SIXTH ST	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	
Lead Status Unknown	721 S SIXTH ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	726 S SIXTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	740 S SIXTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	72 SOLLENBERGER RD	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Lead Status Unknown	121 E SOUTH ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	130 E SOUTH ST	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Lead Status Unknown	138 E SOUTH ST	D) Copper	Not sure	D) 1921 - 1930	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	10 W SOUTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	110 W SOUTH ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	114 W SOUTH ST	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	14 W SOUTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	26 W SOUTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	30 W SOUTH ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Lead Status Unknown	34 W SOUTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	38 W SOUTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	46 W SOUTH ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	H) PVC - polyvinyl chloride	customer verified polyvinyl
Lead Status Unknown	53 W SOUTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	56 W SOUTH ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	57 W SOUTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Lead Status Unknown	58 W SOUTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	61 W SOUTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	65 W SOUTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	69 W SOUTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	73 W SOUTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	75 W SOUTH ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	80 W SOUTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	81 W SOUTH ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Non-Lead	12 SPRING ST	D) Copper	Not sure	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	16/20 SPRING ST	D) Copper	Not sure	M) 2001 - 2010	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	955 SPRING LN	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Non-Lead	969 SPRING LN	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	995 SPRING LN	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	1105 STANLEY AVE	D) Copper	Not sure	P) 2021 - 2030	lead already removed	D) Copper	
Non-Lead	1120 STANLEY AVE	D) Copper	Not sure	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	1121 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1124 STANLEY AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	1127 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990	lead already removed	D) Copper	
Non-Lead	1128 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990	lead already removed	D) Copper	
Non-Lead	1135 STANLEY AVE	D) Copper	No	K) 1981 - 1990	lead already removed	D) Copper	
Non-Lead	1136 STANLEY AVE	D) Copper	No	K) 1981 - 1990	lead already removed	D) Copper	
Non-Lead	1137 STANLEY AVE	D) Copper	No	K) 1981 - 1990	lead already removed	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1138 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990	lead already removed	D) Copper	
Non-Lead	1139 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990	lead already removed	D) Copper	
Non-Lead	1140 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990	lead already removed	D) Copper	
Non-Lead	1143 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990	lead already removed	D) Copper	
Non-Lead	1144 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990	lead already removed	D) Copper	
Non-Lead	1147 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990	lead already removed	D) Copper	
Lead Status Unknown	1148 STANLEY AVE	D) Copper	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1151 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1152 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1155 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1160 STANLEY AVE	D) Copper	Not sure	A) Pre-1901		D) Copper	
Non-Lead	1165 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1166 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1169 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1170 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1174 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1175 STANLEY AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	1178 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1179 STANLEY AVE	D) Copper	Not sure	M) 2001 - 2010	lead already removed	D) Copper	customer verified copper
Lead Status Unknown	1182 STANLEY AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1183 STANLEY AVE	D) Copper	Not sure	H) 1961 - 1970	lead already removed	D) Copper	
Lead Status Unknown	1208 STANLEY AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1216 STANLEY AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	1220 STANLEY AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1224 STANLEY AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	304 STANLEY AVE	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	R) Unknown - Unlikely Lead	
Non-Lead	310 STANLEY AVE	H) PVC - polyvinyl chloride	No	O) 2011 - 2020		D) Copper	
Non-Lead	422 STANLEY AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	428 STANLEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	434 STANLEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	435 STANLEY AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	444 STANLEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	450 STANLEY AVE	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	456 STANLEY AVE	D) Copper	Not sure	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	458 STANLEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	472 STANLEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	528 STANLEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	534 STANLEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	538 STANLEY AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	551 STANLEY AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	554 STANLEY AVE	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	556 STANLEY AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	559 STANLEY AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	563 STANLEY AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	568 STANLEY AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	573 STANLEY AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Lead Status Unknown	574 STANLEY AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	575 STANLEY AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	580 STANLEY AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	BOC verified copper
Non-Lead	581 STANLEY AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	586 STANLEY AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	H) PVC - polyvinyl chloride	customer verified pvc
Lead Status Unknown	590 STANLEY AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	591 STANLEY AVE	D) Copper	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	600 STANLEY AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	610 STANLEY AVE	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	617 STANLEY AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	620 STANLEY AVE	D) Copper	No	G) 1951 - 1960	lead already removed	D) Copper	
Non-Lead	627 STANLEY AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	630 STANLEY AVE	D) Copper	No	H) 1961 - 1970	lead gooseneck already removed	D) Copper	
Non-Lead	635 STANLEY AVE	D) Copper	No	F) 1941 - 1950	lead gooseneck already removed	D) Copper	
Non-Lead	640 STANLEY AVE	D) Copper	No	H) 1961 - 1970	lead gooseneck already removed	D) Copper	
Lead Status Unknown	645 STANLEY AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	702 STANLEY AVE	D) Copper	No	P) 2021 - 2030	lead gooseneck already removed	D) Copper	customer verified copper
Non-Lead	703 STANLEY AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Lead Status Unknown	712 STANLEY AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	715 STANLEY AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	721 STANLEY AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	722 STANLEY AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	731 STANLEY AVE	D) Copper	No	H) 1961 - 1970	lead gooseneck already removed	D) Copper	
Non-Lead	743 STANLEY AVE	D) Copper	No	H) 1961 - 1970	lead gooseneck already removed	D) Copper	customer verified copper
Lead Status Unknown	753 STANLEY AVE	D) Copper	No	J) 1971 - 1980	lead gooseneck already removed	R) Unknown - Unlikely Lead	
Non-Lead	762 STANLEY AVE	D) Copper	No	J) 1971 - 1980	lead gooseneck already removed	H) PVC - polyvinyl chloride	
Non-Lead	763 STANLEY AVE	D) Copper	No	K) 1981 - 1990	lead gooseneck already removed	D) Copper	
Non-Lead	791 STANLEY AVE	D) Copper	No	K) 1981 - 1990	lead gooseneck already removed	D) Copper	
Non-Lead	801 STANLEY AVE	D) Copper	No	K) 1981 - 1990	lead gooseneck already removed	D) Copper	boc verified copper
Non-Lead	804 STANLEY AVE	D) Copper	No	H) 1961 - 1970	lead gooseneck already removed	D) Copper	
Lead Status Unknown	806 STANLEY AVE	D) Copper	Not sure	K) 1981 - 1990	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	812 STANLEY AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	840 STANLEY AVE	D) Copper	No	K) 1981 - 1990	lead gooseneck already removed	D) Copper	customer verified copper
Non-Lead	841 STANLEY AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	850 STANLEY AVE	D) Copper	No	J) 1971 - 1980	removed lead gooseneck	D) Copper	
Lead Status Unknown	871 STANLEY AVE	R) Unknown - Unlikely Lead	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Non-Lead	4 STANLEY COURT	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	5 STANLEY COURT	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	6 STANLEY COURT	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	7 STANLEY COURT	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	8 STANLEY COURT	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	234 STONEGATE CIR N	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	238 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	239 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	240 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	242 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	244 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	248 STONEGATE CIR N	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	251 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	257 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	BOC verified copper
Non-Lead	263 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	302 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	304 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	306 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	308 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	310 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	312 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	314 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified brass
Non-Lead	316 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	318 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	320 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	322 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	324 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	326 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	328 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified plastic
Non-Lead	330 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	332 STONEGATE CIR N	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	249 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	257 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	267 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	271 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	275 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	279 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	280 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	284 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	287 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	BOC verified copper
Non-Lead	288 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	291 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	292 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	295 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	299 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	301 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	305 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	309 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	313 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	317 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	321 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	325 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	329 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	337 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	339 STONEGATE CIR S	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	341 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	345 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	349 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	351 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	355 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	359 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	367 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	boc verified copper
Non-Lead	371 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	375 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	379 STONEGATE CIR S	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	319 STONEGATE CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	323 STONEGATE CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	327 STONEGATE CT	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	334 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	335 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	338 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	339 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	342 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	343 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	346 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	347 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	350 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	351 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	354 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	355 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	359 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	362 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	363 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	367 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	370 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	371 STONEGATE CT	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1070 STOUFFER AVE	E) Cast iron - lined	Not sure	L) 1991 - 2000		E) Cast iron - lined	
Non-Lead	315 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	316 STOUFFER AVE	D) Copper	No	J) 1971 - 1980		D) Copper	BOC verified copper
Non-Lead	318 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	320 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	321 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	322 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		R) Unknown - Unlikely Lead	
Non-Lead	323 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	324 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	327 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	328 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	330/332 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	BOC verified copper
Non-Lead	333 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	340 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	341 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	348 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	349 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	352 STOUFFER AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	BOC VERIFIED COPPER
Non-Lead	409 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	boc verified copper
Non-Lead	410 STOUFFER AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	413 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	417 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	423 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	429 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	430 STOUFFER AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	435 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	441 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	442 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	boc verified copper
Non-Lead	445 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	449 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	453 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	455 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	509 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	J) 1971 - 1980		R) Unknown - Unlikely Lead	
Non-Lead	515 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	541 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	551 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	561 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	565 STOUFFER AVE	D) Copper	Not sure	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Non-Lead	587 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	621 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	631 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	638 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	641 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	customer verified copper
Non-Lead	644 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	645 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	650 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	653 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	654 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	655 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	658 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	669 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	670 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	673 STOUFFER AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	676 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Lead Status Unknown	707 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Lead Status Unknown	708 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	711 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	714 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	715 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	720 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	721 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	724 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	725 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	729 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	739 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	749 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	750 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	754 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	759 STOUFFER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	760 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	769 STOUFFER AVE	H) PVC - polyvinyl chloride	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	779 STOUFFER AVE	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	780 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	784 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	788 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	789 STOUFFER AVE	D) Copper	Not sure	O) 2011 - 2020	RENEW WATER SERVICE LINE	D) Copper	
Non-Lead	805 STOUFFER AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Lead Status Unknown	808 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	811 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	812 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Non-Lead	819 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	820 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	825 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	826 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	829 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	830 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	833 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	837 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		E) Cast iron - lined	customer reports ductile iron
Non-Lead	840 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	841 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	846 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	851 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	854 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	860 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	861 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	863 STOUFFER AVE	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	864 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	870 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	873 STOUFFER AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	878 STOUFFER AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	879 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	882 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	
Non-Lead	910 STOUFFER AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	916 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	922 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	928 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	933 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	934 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	937 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	940 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	941 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	944 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	945 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	953 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	957 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	961 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	965 STOUFFER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	969 STOUFFER AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	12 ST PAUL DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	169 ST PAUL DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	173 ST PAUL DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	181 ST PAUL DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	185 ST PAUL DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	189 ST PAUL DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	194 ST PAUL DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	customer verified copper
Non-Lead	198 ST PAUL DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	22 ST PAUL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	220 ST PAUL DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	37 ST PAUL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	39 ST PAUL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	49 ST PAUL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	59 ST PAUL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	69 ST PAUL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	7 ST PAUL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	79 ST PAUL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	89 ST PAUL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	99 ST PAUL DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	304 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	305 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	308 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	309 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	312 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	313 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	316 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	317 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	320 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	321 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	324 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	325 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	328 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	332 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	333 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	336 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	337 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	340 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	341 SUELINN DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	344 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	345 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	348 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	349 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	352 SUELINN DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	1073 SUMMER ST	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1077 SUMMER ST	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	161 SUNBROOK DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	162 SUNBROOK DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	166 SUNBROOK DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	170 SUNBROOK DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	171 SUNBROOK DR	D) Copper	No	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	177 SUNBROOK DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	182 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	189 SUNBROOK DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	193 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	197 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	201 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	202 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	205 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	206 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	209 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	210 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	213 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	214 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	217 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	218 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	221 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	222 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	225 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	226 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	229 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	230 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	233 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	234 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	237 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	238 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	241 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	242 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	245 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	246 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	249 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	250 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	253 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	254 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	257 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	258 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	261 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	262 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	265 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	266 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	270 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	274 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	301 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	302 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	303 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	304 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	305 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	306 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	307 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	308 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	309 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	310 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	311 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	312 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	313 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	314 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	315 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	316 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	317 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	318 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	319 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	320 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	322 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	324 SUNBROOK DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	20 SUNSET AVE	D) Copper	Not sure	G) 1951 - 1960		D) Copper	boc verified copper
Lead Status Unknown	114 N THIRD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	116 N THIRD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	128 N THIRD ST	R) Unknown - Unlikely Lead	Not sure	L) 1991 - 2000		R) Unknown - Unlikely Lead	
Lead Status Unknown	140 N THIRD ST	D) Copper	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	18 N THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	20 N THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	22 N THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	24 N THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	39 N THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	46 N THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	50 N THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	76 N THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	77 N THIRD ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	78 N THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	86 N THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	120 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	122 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	123 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	125 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	126 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	127 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	128 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	133 S THIRD ST	D) Copper	No	P) 2021 - 2030	lead already removed	R) Unknown - Unlikely Lead	
Lead Status Unknown	135 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	136 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	138 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	144/146 S THIRD ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	150 S THIRD ST	D) Copper	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	151 S THIRD ST	D) Copper	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	153 S THIRD ST	D) Copper	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Lead Status Unknown	154 S THIRD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	157 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	158 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	161 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	164 S THIRD ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	165 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	169 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	176 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	178 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	180 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	182 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	184 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	230 S THIRD ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Lead Status Unknown	232 S THIRD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	234 S THIRD ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	235 S THIRD ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	254/256 S THIRD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	262 S THIRD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	419 S THIRD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	422 S THIRD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	424 S THIRD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	437 S THIRD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	439 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	441/443 S THIRD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	447 S THIRD ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	450 S THIRD ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	56 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	57 S THIRD ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	58 S THIRD ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	68 S THIRD ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	156 TOBIN DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	160 TOBIN DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	164 TOBIN DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	168 TOBIN DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	169 TOBIN DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	172 TOBIN DR	D) Copper	No	O) 2011 - 2020		D) Copper	customr verified copper
Non-Lead	173 TOBIN DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	176 TOBIN DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	177 TOBIN DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	180 TOBIN DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	181 TOBIN DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	184 TOBIN DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	185 TOBIN DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	189 TOBIN DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	346 TOLBERT AVE	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	352/354 TOLBERT AVE	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	356/358 TOLBERT AVE	D) Copper	Not sure	D) 1921 - 1930		D) Copper	
Non-Lead	362/364 TOLBERT AVE	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	366/368 TOLBERT AVE	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	372/374 TOLBERT AVE	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	378/380 TOLBERT AVE	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	383/385 TOLBERT AVE	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Non-Lead	555 TOLBERT AVE	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Non-Lead	280 TOWER RD	H) PVC - polyvinyl chloride	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	5402 TREHER RD	D) Copper	No	P) 2021 - 2030	removed lead	H) PVC - polyvinyl chloride	boc verified pvc
Non-Lead	169 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	173 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	177 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	181 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	182 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	185 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	186 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	189 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	190 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	193 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	194 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	197 TUCKER DR	D) Copper	No	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	0 VILLAGE SQUARE	E) Cast iron - lined	Not sure	K) 1981 - 1990		E) Cast iron - lined	
Non-Lead	121 E VINE ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	126 E VINE ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	128 E VINE ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	129 E VINE ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	131 E VINE ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	137 E VINE ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	138 E VINE ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	140 E VINE ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	141 E VINE ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	151 E VINE ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	225 W VINE ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	208 W VINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	212 W VINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Non-Lead	218 W VINE ST	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Lead Status Unknown	101 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	115 WALKER RD	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	147 WALKER RD	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Lead Status Unknown	199 WALKER RD	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	211 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	225 WALKER RD	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Lead Status Unknown	231 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	235 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	237 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	239 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	241/243 WALKER RD	R) Unknown - Unlikely Lead	Not sure	O) 2011 - 2020		D) Copper	customer verified copper
Lead Status Unknown	245 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	247 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	249 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	255 WALKER RD	R) Unknown - Unlikely Lead	Not sure	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Lead Status Unknown	301 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	351 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	430 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	500 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	540 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	580 WALKER RD	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1000 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1001 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	1009 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1010 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	1020 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	1021 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	1030 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	1031 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1040 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	1041 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	1050 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	1051 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	1059 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	1060 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Lead Status Unknown	610 WALLACE AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	611 WALLACE AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	622 WALLACE AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	631 WALLACE AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	634 WALLACE AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	641 WALLACE AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	644 WALLACE AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	651 WALLACE AVE	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	897 WALLACE AVE	D) Copper	No	M) 2001 - 2010	removed lead goseneck	D) Copper	
Non-Lead	900 WALLACE AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	901 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	905 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	906 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	customer verified pex
Non-Lead	909 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	914 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	915 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	920 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	921 WALLACE AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	926 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	935 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	936 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	937 WALLACE AVE	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	1 WASHABAUGH WAY	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	106 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	110 E WASHINGTON ST	R) Unknown - Unlikely Lead	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Non-Lead	112 E WASHINGTON ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	114 E WASHINGTON ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Lead Status Unknown	120 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	121 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	122 E WASHINGTON ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	124 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	128 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	138 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	139 E WASHINGTON ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	140 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	147 E WASHINGTON ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	BOC verified copper
Lead Status Unknown	157 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	163 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	165 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	173 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	177 E WASHINGTON ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	181 E WASHINGTON ST	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	214 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	217 E WASHINGTON ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	218 E WASHINGTON ST	D) Copper	Not sure	O) 2011 - 2020	removed lead gooseneck	D) Copper	BOC verified copper
Non-Lead	219 E WASHINGTON ST	D) Copper	Not sure	O) 2011 - 2020	removed lead gooseneck	D) Copper	
Lead Status Unknown	222 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	227 E WASHINGTON ST	D) Copper	Not sure	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	228 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	235 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	245 E WASHINGTON ST	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Non-Lead	246 E WASHINGTON ST	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	BOC verified copper
Non-Lead	248 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	BOC verified copper
Lead Status Unknown	251 E WASHINGTON ST	D) Copper	Not sure	H) 1961 - 1970	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	254 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	255 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	259 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	260 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	262 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	265 E WASHINGTON ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	268 E WASHINGTON ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	270 E WASHINGTON ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	271 E WASHINGTON ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	274 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	277 E WASHINGTON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Lead Status Unknown	278 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	280 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	281 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	306 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	307 E WASHINGTON ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	308 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	310 E WASHINGTON ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	311 E WASHINGTON ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	315 E WASHINGTON ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	318 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	319 E WASHINGTON ST	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Non-Lead	322 E WASHINGTON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	323 E WASHINGTON ST	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Non-Lead	327 E WASHINGTON ST	D) Copper	No	O) 2011 - 2020	lead gooseneck removed	D) Copper	
Non-Lead	329 E WASHINGTON ST	D) Copper	No	F) 1941 - 1950	lead gooseneck removed	D) Copper	
Lead Status Unknown	330 E WASHINGTON ST	D) Copper	Not sure	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	335 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	lead gooseneck removed	D) Copper	
Non-Lead	337 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	lead gooseneck removed	D) Copper	
Non-Lead	354 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	356 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	359 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	360 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	362 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	365 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	366 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	368 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	372 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Lead Status Unknown	373 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	376 E WASHINGTON ST	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	
Lead Status Unknown	379 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	380 E WASHINGTON ST	D) Copper	No	G) 1951 - 1960	lead already removed	D) Copper	
Lead Status Unknown	383 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	384 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	386 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	387 E WASHINGTON ST	D) Copper	No	L) 1991 - 2000	removed lead gooseneck	D) Copper	
Non-Lead	390 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	leaad already removed	D) Copper	
Non-Lead	395 E WASHINGTON ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	396 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	398 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	399 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	401 E WASHINGTON ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	402 E WASHINGTON ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	408 E WASHINGTON ST	D) Copper	Not sure	D) 1921 - 1930		H) PVC - polyvinyl chloride	
Non-Lead	410 E WASHINGTON ST	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	414 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	421 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	422 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	423 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	424 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	426 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	427 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	432 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	433 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	435 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	436 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	already copper	D) Copper	
Non-Lead	438 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	already copper	D) Copper	
Lead Status Unknown	441 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	442 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	already copper	D) Copper	
Non-Lead	445 E WASHINGTON ST	D) Copper	Not sure	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Lead Status Unknown	446 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	447 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	448 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	449 E WASHINGTON ST	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	450 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	451 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	452 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	456 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	457 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	458 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	460/462 E WASHINGTON ST	D) Copper	No	H) 1961 - 1970	lead already removed	D) Copper	
Non-Lead	465 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	472 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	482 E WASHINGTON ST	D) Copper	Not sure	G) 1951 - 1960		R) Unknown - Unlikely Lead	customer verified copper
Lead Status Unknown	484 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	485 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	487 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	488 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	489 E WASHINGTON ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	boc verified copper
Non-Lead	492 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	494 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	496 E WASHINGTON ST	D) Copper	No	C) 1911 - 1920	removed lead gooseneck	D) Copper	
Non-Lead	497 E WASHINGTON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	498 E WASHINGTON ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	499 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	502 E WASHINGTON ST	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Lead Status Unknown	507 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	509 E WASHINGTON ST	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	514 E WASHINGTON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	517 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	518 E WASHINGTON ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	520 E WASHINGTON ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	527 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	533 E WASHINGTON ST	D) Copper	No	H) 1961 - 1970	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	540 E WASHINGTON ST	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	543 E WASHINGTON ST	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Lead Status Unknown	547 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	550 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	552 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	555 E WASHINGTON ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Lead Status Unknown	561 E WASHINGTON ST	R) Unknown - Unlikely Lead	Not sure	H) 1961 - 1970		R) Unknown - Unlikely Lead	
Non-Lead	570 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	602 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	612 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	613 E WASHINGTON ST	D) Copper	Yes	J) 1971 - 1980	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	621 E WASHINGTON ST	D) Copper	No	H) 1961 - 1970	removed lead gooseneck	D) Copper	
Lead Status Unknown	629 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	632 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	639 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Lead Status Unknown	641 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	645 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	703 E WASHINGTON ST	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	707 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	713 E WASHINGTON ST	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	721 E WASHINGTON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Non-Lead	723 E WASHINGTON ST	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Lead Status Unknown	725 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	727 E WASHINGTON ST	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	729 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	730 E WASHINGTON ST	E) Cast iron - lined	Not sure	K) 1981 - 1990		E) Cast iron - lined	
Lead Status Unknown	731 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	733 E WASHINGTON ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	740 E WASHINGTON ST	D) Copper	No	J) 1971 - 1980	removed lead gooseneck	D) Copper	
Lead Status Unknown	745 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	749 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	751 E WASHINGTON ST	D) Copper	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead	
Lead Status Unknown	753 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	755 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	757 E WASHINGTON ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	759 E WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	760 E WASHINGTON ST	D) Copper	No	K) 1981 - 1990	removed lead gooseneck	D) Copper	
Lead Status Unknown	125 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	184 W WASHINGTON ST	E) Cast iron - lined	Not sure	H) 1961 - 1970		E) Cast iron - lined	
Lead Status Unknown	20 W WASHINGTON ST	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	22 W WASHINGTON	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	290 W WASHINGTON ST	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	30 W WASHINGTON	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	320 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	34 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	37 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	39 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	40 W WASHINGTON ST	D) Copper	Not sure	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Lead Status Unknown	402 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	41 W WASHINGTON ST	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Lead Status Unknown	412 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	422 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	43 W WASHINGTON ST	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	436 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	440 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	441 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	445 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	449 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	460 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	468 W WASHINGTON ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	78 W WASHINGTON ST	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	8 W WASHINGTON ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	9 W WASHINGTON	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	130 WATER ST	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Lead Status Unknown	132 S WATER ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	134 S WATER ST	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	0 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1001 WAYNE AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	customer verified copper
Lead Status Unknown	1002 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1005 WAYNE AVE	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Lead Status Unknown	1007 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1009 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1011 WAYNE AVE	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	1013 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1017 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1019 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	boc verified copper
Lead Status Unknown	1021 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1025 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1035 WAYNE AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1039 WAYNE AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	1050 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1051 WAYNE AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	1056 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1060 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1070 WAYNE AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	1071 WAYNE AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	1080 WAYNE AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Lead Status Unknown	1086 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		D) Copper	customer verified copper
Non-Lead	1090 WAYNE AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	1091 WAYNE AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Lead Status Unknown	1093 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1095 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	1097 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1099 WAYNE AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	201 WAYNE AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	307 WAYNE AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	311 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	317 WAYNE AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	321 WAYNE AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	329 WAYNE AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	333 WAYNE AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	337 WAYNE AVE	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	349 WAYNE AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	359 WAYNE AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	365 WAYNE AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Non-Lead	366 WAYNE AVE	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Non-Lead	371 WAYNE AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	402 WAYNE AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	405 WAYNE AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	422 WAYNE AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
GRR	424 WAYNE AVE	C) Galvanized	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
Lead Status Unknown	431 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Non-Lead	434 WAYNE AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	439 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Non-Lead	440 WAYNE AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	443 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	453 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	454 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	customer verified copper
Non-Lead	460 WAYNE AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	461 WAYNE AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	472 WAYNE AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	473 WAYNE AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
GRR	502 WAYNE AVE	C) Galvanized	Not sure	F) 1941 - 1950		D) Copper	customer verified copper
GRR	508 WAYNE AVE	C) Galvanized	Not sure	F) 1941 - 1950		C) Galvanized	
Lead Status Unknown	514 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	515 WAYNE AVE	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Lead Status Unknown	521 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Lead Status Unknown	528 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	535 WAYNE AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	customer verified copper
Non-Lead	544 WAYNE AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Lead Status Unknown	545 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
GRR	546 WAYNE AVE	D) Copper	Not sure	O) 2011 - 2020	replaced main to meter pit	C) Galvanized	
Lead Status Unknown	551 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	557 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Non-Lead	560 WAYNE AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	boc verified copper
Non-Lead	565 WAYNE AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	572 WAYNE AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	replaced meter pit to building
Non-Lead	601 WAYNE AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	602 WAYNE AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	603 WAYNE AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	615 WAYNE AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	616 WAYNE AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	632 WAYNE AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	646 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	E) 1931 - 1940		R) Unknown - Unlikely Lead	
Non-Lead	653 WAYNE AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	660 WAYNE AVE	D) Copper	Not sure	F) 1941 - 1950		D) Copper	
Non-Lead	672 WAYNE AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	681 WAYNE AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	701 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	777 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	781 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	785 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	787 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	791 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	800 WAYNE AVE	E) Cast iron - lined	Not sure	M) 2001 - 2010		D) Copper	
Lead Status Unknown	801 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	803 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	804 WAYNE AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	810 WAYNE AVE	D) Copper	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Lead Status Unknown	811 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	819 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	820 WAYNE AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Lead Status Unknown	829 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	831 WAYNE AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	840 WAYNE AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	841 WAYNE AVE	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	900 WAYNE AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	915 WAYNE AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	925 WAYNE AVE	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Lead Status Unknown	935 WAYNE AVE	R) Unknown - Unlikely Lead	Not sure	K) 1981 - 1990		R) Unknown - Unlikely Lead	
Lead Status Unknown	947 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	959 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	985 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	987 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Lead Status Unknown	993 WAYNE AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	252 WEST BURKHART AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	256 WEST BURKHART AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	264 WEST BURKHART AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	265 WEST BURKHART AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	278 WEST BURKHART AVE.	D) Copper	Not sure	G) 1951 - 1960		D) Copper	
Non-Lead	370 WEST BURKHART AVE.	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	102 WEST CATHERINE ST.	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	11/19 WEST CATHERINE ST.	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	D) Copper	customer verified copper
Lead Status Unknown	133 WEST CATHERINE ST.	D) Copper	Not sure	F) 1941 - 1950		R) Unknown - Unlikely Lead	
Non-Lead	155 WEST CATHERINE ST.	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Lead Status Unknown	18 WEST CATHERINE ST.	D) Copper	No	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Lead Status Unknown	25 /29 WEST CATHERINE ST.	D) Copper	No	O) 2011 - 2020	REPAIRED WATER SERVICE	R) Unknown - Unlikely Lead	
Non-Lead	30 WEST CATHERINE ST.	D) Copper	No	J) 1971 - 1980	removed lead gooseneck	D) Copper	
Lead Status Unknown	34/38 WEST CATHERINE ST.	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	35 WEST CATHERINE ST.	D) Copper	No	E) 1931 - 1940	removed lead gooseneck	D) Copper	
Lead Status Unknown	37 WEST CATHERINE ST.	D) Copper	No	O) 2011 - 2020		R) Unknown - Unlikely Lead	
Lead Status Unknown	48 WEST CATHERINE ST.	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Non-Lead	50 WEST CATHERINE ST.	D) Copper	No	D) 1921 - 1930	removed lead gooseneck	D) Copper	
Lead Status Unknown	64 WEST CATHERINE ST.	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	67 WEST CATHERINE ST.	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Non-Lead	7 WEST CATHERINE ST.	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Lead Status Unknown	9 WEST CATHERINE ST.	D) Copper	No	O) 2011 - 2020	removed lead gooseneck	R) Unknown - Unlikely Lead	
Lead Status Unknown	132 W CATHERINE ST	R) Unknown - Unlikely Lead	Not sure	C) 1911 - 1920		R) Unknown - Unlikely Lead	
Lead Status Unknown	12 W CATHERINE ST	R) Unknown - Unlikely Lead	Not sure	M) 2001 - 2010	new water lateral installed	R) Unknown - Unlikely Lead	
Lead Status Unknown	0 WEAVER AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	514 WEAVER AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Non-Lead	515 WEAVER AVE	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Non-Lead	521 WEAVER AVE	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Non-Lead	525 WEAVER AVE	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Non-Lead	526 WEAVER AVE	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Non-Lead	535 WEAVER AVE	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Non-Lead	536 WEAVER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	544 WEAVER AVE	D) Copper	No	O) 2011 - 2020	ALREADY COPPER	D) Copper	
Non-Lead	545 WEAVER AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	550 WEAVER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	551 WEAVER AVE	D) Copper	Not sure	O) 2011 - 2020	already copper	D) Copper	
Non-Lead	557 WEAVER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	560 WEAVER AVE	D) Copper	Not sure	O) 2011 - 2020	SERVICE ALREADY COPPER	D) Copper	
Non-Lead	561 WEAVER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	569 WEAVER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	575 WEAVER AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	579 WEAVER AVE	D) Copper	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	BOC verified copper
Non-Lead	307 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	308 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	311 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	312 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	315 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	316 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	319 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	320 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	324 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	327 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	328 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	334 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	335 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	339 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	340 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	343 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	344 WELLSLEE DR	D) Copper	No	L) 1991 - 2000		D) Copper	customer verified copper
Non-Lead	1048 WESTGATE DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1052 WESTGATE DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1056 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1059 WESTGATE DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1060 WESTGATE DR	D) Copper	No	K) 1981 - 1990		D) Copper	
Non-Lead	1063 WESTGATE DR	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1064 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1067 WESTGATE DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1068 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1071 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1072 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1075 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	1076 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1079 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1080 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1083 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1084 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1087 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1088 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	1090 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	1091 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1094 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1095 WESTGATE DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1098 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1099 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1102 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	1103 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1106 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	1107 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	1111 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	1115 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1130 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	1134 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1138 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	1142 WESTGATE DR	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1146 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1150 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1154 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1158 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1162 WESTGATE DR	D) Copper	No	K) 1981 - 1990		D) Copper	customer verified copper
Non-Lead	1166 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1170 WESTGATE DR	D) Copper	No	K) 1981 - 1990		D) Copper	boc verified copper
Non-Lead	1174 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1178 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	1182 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	BOC VERIFIED COPPER
Non-Lead	1186 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	boc verified cooper
Non-Lead	1190 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	1193 WESTGATE DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	200 WHITLEY DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	201 WHITLEY DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	202 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	203 WHITLEY DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	204 WHITLEY DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	205 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	206 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	207 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	208 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	209 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	210 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	211 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	212 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	213 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	214 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	215 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	216 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	217 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	218 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	219 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	220 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	221 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	222 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	223 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	224 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	225 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	226 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	227 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	228 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	229 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	230 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	231 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	232 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	233 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	234 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	235 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	236 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	237 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	238 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	239 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	240 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	241 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	242 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	243 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	244 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	245 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	246 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	247 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	248 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	249 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	250 WHITLEY DR	D) Copper	No	O) 2011 - 2020		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	251 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	252 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	254 WHITLEY DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	15 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	17 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	19 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	21 WILLIAM PENN DR	D) Copper	Not sure	L) 1991 - 2000		H) PVC - polyvinyl chloride	
Non-Lead	23 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	25 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	27 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	30 WILLIAM PENN DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	32 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	34 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	35 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	36 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	37 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	38 WILLIAM PENN DR	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified
Non-Lead	39 WILLIAM PENN DR	D) Copper	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	41 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	43 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	47 WILLIAM PENN DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	49 WILLIAM PENN DR	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	51 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	53 WILLIAM PENN DR	H) PVC - polyvinyl chloride	Not sure	M) 2001 - 2010		H) PVC - polyvinyl chloride	
Non-Lead	55 WILLIAM PENN DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	85 WILLOWBROOK DR	D) Copper	Not sure	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	94 WILLOWBROOK DR	D) Copper	Not sure	M) 2001 - 2010		D) Copper	
Lead Status Unknown	1002 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	1018 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	1024 WILSON AVE	D) Copper	Not sure	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	customer verified copper
Lead Status Unknown	1025 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	1039 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	custpomer verified copper
Non-Lead	1040 WILSON AVE	D) Copper	No	P) 2021 - 2030	lead already removed	D) Copper	
Non-Lead	1053 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	1106 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	1118 WILSON AVE	D) Copper	No	K) 1981 - 1990	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	1128 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	1129 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	1137 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	1140 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	1142 WILSON AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	1204 WILSON AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	1216 WILSON AVE	D) Copper	No	K) 1981 - 1990	LEAD ALREADY REMOVED	D) Copper	
Non-Lead	1217 WILSON AVE	D) Copper	No	K) 1981 - 1990	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	1220 WILSON AVE	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	1229 WILSON AVE	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	1230 WILSON AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	1235 WILSON AVE	D) Copper	No	D) 1921 - 1930	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	1240 WILSON AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	1307 WILSON AVE	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Non-Lead	1311 WILSON AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	1314 WILSON AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	1316 WILSON AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead	
Non-Lead	1318 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	1322 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)		
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments	
Non-Lead	1325 WILSON AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper		
Lead Status Unknown	1405 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead		
Non-Lead	1413 WILSON AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper	
Lead Status Unknown	1416 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead		
Non-Lead	1427 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper	
Non-Lead	1431 WILSON AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper		
Non-Lead	1445 WILSON AVE	D) Copper	No	E) 1931 - 1940	REMOVED LEAD GOOSENECK	D) Copper		
Non-Lead	1447 WILSON AVE	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper	
Non-Lead	1509 WILSON AVE	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper		
Non-Lead	1516 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper	
Lead Status Unknown	1521 WILSON AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead		
Non-Lead	1529 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper	
Non-Lead	1530 WILSON AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper		
Non-Lead	1537 WILSON AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper		
Non-Lead	1554 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper	
Non-Lead	1555 WILSON AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper		
Non-Lead	1560 WILSON AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper		
Non-Lead	1566 WILSON AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper	
Non-Lead	1575 WILSON AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper		
Non-Lead	1587 WILSON AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper		
Lead Status Unknown	1605 WILSON AVE	D) Copper	Not sure	M) 2001 - 2010		R) Unknown - Unlikely Lead		
Non-Lead	1617 WILSON AVE	D) Copper	Not sure	M) 2001 - 2010		D) Copper		
Non-Lead	1630 WILSON AVE	D) Copper	Not sure	M) 2001 - 2010		D) Copper		
Non-Lead	1694 WILSON AVE	D) Copper	Not sure	M) 2001 - 2010		D) Copper		
Lead Status Unknown	904 WILSON AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead		
Lead Status Unknown	910-912 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead		
Lead Status Unknown	914 WILSON AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead		
Lead Status Unknown	915 WILSON AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead		
Lead Status Unknown	916 WILSON AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead		
Lead Status Unknown	918 WILSON AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead		
Lead Status Unknown	921 WILSON AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead		
Lead Status Unknown	922 WILSON AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead		
Lead Status Unknown	926 WILSON AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead		
Non-Lead	927 WILSON AVE	D) Copper	Not sure	H) 1961 - 1970		D) Copper		
Non-Lead	931 WILSON AVE	D) Copper	No	P) 2021 - 2030		D) Copper	customer verified copper	
Non-Lead	937 WILSON AVE	D) Copper	Not sure	K) 1981 - 1990		D) Copper		
Lead Status Unknown	938 WILSON AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead		
Lead Status Unknown	943 WILSON AVE	R) Unknown - Unlikely Lead	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead		
Lead Status Unknown	944 WILSON AVE	O) Asbestos cement	Not sure	A) Pre-1901		R) Unknown - Unlikely Lead		
Lead Status Unknown	948 WILSON AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	R) Unknown - Unlikely Lead		
Non-Lead	953 WILSON AVE	D) Copper	Not sure	H) 1961 - 1970	LEAD ALREADY REMOVED	D) Copper		
Lead Status Unknown	954 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead		
Lead Status Unknown	962 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead		
Lead Status Unknown	963 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead		
Lead Status Unknown	972 WILSON AVE	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead		
Non-Lead	976 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper	
Non-Lead	980 WILSON AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper	
Non-Lead	100 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper		
Non-Lead	101 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper		
Non-Lead	102 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper		
Non-Lead	103 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper		
Non-Lead	104 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper		
Non-Lead	105 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper		
Non-Lead	106 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper		
Non-Lead	107 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper		

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	108 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	109 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	110 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	111 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	112 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	113 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	114 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	115 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	116 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	118 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	120 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	122 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	124 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	126 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	128 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	130 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	132 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	134 WINDMILL LN	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	327 WOLF AVE	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	329 WOLF AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	330 WOLF AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	331 WOLF AVE	D) Copper	No	F) 1941 - 1950	removed lead gooseneck	D) Copper	
Non-Lead	351 WOLF AVE	D) Copper	No	G) 1951 - 1960	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	357 WOLF AVE	D) Copper	No	F) 1941 - 1950	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	403 WOLF AVE	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	408 WOLF AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	410 WOLF AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	412 WOLF AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	414 WOLF AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	416 WOLF AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	430 WOLF AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	432 WOLF AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	437 WOLF AVE	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	802 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	803 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	804 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	805 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	806 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	807 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	808 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	809 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	810 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified COPPER
Non-Lead	811 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	812 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	boc verified copper
Non-Lead	814 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	customer verified COPPER
Non-Lead	815 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	817 WOODLAWN CIR	D) Copper	Not sure	H) 1961 - 1970		D) Copper	
Non-Lead	820 WOODLAWN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	822 WOODLAWN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	customer verified COPPER
Non-Lead	823 WOODLAWN DR	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	824 WOODLAWN DR	D) Copper	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	825 WOODLAWN DR	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	826 WOODLAWN DR	D) Copper	Not sure	J) 1971 - 1980		D) Copper	REPAIR CURBSTOP TO BLDG
Non-Lead	828 WOODLAWN DR	D) Copper	Not sure	J) 1971 - 1980		D) Copper	Replaced curb stop to house
Non-Lead	830 WOODLAWN DR	D) Copper	Not sure	J) 1971 - 1980		D) Copper	

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	839 WOODLAWN DR	D) Copper	Not sure	K) 1981 - 1990		D) Copper	
Non-Lead	840 WOODLAWN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	841 WOODLAWN DR	D) Copper	Not sure	J) 1971 - 1980		D) Copper	
Non-Lead	842 WOODLAWN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	843 WOODLAWN DR	D) Copper	Not sure	L) 1991 - 2000		D) Copper	
Non-Lead	844 WOODLAWN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	845 WOODLAWN DR	H) PVC - polyvinyl chloride	Not sure	K) 1981 - 1990		H) PVC - polyvinyl chloride	
Non-Lead	846 WOODLAWN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	847 WOODLAWN DR	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	848 WOODLAWN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	849 WOODLAWN DR	D) Copper	Not sure	F) 1941 - 1950		H) PVC - polyvinyl chloride	
Non-Lead	850 WOODLAWN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	851 WOODLAWN DR	D) Copper	Not sure	O) 2011 - 2020		D) Copper	
Non-Lead	852 WOODLAWN DR	H) PVC - polyvinyl chloride	Not sure	J) 1971 - 1980		H) PVC - polyvinyl chloride	
Non-Lead	860 WOODLAWN DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	862 WOODLAWN DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	864 WOODLAWN DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	866 WOODLAWN DR	D) Copper	Not sure	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	868 WOODLAWN DR	D) Copper	Not sure	O) 2011 - 2020		D) Copper	customer verified copper
Non-Lead	870 WOODLAWN DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	customer verified plastic
Non-Lead	872 WOODLAWN DR	D) Copper	Not sure	O) 2011 - 2020		H) PVC - polyvinyl chloride	
Non-Lead	430 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	480 WOODSTOCK RD	D) Copper	No	P) 2021 - 2030	removed lead gooseneck	D) Copper	
Non-Lead	485 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	513 WOODSTOCK RD	D) Copper	No	L) 1991 - 2000	removed lead gooseneck	D) Copper	
Non-Lead	514 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	customer verified copper
Non-Lead	517 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	520 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	521 WOODSTOCK RD	D) Copper	No	L) 1991 - 2000		D) Copper	
Non-Lead	526 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	527 WOODSTOCK RD	D) Copper	No	L) 1991 - 2000	removed lead gooseneck	D) Copper	
Non-Lead	530 WOODSTOCK RD	D) Copper	No	L) 1991 - 2000	removed lead gooseneck	D) Copper	
Non-Lead	531 WOODSTOCK RD	D) Copper	No	L) 1991 - 2000	removed lead gooseneck	D) Copper	
Non-Lead	535 WOODSTOCK RD	D) Copper	No	L) 1991 - 2000	removed lead gooseneck	D) Copper	
Non-Lead	539 WOODSTOCK RD	D) Copper	No	L) 1991 - 2000	removed lead gooseneck	D) Copper	
Non-Lead	540 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	543 WOODSTOCK RD	D) Copper	No	L) 1991 - 2000	removed lead gooseneck	D) Copper	
Non-Lead	550 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	552 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	556 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	570 WOODSTOCK RD	D) Copper	No	K) 1981 - 1990	removed lead gooseneck	H) PVC - polyvinyl chloride	
Non-Lead	574 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	580 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	586 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	
Non-Lead	587 WOODSTOCK RD	D) Copper	No	G) 1951 - 1960	removed lead gooseneck	D) Copper	boc verified copper
Non-Lead	707 WOODSTOCK RD	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	H) PVC - polyvinyl chloride	boc verified
Non-Lead	902 WOODSTOCK RD	D) Copper	No	M) 2001 - 2010	removed lead gooseneck	D) Copper	
Non-Lead	215 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	219 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified
Non-Lead	220 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	223 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	224 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified
Non-Lead	227 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	228 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	231 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified

Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Non-Lead	232 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified
Non-Lead	235 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	236 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	239 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	240 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	243 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	244 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	247 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	248 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	251 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	252 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	255 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	256 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified
Non-Lead	259 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	260 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	263 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	264 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	268 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	272 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	301 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	302 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	303 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	304 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	305 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	306 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	307 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	308 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	309 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	310 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	311 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	312 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	313 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	314 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	315 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	316 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	317 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	319 WOODVALE DR	D) Copper	No	O) 2011 - 2020		D) Copper	
Non-Lead	321 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	323 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	customer verified copper
Non-Lead	325 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Non-Lead	327 WOODVALE DR	D) Copper	No	M) 2001 - 2010		D) Copper	
Lead Status Unknown	226 W QUEEN ST	D) Copper	Not sure	P) 2021 - 2030		R) Unknown - Unlikely Lead	
Lead Status Unknown	235/237 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	236 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	241/243 W QUEEN ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	242 W QUEEN ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Lead Status Unknown	246 W QUEEN ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	247 W QUEEN ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	248 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	254 W QUEEN ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	257/261 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	258 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	26 W QUEEN ST	D) Copper	Not sure	E) 1931 - 1940		D) Copper	
Lead Status Unknown	263 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	264 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	



Service Line Basic Information		Utility Owned Portion of the Service Line (Main to Curbstop)				Customer Owned Portion of the Service Line (Curbstop to Building)	
Service Line Classification	Address	Material	Lead Gooseneck	Install Date	Service Line Comments	Material	Service Line Comments
Lead Status Unknown	271/275 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	279 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	281 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	286/288 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	296 W QUEEN ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	30 W QUEEN ST	D) Copper	Not sure	D) 1921 - 1930		R) Unknown - Unlikely Lead	
Lead Status Unknown	302 W QUEEN ST	D) Copper	No	O) 2011 - 2020	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	328 W QUEEN ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	332 W QUEEN ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Lead Status Unknown	333 W QUEEN ST	D) Copper	No	M) 2001 - 2010	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	341 W QUEEN ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	R) Unknown - Unlikely Lead	
Non-Lead	342 W QUEEN ST	D) Copper	No	P) 2021 - 2030	LEAD ALREADY REMOVED	D) Copper	
Lead Status Unknown	343 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	352 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	353 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	358 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	359 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	363 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	364 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	367 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	368 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	372 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	373 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	375 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	378 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	384 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	385 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	390 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	395 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	402 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Lead Status Unknown	404 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	405 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	boc verified copper
Lead Status Unknown	410 W QUEEN ST	D) Copper	No	P) 2021 - 2030	ALREADY COPPER	R) Unknown - Unlikely Lead	
Non-Lead	411 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Non-Lead	415 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Lead Status Unknown	420 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	431 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	REPLACED CURB VALVE
Lead Status Unknown	434 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	439 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	
Lead Status Unknown	452 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	R) Unknown - Unlikely Lead	
Non-Lead	503/505 W QUEEN ST	D) Copper	No	P) 2021 - 2030	REMOVED LEAD GOOSENECK	D) Copper	customer verified copper
Non-Lead	54 W QUEEN ST	D) Copper	Not sure	O) 2011 - 2020	REPLACED WATER CURB VALVE	D) Copper	
Lead Status Unknown	83 W QUEEN ST	D) Copper	Not sure	O) 2011 - 2020		R) Unknown - Unlikely Lead	